

PRODUCT CATALOGUE X

Power Cable







CONTENTS

- PRODUCT STANDARDS.
- Some Of Cables Clients
- Power Cable
 - Low Voltage Power Cable
 - Medium Voltage Power Cable
 - High and Extra High Voltage Power Cable



PRODUCT STANDARDS

With years of professional experiences of research and development, iCable is able to manufacture and supply products according to different national and international standards. iCable is totally able to meet different normal and special technical, manufacture and test requirements.















AENOR





























Some of Cables Clients

iCables various products are widely used in different industries, including Electric Power, Petrifaction, Railway, Construction, Automobile, Metallurgical, Appliance and so on. iCable's clients cover Power Utility, Electricity Supply Company, EPC Contractor, Construction Corporation, Real Estate Corporation, Railway Bureau, Factories, and many others.









































































































PRODUCT CATALOGUE













Part I Low Voltage Power Cable



CU(AL)/PVC/PVC 0.6/1(1.2)kV

CU(AL)/PVC/PVC/SSTA/PVC 0.6/1(1.2)kV

CU(AL)/PVC/PVC/STA/PVC 0.6/1(1.2)kV

CU(AL)/PVC/PVC/AWA/PVC 0.6/1(1.2)kV

CU(AL)/PVC/PVC/SWA/PVC 0.6/1(1.2)kV

CU(AL,AA)/XLPE/PVC 0.6/1(1.2)kV~1.8/3(3.6)kV

CU(AL,AA)/XLPE/PVC/SSTA/PVC 0.6/1(1.2)kV~1.8/3(3.6)kV

CU(AL,AA)/XLPE/PVC/STA/PVC 0.6/1(1.2)kV~1.8/3(3.6)kV

CU(AL)/XLPE/PVC/AWA/PVC 0.6/1(1.2)kV~1.8/3(3.6)kV

CU(AL)/XLPE/PVC/SWA/PVC 0.6/1(1.2)KV~1.8/3(3.6)kV





CU(AL)/PVC/PVC 0.6/1(1.2) kV

Standards

• AS/NZS 5000.1 • DIN VDE 0276-603

IEC 60502-1 • HD 603

Application

The cable is used for electricity supply in low voltage installation system, suitable for installation in indoors and outdoors, in cable ducts, underground, in power and switching stations, local energy distributions, industrial plants, where there is no risk of mechanical damage.

AS/NZS 5000.1

• Conductor: Copper/Aluminum

Insulation: PVCSheath: PVC

(Optional) Flame Retardant Property

• (Optional) Fire Resistant Property

• (Optional) Anti-Termite & Rodent Property

(Optional) Water Resistant Property



Section	Insulation Thickness	Sheath Thickness	Overall Diameter		Weight	DC. Electrical Re	
No.xmm²	mm	mm	mm	Cu kg	Al /km	Cu Ω/	Al km
1x0.5	0.8	1.4	5.2	37		36.0	(50)
1x0.75	0.8	1.4	5.4	41		24.9	-
1x1.5	0.8	1.4	5.8	52	43	12.1	18.1
1x2.5	0.8	1.4	6.2	65	50	7.41	12.1
1x4	1.0	1.4	7.1	90	66	4.61	7.41
1x6	1.0	1.4	7.6	114	77	3.08	4.61
1x10	1.0	1.4	8.9	166	103	1.83	3.08
1x16	1.0	1.4	9.9	230	131	1.15	1.91
1x25	1.2	1.4	11.6	338	182	0.727	1.20
1x35	1.2	1.4	12.2	428	214	0.524	0.868
1x50	1.4	1.4	13.9	565	276	0.387	0.641
1x70	1.4	1.5	15.6	778	360	0.268	0.443
1x95	1.6	1.5	17.7	1050	470	0.193	0.320
1x120	1.6	1.6	19.4	1299	567	0.153	0.253
1x150	1.8	1.6	21.3	1587	683	0.124	0.206
1x185	2.0	1.6	23.5	1970	839	0.0991	0.164
1x240	2.2	1.7	26.4	2555	1069	0.0754	0.125
1x300	2.4	1.8	29.2	3178	1313	0.0601	0.100
1x400	2.6	1.9	32.7	4025	1641	0.0470	0.0778
1x500	2.8	2.0	36.3	5110	2048	0.0366	0.0609
1x630	2.8	2.1	40.0	6296	2537	0.0283	0.0469
1x800	2.8	2.2	44.2	8203	3133	0.0221	0.0367
2x0.5	0.8	1.8	9.6	93	-	36.0	-
2x0.75	0.8	1.8	10.0	103		24.9	
2x1.5	0.8	1.8	10.8	129	110	12.1	18.1
2x2.5	0.8	1.8	11.6	158	127	7.41	12.1
2x4	1.0	1.8	13.4	218	168	4.61	7.41
2x6	1.0	1.8	14.4	272	196	3.08	4.61
2x10	1.0	1.8	17.0	392	265	1.83	3.08
2x16	1.0	1.8	19.0	536	335	1.15	1.91
2x25	1.2	1.8	22.4	781	465	0.727	1.20
	1.2	1.8		974	541	0.524	0.868
2x35 2x50	1.4	1.8	23.6	1286	700	0.324	0.641
	1,4		27.0				
2x70		1.9	30.2	1750	901	0.268	0.443
2x95	1.6	2.0	34.6	2371	1192	0.193	0.320
2x120	1.6	2.1	37.8	2917	1431	0.153	0.253
2x150	1.8	2.2	41.8	3579	1744	0.124	0.206
2x185	2.0	2.4	46.2	4445	2150	0.0991	0.164
2x240	2.2	2.6	52.0	5762	2745	0.0754	0.125
2x300	2.4	2.7	57.4	7142	3357	0.0601	0.100
2x400	2.6	3.0	64.6	9079	4239	0.0470	0.0778
2x500	2.8	3.2	71.8	11503	5287	0.0366	0.0605
3x0.5	0.8	1.8	10.0	107	-	36.0	-
3x0.75	0.8	1.8	10.4	119		24.9	
3x1.5	0.8	1.8	11.3	155	126	12.1	18.1
3x2.5	0.8	1.8	12.1	194	147	7.41	12.1
3x4	1.0	1.8	14.1	274	199	4.61	7.41
3x6	1.0	1.8	15.2	350	236	3.08	4.61
3x10	1.0	1.8	18.0	512	322	1.83	3.08
3x16	1.0	1.8	20.1	714	412	1.15	1.91
3x25	1.2	1.8	23.8	1055	580	0.727	1.20
3x35	1.2	1.8	25.1	1334	685	0.524	0.868
3x50	1.4	1.8	28.8	1772	893	0.387	0.641
3x70	1.4	2.0	32.4	2446	1173	0.268	0.443
3x95	1.6	2.1	37.2	3328	1560	0.193	0.320
3x120	1.6	22	40.6	4105	1875	0.153	0.253





CU(AL)/PVC/PVC 0.6/1(1.2) kV Conductor: Copper/Aluminum Insulation: PVC Sheath: PVC

Section	Insulation Thickr	ness Sheath Thickness	Overall Diameter		able Weight		Resistance at 20°C
No.xmm ²	mm	mm	mm	Cu	Al kg/km	Cu	Al 2/km
3x150	1.8	2.3	44.9	5041	2289	0.124	0.206
3x185	2.0	2.5	49.6	6267	2824	0.0991	0.164
3x240	2.2	2.7	55.8	8137	3612	0.0754	0.125
3x300	2.4	2.9	61.9	10138	4460	0.0601	0.100
3x400	2.6	3.1	69.4	12855	5595	0.0470	0.0778
3x500	2.8	3.4	77.3	16349	7026	0.0366	0.0605
4x0.5	0.8	1.8	10.6	123	-	36.0	-
	0.8				-	24.9	
4x0.75		1.8	11,1	140	147		10.1
4x1.5	0.8	1.8	12.1	185	147	12.1	18.1
4x2.5	0.8	1.8	13.0	236	174	7.41	12.1
4x4	1.0	1.8	15.2	338	238	4.61	7.41
4x6	1.0	1.8	16.4	435	283	3.08	4.61
4x10	1.0	1.8	19.6	645	392	1.83	3.08
4x16	1.0	1.8	22.0	909	507	1.15	1.91
4x25	1.2	1.8	26.1	1353	719	0.727	1.20
4x35	1.2	1.8	27.5	1720	854	0.524	0.868
4x50	1.4	1.9	27.7	2196	1023	0.387	0.641
4X70	1.4	2.1	31.8	3054	1357	0.268	0.443
4X95	1.6	2.2	41.2	4346	1989	0.193	0.320
4X120	1.6	2.4	45.2	5386	2412	0.153	0.253
4X150	1.8	2.5	50.0	6615	2946	0.124	0.206
4X185	2.0	2.7	55.2	8223	3632	0.0991	0.164
4X240	2.2	2.9	62.2	10686	4652	0.0754	0.125
4X240 4X300	2.4	3.1	68.9	13309	5739	0.0601	0.125
4x400	2.6	3.4	77.5	16916	7236	0.0470	0.0778
4x500	2.8	3.6	86.1	21477	9046	0.0366	0.0605
5x0.5	0.8	1.8	11.3	142		36.0	-
5x0.75	0.8	1.8	11.8	162	-	24.9	-
5x1.5	0.8	1.8	12.9	216	169	12.1	18.1
5x2.5	0.8	1.8	14.0	280	202	7.41	12.1
5x4	1.0	1.8	16.4	404	279	4.61	7.41
5x6	1.0	1.8	17.8	525	335	3.08	4.61
5x10	1.0	1.8	21.3	782	466	1.83	3.08
5x16	1.0	1.8	24.0	1110	607	1.15	1.91
5x25	1.2	1.8	28.6	1660	868	0.727	1.20
5x35	1.2	1.9	30.4	2132	1049	0.524	0.868
5x50	1.4	2.1	35.4	2873	1407	0.387	0.641
5x70	1.4	2.2	39.6	3953	1831	0.268	0.443
5x95	1.6	2.4	45.7	5411	2464	0.193	0.320
5x120	1.6	2.5	50.0	6685	2968	0.153	0.253
5x150	1.8	2.7	55.5	8236	3650	0.124	0.206
5x185	2.0	2.9	61.3	10238	4499	0.0991	0.164
5x240	2.2	3.1	69.0	13299	5757	0.0754	0.125
5x300	2.4	3.3	76.4	16561	7098	0.0601	0.100
5x400	2.6	3.7	86.1	21081	8981	0.0470	0.0778
5x500	2.8	4.0	95.9	26809	11271	0.0366	0.0605
2x1+1x0.5	0.8 0	1.8	10.4	122	2	18.1/36.0	2
2x1+1x0.75	0.8 0	.8 1.8	10.5	126	-	18.1/24.5	-
2x1.5+1x1		1.8	11.0	145	0	12.1/18.1	-
2x2.5+1x1.5		1.8	11.8	180	140	7.41/12.1	12.1/18.1
2x4+1x1.5		.0 1.8	13.4	237	178	4.61/12.1	7.41/18.1
2x4+1x1.5		.0 1.8	13.5	248	182	4.61/7.41	7.41/12.1
			14.4	300			
2x6+1x2.5		.0 1.8			209	3.08/7.41	4.61/12.1
2x6+1x4		.0 1.8	14.8	323	223	3.08/4.61	4.61/7.41
2x10+1x4		.0 1.8	17.0	436	285	1.83/4.61	3.08/7.41
2x10+1x6		.0 1.8	17.1	457	293	1.83/3.08	3.08/4.61
2x16+1x6		.0 1.8	19.0	599	361	1.15/3.08	1.91/4.61
2x16+1x10		.0 1.8	19.4	644	381	1.15/1.83	1.91/3.08
2x25+1x6	1.2 1	.0 1.8	22.8	853	499	0.727/3.08	1.20/4.61
2x25+1x10	1.2 1	.0 1.8	22.4	881	502	0.727/1.83	1.20/3.08
2x25+1x16		.0 1.8	22.7	940	525	0.727/1.15	1.20/1.91
2x35+1x10		.0 1.8	23.6	1074	579	0.524/1.83	0.868/3.08
2x35+1x16		.0 1.8	23.7	1129	597	0.524/1.15	0.868/1.91
2x35+1x15		.2 1.8	24.6	1236	646	0.524/0.727	0.868/1.20
2x50+1x16		.0 1.8	27.0	1438	753	0.387/1.15	0.641/1.9
			27.3				
2x50+1x25		.2 1.8		1531	789	0.387/0.727	0.641/1.20
2x50+1x35		.2 1.8	27.6	1621	821	0.387/0.524	0.641/0.86
2x70+1x16		.0 1.8	30.4	1901	953	0.268/1.15	0.443/1.9
2x70+1x25		.2 1.8	30.0	1974	969	0.268/0.727	0.443/1.20
2x70+1x35		.2 1.8	30.3	2072	1009	0.268/0.524	0.443/0.86
2x70+1x50		.4 1.9	31.1	2207	1069	0.268/0.387	0.443/0.64
2x95+1x35	1.6 1	.2 1.9	34.6	2690	1297	0.193/0.524	0.320/0.86
2x95+1x50	1.6 1	.4 2.0	34.7	2805	1337	0.193/0.387	0.320/0.64
		.4 2.0	35.7	3028	1431	0.193/0.268	0.320/0.44
2x95+1x70							





CU(AL)/PVC/PVC 0.6/1(1.2) kV
Conductor: Copper/Aluminum
Insulation: PVC
Sheath: PVC

Section	insulation	Thickness	Sheath Thickness	Overall Diameter		Weight	DC. Electrical Re	
No.xmm ²	m	ım	mm	mm	Cu kg	Al /km	Cu Ω/	km Al
2x120+1x70	1.6	1.4	2.1	38.1	3540	1635	0.153/0.268	0.253/0.44
2x120+1x95	1.6	1.6	2.1	39.5	3836	1768	0.153/0.193	0.253/0.32
2x150+1x50	1.8	1.4	2.2	41.8	4010	1886	0.124/0.387	0.206/0.64
2x150+1x70	1.8	1.4	2.2	41.8	4191	1938	0.124/0.268	0.206/0.44
2x150+1x95	1.8	1.6	2.2	42.5	4464	2049	0.124/0.193	0.206/0.32
2x150+1x120	1.8	1.6	2.3	43.4	4711	2144	0.124/0.153	0.206/0.25
2x185+1x70	2.0	1.4	2.3	46.0	5037	2324	0.0991/0.268	0.164/0.44
2x185+1x95	2.0	1.6	2.4	46.2	5292	2416	0.0991/0.193	0.164/0.32
2x185+1x120	2.0	1.6	2.4	46.8	5529	2501	0.0991/0.153	0.164/0.25
2x185+1x150	2.0	1.8	2.4	47.8	5820	2621	0.0991/0.124	0.164/0.20
2x240+1x70	2.2	1.4	2.4	52.5	6371	2936	0.0754/0.268	0.125/0.44
2x240+1x95	2.2	1.6	2.5	51.8	6586	2989	0.0754/0.193	0.125/0.32
2x240+1x120	2.2	1.6	2.5	51.8	6797	3048	0.0754/0.153	0.125/0.25
2x240+1x150	2.2	1.8	2.6	52.7	7101	3180	0.0754/0.124	0.125/0.20
2x300+1x95	2.4	1.6	2.6	57.7	7990	3624	0.0601/0.193	0.100/0.32
2x300+1x120	2.4	1.6	2.7	57.4	8200	3682	0.0601/0.153	0.100/0.25
2x300+1x150	2.4	1.8	2.7	57.4	8447	3758	0.0601/0.124	0.100/0.20
2x300+1x185	2.4	2.0	2.8	58.4	8841	3926	0.0601/0.0991	0.100/0.16
2x300+1x240	2.4	2.2	2.8	59.6	9412	4141	0.0601/0.0754	0.100/0.12
2x400+1x120	2.6	1.6	2.8	65.1	10134	4561	0.0470/0.153	0.0778/0.2
2x400+1x150	2.6	1.8	2.9	64.4	10357	4613	0.0470/0.124	0.0778/0.2
2x400+1x185	2.6		2.9					
		2.0		64.4	10683	4713	0.0470/0.0991	0.0778/0.1
2x400+1x240	2.6	2.0	3.0	65.5	11271	4945	0.0470/0.0754	0.0778/0.1
x500+1x150	2.8	1.8	3.0	72.4	12810	5691	0.0366/0.124	0.0605/0.2
x500+1x185	2.8	2.0	3.1	71.6	13103	5757	0.0366/0.0991	0.0605/0.1
x500+1x240	2.8	2.2	3.1	71.6	13609	5908	0.0366/0.0754	0.0605/0.1
2x500+1x300	2.8	2.4	3.2	72.8	14245	6165	0.0366/0.0601	0.0605/0.1
3x1+1x0.5	0.8	0.8	1.8	11.1	145	-	18.1/36.0	
						-		
3x1+1x0.75	0.8	0.8	1.8	11.3	151		18.1/24.5	
3x1.5+1x1	0.8	0.8	1.8	11.9	177	-	12.1/18.1	-
3x2.5+1x1.5	0.8	8.0	1.8	12.8	223	167	7.41/12.1	12.1/18.1
3x4+1x1.5	1.0	8.0	1.8	14.4	298	214	4.61/12.1	7.41/18.1
3x4+1x2.5	1.0	8.0	1.8	14.6	311	220	4.61/7.41	7.41/12.1
3x6+1x2.5	1.0	0.8	1.8	15.6	384	256	3.08/7.41	4.61/12.1
3x6+1x4	1.0	1.0	1.8	16.1	409	271	3.08/4.61	4.61/7.41
3x10+1x4	1.0	1.0	1.8	18.5	566	351	1.83/4.61	3.08/7.41
3x10+1x6	1.0	1.0	1.8		590	363		
				18.8			1.83/3.08	3.08/4.61
3x16+1x6	1.0	1.0	1.8	20.6	787	448	1.15/3.08	1.91/4.61
3x16+1x10	1,0	1.0	1.8	21.3	839	475	1.15/1.83	1.91/3.08
3x25+1x6	1.2	1.0	1.8	24.0	1123	610	0.727/3.08	1.20/4.61
3x25+1x10	1.2	1.0	1.8	24.5	1172	634	0.727/1.83	1.20/3.08
3x25+1x16	1.2	1.0	1.8	25.0	1236	662	0.727/1.15	1.20/1.91
3x35+1x10	1.2	1.0	1.8	25.7	1449	737	0.524/1.83	0.868/3.0
3x35+1x16	1.2	1.0	1.8	26.1	1512	763	0.524/1.15	0.868/1.9
3x35+1x25	1.2	1.2	1.8	27.1	1623	817	0.524/0.727	0.868/1.2
3x50+1x16	1.4	1.0	1.9	29.6	1954	975	0.387/1.15	0.641/1.9
3x50+1x25	1.4	1.2	1.9	30.4	2062	1026	0.387/0.727	0.641/1.2
3x50+1x35	1.4	1.2	1.9	30.8	2155	1062	0.387/0.524	0.641/0.86
3x70+1x16	1.4	1.0	1.9	32.5	2593	1221	0.268/1.15	0.443/1.9
3x70+1x25	1.4	1.2	2.0	33.8	2721	1292	0.268/0.727	0.443/1.2
3x70+1x35	1.4	1.2	2.0	34.7	2809	1322	0.268/0.524	0.443/0.86
3x70+1x50	1.4	1.4	2.0	38.3	2950	1388	0.268/0.387	0.443/0.64
3x95+1x35	1.6	1.2	2.1	39.0	3675	1694	0.193/0.524	0.320/0.86
3x95+1x50	1.6	1.4	2.2	39.0	3833	1776	0.193/0.387	0.320/0.64
3x95+1x70	1.6	1.4	2.2	39.9	4048	1862	0.193/0.268	0.320/0.44
3x120+1x50	1.6	1.4	2.2	41.9	4586	2067	0.153/0.387	0.253/0.64
3x120+1x70	1.6	1.4	2.3	41.7	4990	2179	0.153/0.268	0.253/0.44
3x120+1x95	1.6	1.6	2.3	43.9	5092	2282	0.153/0.193	0.253/0.32
3x150+1x50	1.8	1.4	2.4	46.0	5530	2489	0.124/0.387	0.206/0.64
3x150+1x70	1.8	1.4	2.4	46.5	5732	2563	0.124/0.268	0.206/0.44
3x150+1x95	1.8	1.6	2.4	47.6	6015	2683	0.124/0.193	0.206/0.32
8x150+1x120	1.8	1.6	2.5	48.7	6287	2803	0.124/0.153	0.206/0.25
3x185+1x70	2.0	1.4	2.5	51.5	6934	3073	0.0991/0.268	0.164/0.44
3x185+1x95	2.0	1.6	2.6	51.8	7230	3206	0.0991/0.193	0.164/0.32
x185+1x120	2.0	1.6	2.6	52.6	7479	3304	0.0991/0.153	0.164/0.25
x185+1x150	2.0	1.8	2.6	53.6	7776	3429	0.0991/0.124	0.164/0.20
3x240+1x70	2.2	1.4	2.7	57.7	8806	3862	0.0754/0.268	0.125/0.44
3x240+1x95	2.2	1.6	2.7	57.7	9041	3935	0.0754/0.193	0.125/0.32
8x240+1x120	2.2	1.6	2.8	58.1	9330	4072	0.0754/0.153	0.125/0.25
3x240+1x150	2.2	1.8	2.8	59.0	9625	4196	0.0754/0.124	0.125/0.20
3x300+1x95	2.4	1.6	2.9	62.6	11024	4766	0.0601/0.193	0.100/0.32
3x300+1x120	2,4	1.6	2.9	63.4	11281	4872	0.0601/0.153	0.100/0.25
	2.4	1.8	3.0	64.4	11603	5022	0.0601/0.124	0.100/0.20
3x300+1x150								
x300+1x185	2.4	2.0	3.0	65.4	11989	5181	0.0601/0.0991	0.100/0.16
x300+1x240	2.4	2.2	3.1	67.1	12615	5451	0.0601/0.0754	0.100/0.12
x400+1x120	2.6	1.6	3.1	70.0	13951	5958	0.0470/0.153	0.0778/0.2
X400+1X120								





CU(AL)/PVC/PVC 0.6/1(1.2) kV Conductor: Copper/Aluminum Insulation: PVC Sheath: PVC

No.mm	0.754
Name Na	0991 0.0778/0 07954 0.0778/0 07954 0.0605/0 0991 0.0605/0 07954 0.0605/0 0601 0.0605/0 6.0 - 4.5 - 2.1 12.1/18 2.1 7.41/18 41 7.41/18 41 4.61/12 61 4.61/7 61 3.08/7 08 3.08/4 08 1.91/4 83 1.91/3
3800-11520	0.754
3-500-11-150	1.124 0.0605/0 0991 0.0605/0 0754 0.0605/0 0754 0.0605/0 0601 0.0605/0 5.0 - 4.5 - 3.1 - 2.1 12.1/18 2.1 7.41/12 4.1 4.61/12 6.1 4.61/12 6.1 4.61/7 6.1 3.08/7 0.08 3.08/4 0.08 1.91/4 8.3 1.91/3
3:500-1:150	1.124 0.0605/0 0991 0.0605/0 0754 0.0605/0 0754 0.0605/0 0601 0.0605/0 5.0 - 4.5 - 3.1 - 2.1 12.1/18 2.1 7.41/12 4.1 4.61/12 6.1 4.61/12 6.1 4.61/7 6.1 3.08/7 0.08 3.08/4 0.08 1.91/4 8.3 1.91/3
3:500-11:240	0991 0.0605/0 0754 0.0605/0 0601 0.0605/0 5.0 4.5 8.1 2.1 12.1/18 2.1 7.41/18 41 4.61/12 61 4.61/12 61 4.61/7 61 3.08/7 08 3.08/4 08 1.91/4 83 1.91/3
3:600-1:4200	0.754
3x5091x300	0601 0.0605/0 5.0 - 4.5 - 3.1 - 2.1 12.1/18 2.1 7.41/12 41 7.41/12 41 4.61/7: 61 4.61/7: 61 3.08/7. 08 3.08/4: 08 1.91/4. 83 1.91/3:
341-220.5	6.0 -4.5 -5.3.1 -7.3.1 -7.3.1 -7.3.1 -7.3.1 -7.3.1 -7.3.1 -7.3.1 -7.4.1/12 -4.1 -7.4.1/12 -4.1 -4.6.1/12 -6.1 -4.6.1/12 -6.1 -3.0.8/12 -0.0 -6.1 -3.0.8/42 -0.0 -7.3.1 -9.1/32 -7.3.1 -9.1
311+20/75	4.5
34.5-2-21	8.1
342-52-615	2.1 12.1/18 2.1 7.41/18 41 7.41/12 41 4.61/12 61 4.61/73 61 3.08/73 08 3.08/43 08 1.91/43 83 1.91/33
344-22.5	2.1 7.41/18 41 7.41/12 41 4.61/12 61 4.61/7. 61 3.08/7. 08 3.08/4. 08 1.91/4.
344-22.5 1.0 0.8 1.8 15.1 329 235 46.9 46.5 36.4 22.2 5 1.0 0.8 1.8 15.5 35.5 24.9 46.5 36.4 22.2 5 1.0 0.8 1.8 16.4 42.8 28.3 3.0.9 36.4 22.2 5 1.0 0.8 1.8 16.4 42.8 28.3 3.0.9 36.4 22.4 1.0 1.0 1.0 1.8 17.2 47.5 31.2 3.0.9 3.0.9 3.0.4 22.4 1.0 1.0 1.0 1.8 17.5 65.2 37.2 12.3 3.0.9 3.0.0 2.0 1.0 1.0 1.8 17.5 65.2 37.2 1.0 3.0.9 3.0 3.0 3.0 3.0 3.0 3.0 3.0 3.0 3.0 3.0	2.1 7.41/18 41 7.41/12 41 4.61/12 61 4.61/7. 61 3.08/7. 08 3.08/4. 08 1.91/4.
364-2225	41 7.41/12 41 4.61/12 61 4.61/7. 61 3.08/7. 08 3.08/4. 08 1.91/4. 83 1.91/3.
366-222.5	41 4.61/12 61 4.61/7. 61 3.08/7. 08 3.08/4. 08 1.91/4. 83 1.91/3.
336-224	61 4.61/7. 61 3.08/7. 08 3.08/4. 08 1.91/4. 83 1.91/3.
3x10+2x4	61 3.08/7. 08 3.08/4. 08 1.91/4. 83 1.91/3.
3x10+2x6	08 3.08/4. 08 1.91/4. 83 1.91/3.
3x16+2x16	08 1.91/4. 83 1.91/3.
3.416+2x10 1.0 1.0 1.8 2.9 978 5.49 1.15/ 3x25+2x10 1.2 1.0 1.8 24.9 1210 659 0.727, 3x25+2x16 1.2 1.0 1.8 25.9 1309 708 0.727, 3x25+2x16 1.2 1.0 1.8 26.8 1439 763 0.727, 3x25+2x16 1.2 1.0 1.8 26.8 1439 763 0.727, 3x25+2x16 1.2 1.0 1.8 27.0 1586 810 0.524, 3x35+2x16 1.2 1.0 1.9 31.1 2155 1074 0.387, 3x50+2x51 1.1 1.2 1.9 31.1 2155 1074 0.387, 3x50+2x51 1.4 1.2 1.9 32.6 2373 1177 0.387, 3x50+2x51 1.4 1.2 1.9 32.6 2373 1177 0.387, 3x70+2x5 1.4 1.2 2.0 33.4 2572 1259 0.387, 3x70+2x5 1.4 1.2 2.0 33.4 2572 1259 0.387, 3x70+2x5 1.4 1.2 2.0 35.4 30.5 1435 0.268, 3x70+2x35 1.4 1.2 2.0 35.4 30.5 1435 0.268, 3x70+2x35 1.4 1.2 2.1 36.1 3223 1516 0.268, 3x70+2x5 1.4 1.4 2.1 37.8 3509 1650 0.268, 3x70+2x5 1.6 1.4 2.2 2 41.6 4376 2022 0.193, 3x55+2x5 1.6 1.4 2.2 2 41.6 4376 2022 0.193, 3x120+2x7 0.16 1.4 2.3 44.5 51.6 2329 0.153, 3x120+2x7 0.16 1.4 2.4 460 5589 2510 0.153, 3x150+2x5 1.8 1.4 2.4 460 5589 2510 0.153, 3x150+2x5 1.8 1.4 2.4 460 5589 2510 0.153, 3x150+2x5 1.8 1.6 2.6 53.8 70.9 94.6 615 2.9 0.133, 3x150+2x5 1.8 1.6 2.6 53.8 70.9 94.6 4148 0.0991, 3x150+2x5 1.8 1.6 2.6 53.8 70.9 94.6 4148 0.0991, 3x150+2x5 2.0 1.6 2.7 55.4 82.9 637 40.991, 3x150+2x5 2.0 1.8 2.8 2.9 63.8 1125 80.9 94.6 4148 0.0991, 3x150+2x5 2.0 1.6 2.7 55.4 82.9 637 40.991, 3x150+2x5 2.0 1.6 2.7 55.4 82.9 638 1125 80.90 90.954, 3x150+2x5 2.0 1.6 2.9 63.9 63.8 1125 80.90 90.954, 3x150+2x5 2.0 2.1 8 2.9 63.8 1125 80.90 90.954, 3x150+2x5 2.0 2.1 8 2.9 63.8 1125 80.90 90.954, 3x150+2x5 2.0 2.1 8 3.1 66.0 6.9 12598 534 40.00 90.954, 3x150+2x5 2	83 1.91/3.
3325+2x10	
3325+2x10	
3x25+2x10	
3a25+2x16	.83 1.20/3.
3x35+2x10	
3x35+2x16	
3x35+2x25	
3x50+2x16	
3x50+2x25	727 0.868/1
3x50+2x25	.15 0.641/1
3x50+22x55	
3x70+2x16	
3x70+2x25 1.4 1.2 2.0 35.4 3025 1435 0.268/ 3x70+2x35 1.4 1.2 2.1 36.1 3223 1516 0.268/ 3x70+2x50 1.4 1.4 2.1 37.8 3509 1650 0.268/ 3x95+2x35 1.6 1.2 2.2 40.1 4091 1890 0.193/ 3x95+2x50 1.6 1.4 2.2 41.6 4376 2022 0.193/ 3x95+2x70 1.6 1.4 2.3 43.3 4823 206 0.193/ 3x120+2x50 1.6 1.4 2.3 44.5 5146 2329 0.153/ 3x120+2x70 1.6 1.4 2.3 44.5 5146 2329 0.153/ 3x120+2x70 1.6 1.4 2.3 44.5 5146 2329 0.153/ 3x120+2x95 1.6 1.6 2.4 2.4 46.0 5589 2510 0.153/ 3x120+2x95 1.8 1.4 2.4 48.2 6070 2732 0.124/ 3x150+2x95 1.8 1.4 2.4 48.2 6070 2732 0.124/ 3x150+2x95 1.8 1.4 2.5 49.6 6515 2914 0.124/ 3x150+2x10 1.8 1.6 2.6 53.3 7609 3371 0.124/ 3x150+2x95 1.8 1.6 2.6 53.3 7609 3371 0.124/ 3x150+2x95 2.0 1.6 2.7 55.4 8296 3674 0.0991, 3x185+2x95 2.0 1.6 2.7 55.4 8296 3674 0.0991, 3x185+2x95 2.0 1.6 2.7 55.4 8296 3674 0.0991, 3x185+2x150 2.0 1.8 2.8 58.9 9426 4148 0.0991, 3x185+2x150 2.0 1.8 2.8 58.9 9426 4148 0.0991, 3x240+2x95 2.2 1.6 2.9 61.9 10647 4634 0.0754, 3x240+2x150 2.2 1.6 2.9 61.9 10647 4634 0.0754, 3x240+2x150 2.2 1.8 2.9 63.8 11258 4899 0.0754, 3x240+2x150 2.2 1.8 3.1 6.6 2.9 61.9 10647 4634 0.0754, 3x340+2x150 2.4 1.8 3.1 68.6 13233 5711 0.0601, 3x300+2x150 2.4 1.8 3.3 75.0 15912 6818 0.0470, 3x300+2x150 2.6 1.8 3.3 75.0 15912 6818 0.0470, 3x300+2x150 2.8 1.8 3.4 79.5 17939 7662 0.0470, 3x300+2x150 2.8 1.8 3.3 75.0 15912 6818 0.0470, 3x300+2x150 2.8 1.8 3.3 75.0 15912 6818 0.0470, 3x300+2x150 2.8 1.8 3.3 75.0 15912 6818 0.0470, 3x300+2x150 2.8 1.8 3.3 4 81.5 13904 8147 0.0366, 3x500+2x240 2.6 2.8 2.9 3.5 838 201364 9024 0.0366/	
3x70+2x35	
3x70+2x50 1.4 1.4 2.1 37.8 3509 1650 0.268/ 3x95+2x55 1.6 1.2 2.2 40.1 4091 1890 0.193/ 3x95+2x50 1.6 1.4 2.2 41.6 4376 2022 0.193/ 3x95+2x70 1.6 1.4 2.3 43.3 4823 2206 0.193/ 3x120+2x50 1.6 1.4 2.3 44.5 5146 2329 0.153/ 3x120+2x70 1.6 1.4 2.4 46.0 5589 2510 0.153/ 3x120+2x95 1.6 1.6 1.6 2.5 48.3 6179 2770 0.153/ 3x150+2x50 1.8 1.4 2.4 48.2 6070 2732 0.124/ 3x150+2x70 1.8 1.6 2.6 51.8 7108 3371 0.124/ 3x150+2x70 1.8 1.6 2.6 53.4 7705 3413 0.0991, 3x185	
3x95+2x35	524 0.443/0.
3x95+2x50	387 0.443/0.
3x95+2x70	524 0.320/0.
3x95+2x70	387 0.320/0.
3x120+2x50	
3x120+2x70	
3x120+2x95	
3x150+2x50	
3x150+2x70 1.8 1.4 2.5 49.6 6515 2914 0.124/ 3x150+2x95 1.8 1.6 2.6 51.8 7108 3177 0.124/ 3x150+2x120 1.8 1.6 2.6 53.3 7609 3371 0.124/ 3x185+2x70 2.0 1.4 2.6 53.4 7705 3413 0.0991, 3x185+2x95 2.0 1.6 2.7 55.4 8296 3674 0.0991, 3x185+2x120 2.0 1.6 2.7 56.9 8802 3872 0.0991, 3x185+2x150 2.0 1.8 2.8 58.9 9426 4148 0.0971, 3x240+2x70 2.2 1.4 2.7 58.6 9528 4154 0.0754, 3x240+2x95 2.2 1.6 2.8 60.6 10130 4426 0.0754, 3x240+2x150 2.2 1.6 2.9 61.9 10647 4634 0.0754, 3x240+2x15	
3x150+2x95 1.8 1.6 2.6 51.8 7108 3177 0.124/8x150+2x120 1.8 1.6 2.6 53.3 7609 3371 0.124/8x150+2x120 2.0 1.4 2.6 53.4 7705 3413 0.0991,3x185+2x70 2.0 1.6 2.7 55.4 8296 3674 0.0991,3x185+2x120 2.0 1.6 2.7 56.9 8802 3872 0.0991,3x185+2x150 2.0 1.8 2.8 58.9 9426 4148 0.0991,3x240+2x70 2.2 1.4 2.7 58.6 9528 4154 0.0754,3x240+2x95 2.2 1.6 2.8 60.6 10130 4426 0.0754,3x240+2x95 2.2 1.6 2.8 60.6 10130 4426 0.0754,3x240+2x95 2.2 1.6 2.9 61.9 10647 4634 0.0754,3x240+2x150 2.2 1.8 2.9 63.8 11258 4899 0.0754,3x240+2x150 2.2 1.8 2.9 63.8 11258 4899 0.0754,4x240+2x150 2.2	387 0.206/0.
8x150+2x120 1.8 1.6 2.6 53.3 7609 3371 0.124/ 3x185+2x70 2.0 1.4 2.6 53.4 7705 3413 0.0991, 3x185+2x95 2.0 1.6 2.7 55.4 8296 3674 0.0991, 3x185+2x120 2.0 1.6 2.7 56.9 8802 3872 0.0991, 3x185+2x150 2.0 1.8 2.8 58.9 9426 4148 0.0991, 3x240+2x70 2.2 1.4 2.7 58.6 9528 4154 0.0754, 3x240+2x95 2.2 1.6 2.8 60.6 10130 4426 0.0754, 3x240+2x120 2.2 1.6 2.8 60.6 10130 4426 0.0754, 3x240+2x150 2.2 1.8 2.9 63.8 11258 4899 0.0754, 3x240+2x150 2.2 1.8 3.0 65.8 12057 5237 0.0754, 3x30	268 0.206/0.
3x185+2x70 2.0 1.4 2.6 53.4 7705 3413 0.0991, 3x185+2x95 2.0 1.6 2.7 55.4 8296 3674 0.0991, 3x185+2x95 2.0 1.6 2.7 55.9 8802 3872 0.0991, 3x185+2x150 2.0 1.8 2.8 58.9 9426 4148 0.0991, 3x240+2x70 2.2 1.4 2.7 58.6 9528 4154 0.0754, 3x240+2x95 2.2 1.6 2.8 60.6 10130 4426 0.0754, 43x240+2x120 2.2 1.6 2.9 61.9 10647 4634 0.0754, 43x240+2x150 2.2 1.8 2.9 63.8 11258 4899 0.0754, 43x240+2x150 2.2 1.8 2.9 63.8 11258 4899 0.0754, 43x240+2x150 2.2 1.8 2.9 63.8 12057 5237 0.0754, 43x240+2x150 2.2 1.8 3.0 65.8 12057 5237 0.0754, 43x240+2x150 2.4 1.8 3.1 66.9 12598 5434 0.0601, 43x240+2x150	193 0.206/0.
3x185+2x70 2.0 1.4 2.6 53.4 7705 3413 0.0991, 3x185+2x95 2.0 1.6 2.7 55.4 8296 3674 0.0991, 3x185+2x95 2.0 1.6 2.7 55.9 8802 3872 0.0991, 3x185+2x150 2.0 1.8 2.8 58.9 9426 4148 0.0991, 3x240+2x70 2.2 1.4 2.7 58.6 9528 4154 0.0754, 3x240+2x95 2.2 1.6 2.8 60.6 10130 4426 0.0754, 43x240+2x120 2.2 1.6 2.9 61.9 10647 4634 0.0754, 43x240+2x150 2.2 1.8 2.9 63.8 11258 4899 0.0754, 43x240+2x150 2.2 1.8 2.9 63.8 11258 4899 0.0754, 43x240+2x150 2.2 1.8 2.9 63.8 12057 5237 0.0754, 43x240+2x150 2.2 1.8 3.0 65.8 12057 5237 0.0754, 43x240+2x150 2.4 1.8 3.1 66.9 12598 5434 0.0601, 43x240+2x150	153 0.206/0.
3x185+2x95 2.0 1.6 2.7 55.4 8296 3674 0.0991, 3x185+2x120 2.0 1.6 2.7 56.9 8802 3872 0.0991, 3x185+2x150 2.0 1.8 2.8 58.9 9426 4148 0.0991, 3x240+2x70 2.2 1.4 2.7 58.6 9528 4154 0.0754, 3x240+2x95 2.2 1.6 2.8 60.6 10130 4426 0.0754, 3x240+2x120 2.2 1.6 2.9 61.9 10647 4634 0.0754, 3x240+2x150 2.2 1.8 2.9 63.8 11258 4899 0.0754, 3x240+2x165 2.2 1.8 2.9 63.8 11258 4899 0.0754, 3x240+2x185 2.2 2.0 3.0 65.8 12057 5237 0.0754, 3x240+2x185 2.2 2.0 3.0 65.8 12057 5237 0.0754, 3x240+2x185 2.2 2.0 3.0 66.9 12598 5434 0.0601, 3x300+2x185 2.4 1.8 3.1 68.6 13233 5711 0.0601, 3x300+2x185 <	
8x185+2x120 2.0 1.6 2.7 56.9 8802 3872 0.0991, 3x185+2x150 2.0 1.8 2.8 58.9 9426 4148 0.0991, 3x240+2x70 2.2 1.4 2.7 58.6 9528 4154 0.0754, 3x240+2x95 2.2 1.6 2.8 60.6 10130 4426 0.0754, 3x240+2x120 2.2 1.6 2.9 61.9 10647 4634 0.0754, 3x240+2x150 2.2 1.8 2.9 63.8 11258 4899 0.0754, 3x240+2x185 2.2 2.0 3.0 65.8 12057 5237 0.0754/ 3x340+2x185 2.2 2.0 3.0 66.8 1258 5434 0.0601, 3x340+2x120 2.4 1.6 3.0 66.9 12598 5434 0.0601, 3x340+2x120 2.4 1.8 3.1 68.6 13233 5711 0.0601, 3x340+2x150 2.4 1.8 3.1 70.6 14014 6041 0.0601/ 3x340+2x160 2.4 2.2 3.2 73.4 15243 6549 0.0601/ 3x400+2x120	
8x185+2x150 2.0 1.8 2.8 58.9 9426 4148 0.0991, 3x240+2x70 2.2 1.4 2.7 58.6 9528 4154 0.0754, 3x240+2x95 2.2 1.6 2.8 60.6 10130 4426 0.0754, 43x240+2x120 2.2 1.6 2.9 61.9 10647 4634 0.0754, 45x240+2x150 2.2 1.8 2.9 63.8 11258 4899 0.0754, 45x240+2x185 2.2 2.0 3.0 65.8 12057 5237 0.0754, 45x240+2x185 2.2 2.0 3.0 66.9 12598 5434 0.0601, 3x300+2x120 2.4 1.6 3.0 66.9 12598 5434 0.0601, 3x300+2x150 2.4 1.8 3.1 68.6 13233 5711 0.0601, 3x300+2x185 2.4 2.0 3.1 70.6 14014 6041 0.0601/ 3x300+2x120 2.4 1.8 3.2 73.4 15243 6549 0.0601/ 3x400+2x120 2.6 1.6 3.2 73.3 15276 6529 0.0470/ 3x400+2x120	
3x240+2x70	
3x240+2x95	
8x240+2x120 2.2 1.6 2.9 61.9 10647 4634 0.0754, 8x240+2x150 2.2 1.8 2.9 63.8 11258 4899 0.0754, 8x240+2x185 2.2 2.0 3.0 65.8 12057 5237 0.0754/ 8x300+2x120 2.4 1.6 3.0 66.9 12598 5434 0.0601, 8x300+2x150 2.4 1.8 3.1 68.6 13233 5711 0.0601, 8x300+2x185 2.4 2.0 3.1 70.6 14014 6041 0.0601/ 8x300+2x185 2.4 2.2 3.2 73.4 15243 6549 0.0601/ 8x400+2x120 2.6 1.6 3.2 73.3 15276 6529 0.0470, 8x400+2x150 2.6 1.8 3.3 75.0 15912 6618 0.0470, 8x400+2x185 2.6 2.0 3.3 76.7 16693 7138 0.0470/	
8x240+2x150 2.2 1.8 2.9 63.8 11258 4899 0.0754, 3x240+2x185 2.2 2.0 3.0 65.8 12057 5237 0.0754/3 0.0601/3 0.0754/3 0.0754/3 0.0601/3 0.0754/3 0.0754/3 0.0754/3 0.0601/3 0.0754/3 0.0754/3 0.0601/3 0.0754/3 0.0754/3 0.0754/3 0.0754/3 0.0754/3 0.0754/3 0.0754/3 0.0754/3 0.0754/3 0.0754/3 0.0754/3 0.0601/3 0.0754/3 0.0754/3 0.0754/3 0.0754/4 0.0754/4 0.0754/4 0.0754/4 0.0754/4 0.0754/4 0.0754/4 0.0754/4 0.0754/4 0.0754/4 0.0754/4 0.0754/4 0.0754/4 0.0754/4 0.0754/4 0.0754/	.193 0.125/0.
8x240+2x185 2.2 2.0 3.0 65.8 12057 5237 0.0754/ 8x300+2x120 2.4 1.6 3.0 66.9 12598 5434 0.0601, 8x300+2x150 2.4 1.8 3.1 68.6 13233 5711 0.0601, 8x300+2x185 2.4 2.0 3.1 70.6 14014 6041 0.0601/ 8x300+2x240 2.4 2.2 3.2 73.4 15243 6549 0.0601/ 8x400+2x120 2.6 1.6 3.2 73.3 15276 6529 0.0470/ 8x400+2x150 2.6 1.8 3.3 75.0 15912 6818 0.0470/ 8x400+2x150 2.6 1.8 3.3 76.7 16693 7138 0.0470/ 8x400+2x185 2.6 2.2 3.4 79.5 17939 7662 0.0470/ 8x500+2x150 2.8 1.8 3.4 81.5 19304 8147 0.0366/	.153 0.125/0.
8x240+2x185 2.2 2.0 3.0 65.8 12057 5237 0.0754/ 8x300+2x120 2.4 1.6 3.0 66.9 12598 5434 0.0601, 8x300+2x150 2.4 1.8 3.1 68.6 13233 5711 0.0601, 8x300+2x185 2.4 2.0 3.1 70.6 14014 6041 0.0601/ 8x300+2x240 2.4 2.2 3.2 73.4 15243 6549 0.0601/ 8x400+2x120 2.6 1.6 3.2 73.3 15276 6529 0.0470/ 8x400+2x150 2.6 1.8 3.3 75.0 15912 6818 0.0470/ 8x400+2x150 2.6 1.8 3.3 76.7 16693 7138 0.0470/ 8x400+2x185 2.6 2.2 3.4 79.5 17939 7662 0.0470/ 8x500+2x150 2.8 1.8 3.4 81.5 19304 8147 0.0366/	.124 0.125/0.
8x300+2x120 2.4 1.6 3.0 66.9 12598 5434 0.0601, 8x300+2x150 2.4 1.8 3.1 68.6 13233 5711 0.0601, 8x300+2x165 2.4 2.0 3.1 70.6 14014 6041 0.0601/ 8x300+2x240 2.4 2.2 3.2 73.4 15243 6549 0.0601/ 8x400+2x120 2.6 1.6 3.2 73.3 15276 6529 0.0470/ 8x400+2x150 2.6 1.8 3.3 75.0 15912 6818 0.0470/ 8x400+2x155 2.6 2.0 3.3 76.7 16693 7138 0.0470/ 8x400+2x145 2.6 2.2 3.4 79.5 17999 7662 0.0470/ 8x400+2x150 2.8 1.8 3.4 81.5 19304 8147 0.0366/ 8x500+2x150 2.8 1.8 3.4 81.5 19304 8147 0.0366/ 8x500+2x185 2.8 2.8 2.0 3.5 83.3 20123 8505 0.0366/ 8x500+2x240 2.8 2.2 3.6 85.8 21364 9024 0.0366	
8x300+2x150 2.4 1.8 3.1 68.6 13233 5711 0.0601, 8x300+2x185 2.4 2.0 3.1 70.6 14014 6041 0.0601/ 8x300+2x240 2.4 2.2 3.2 73.4 15243 6549 0.0601/ 8x400+2x120 2.6 1.6 3.2 73.3 15276 6529 0.0470, 8x400+2x150 2.6 1.8 3.3 75.0 15912 6818 0.0470, 8x400+2x150 2.6 2.0 3.3 76.7 16693 7138 0.0470/ 8x400+2x240 2.6 2.2 3.4 79.5 17939 7662 0.0470/ 8x500+2x150 2.8 1.8 3.4 81.5 19304 8147 0.0366/ 8x500+2x185 2.8 2.0 3.5 83.3 20123 8505 0.0366/ 8x500+2x240 2.8 2.2 3.6 85.8 21364 9024 0.0366/ 924	
8x300+2x185 2.4 2.0 3.1 70.6 14014 6041 0.0601/ 8x300+2x240 2.4 2.2 3.2 73.4 15243 6549 0.0601/ 8x400+2x120 2.6 1.6 3.2 73.3 15276 6529 0.0470/ 8x400+2x150 2.6 1.8 3.3 75.0 15912 6818 0.0470/ 8x400+2x185 2.6 2.0 3.3 76.7 16693 7138 0.0470/ 8x400+2x240 2.6 2.2 3.4 79.5 17939 7662 0.0470/ 8x500+2x150 2.8 1.8 3.4 81.5 19304 8147 0.0366/ 8x500+2x185 2.8 2.0 3.5 83.3 20123 805 0.0366/ 8x500+2x240 2.8 2.2 3.6 85.8 21364 9024 0.0366/	
8x300+2x240 2.4 2.2 3.2 73.4 15243 6549 0.0601/ 8x400+2x120 2.6 1.6 3.2 73.3 15276 6529 0.0470/ 8x400+2x150 2.6 1.8 3.3 75.0 15912 6818 0.0470/ 8x400+2x185 2.6 2.0 3.3 76.7 16693 7138 0.0470/ 8x400+2x240 2.6 2.2 3.4 79.5 17939 7662 0.0470/ 8x500+2x150 2.8 1.8 3.4 81.5 19304 8147 0.0366/ 8x500+2x185 2.8 2.0 3.5 83.3 20123 8505 0.0366/ 8x500+2x240 2.8 2.2 3.6 85.8 21364 9024 0.0366/	
8x400+2x120 2.6 1.6 3.2 73.3 15276 6529 0.0470, 8x400+2x150 2.6 1.8 3.3 75.0 15912 6818 0.0470, 8x400+2x185 2.6 2.0 3.3 76.7 16693 7138 0.0470/ 8x400+2x240 2.6 2.2 3.4 79.5 17939 7662 0.0470/ 8x500+2x150 2.8 1.8 3.4 81.5 19304 8147 0.0366/ 8x500+2x185 2.8 2.0 3.5 83.3 20123 8505 0.0366/ 8x500+2x240 2.8 2.2 3.6 85.8 21364 9024 0.0366/	
8x400+2x150 2.6 1.8 3.3 75.0 15912 6818 0.0470/ 8x400+2x185 2.6 2.0 3.3 76.7 16693 7138 0.0470/ 8x400+2x240 2.6 2.2 3.4 79.5 17939 7662 0.0470/ 8x500+2x150 2.8 1.8 3.4 81.5 19304 8147 0.0366/ 8x500+2x185 2.8 2.0 3.5 83.3 20123 8505 0.0366/ 8x500+2x240 2.8 2.2 3.6 85.8 21364 9024 0.0366/	
8x400+2x185 2.6 2.0 3.3 76.7 16693 7138 0.0470/ 8x400+2x240 2.6 2.2 3.4 79.5 17939 7662 0.0470/ 8x500+2x150 2.8 1.8 3.4 81.5 19304 8147 0.0366/ 8x500+2x185 2.8 2.0 3.5 83.3 20123 8505 0.0366/ 8x500+2x240 2.8 2.2 3.6 85.8 21364 9024 0.0366/	.153 0.0778/0
8x400+2x185 2.6 2.0 3.3 76.7 16693 7138 0.0470/ 8x400+2x240 2.6 2.2 3.4 79.5 17939 7662 0.0470/ 8x500+2x150 2.8 1.8 3.4 81.5 19304 8147 0.0366/ 8x500+2x185 2.8 2.0 3.5 83.3 20123 8505 0.0366/ 8x500+2x240 2.8 2.2 3.6 85.8 21364 9024 0.0366/	.124 0.0778/0
8x400+2x240 2.6 2.2 3.4 79.5 17939 7662 0.0470/ 8x500+2x150 2.8 1.8 3.4 81.5 19304 8147 0.0366/ 8x500+2x185 2.8 2.0 3.5 83.3 20123 8505 0.0366/ 8x500+2x240 2.8 2.2 3.6 85.8 21364 9024 0.0366/	
8x500+2x150 2.8 1.8 3.4 81.5 19304 8147 0.0366, 8x500+2x185 2.8 2.0 3.5 83.3 20123 8505 0.0366/ 8x500+2x240 2.8 2.2 3.6 85.8 21364 9024 0.0366/	
3x500+2x185 2.8 2.0 3.5 83.3 20123 8505 0.0366/ 3x500+2x240 2.8 2.2 3.6 85.8 21364 9024 0.0366/	
3x500+2x240 2.8 2.2 3.6 85.8 21364 9024 0.0366/	
27500+27300 28 24 37 995 23602 0505 03266	
8x500+2x300 2.8 2.4 3.7 88.5 22693 9585 0.0366/	0601 0.0605/0
4x1+1x0.5 0.8 0.8 1.8 11.9 171 - 18.1/	5.0 -
4x1+1x0.75	
4x1.5+1x1	
4x2.5+1x1.5	
4x4+1x1.5 1.0 0.8 1.8 15.7 365 256 4.61/	
4x4+1x2.5 1.0 0.8 1.8 15.9 378 262 4.61/	
4x6+1x2.5 1.0 0.8 1.8 17.0 474 307 3.08/	41 4.61/12
4x6+1x4 1.0 1.0 1.8 17.5 499 323 3.08/	61 4.61/7.
4x10+1x4 1.0 1.0 1.8 20.4 706 428 1.83/	
4x10+1x6 1.0 1.0 1.8 20.6 729 438 1.83/	
4x16+1x6 1.0 1.0 1.8 22.8 991 551 1.15/	
4x16+1x10 1.0 1.0 1.8 23.4 1041 576 1.15/ 4x25+1x6 1.2 1.0 1.8 26.5 1436 755 0.727/	





CU(AL)/PVC/PVC 0.6/1(1.2) kV Conductor: Copper/Aluminum Insulation: PVC

0 Sheath: PVC

Section	Insulation	Thickness	Sheath Thickness	Overall Diameter	Cable	Weight	DC. Electrical R	esistance at 20°C
No.xmm ²	m	nm	mm	mm	Cu	Al /km	Cu	Al /km
4x25+1x10	1.2	1.0	1.8	27.2	1481	785	0.727/1.83	1.20/3.08
4x25+1x16	1.2	1.0	1.8	27.7	1547	814	0.727/1.15	1.20/1.91
4x35+1x10	1.2	1.0	1.8	28.5	1847	918	0.524/1.83	0.868/3.08
4x35+1x16	1.2	1.0	1.8	29.0	1913	948	0.524/1.15	0.868/1.91
4x35+1x25	1.2	1.2	1.9	30.0	2033	1011	0.524/0.727	0.868/1.20
4x50+1x16	1.4	1.0	2.0	33.1	2505	1233	0.387/1.15	0.641/1.91
4x50+1x25	1.4	1.2	2.0	33.9	2615	1286	0.387/0.727	0.641/1.20
4x50+1x35	1.4	1.2	2.0	34.3	2709	1323	0.387/0.524	0.641/0.868
4x70+1x16	1.4	1.0	2.1	36.6	3366	1570	0.268/1.15	0.443/1.91
4x70+1x25	1.4	1.2	2.1	37.4	3479	1626	0.268/0.727	0.443/1.20
4x70+1x35	1.4	1.2	2.1	37.8	3575	1664	0.268/0.524	0.443/0.868
4x70+1x50	1.4	1.4	2.2	38.7	3728	1742	0.268/0.387	0.443/0.641
4x95+1x35	1.6	1.2	2.3	42.7	4734	2163	0.193/0.524	0.320/0.868
4x95+1x50	1.6	1.4	2.3	43.6	4882	2236	0.193/0.387	0.320/0.641
4x95+1x70	1.6	1.4	2.3	44.3	5092	2317	0.193/0.268	0.320/0.443
4x120+1x50	1.6	1.4	2.4	47.1	5898	2636	0.153/0.387	0.253/0.641
4x120+1x70	1.6	1.4	2.5	48.0	6131	2739	0.153/0.268	0.253/0.443
4x120+1x70 4x120+1x95	1.6	1.6	2.5	49.1	6415	2861	0.153/0.268	0.253/0.320
4x150+1x50	1.8	1.4	2.6	51.7	7139	3181	0.124/0.387	0.206/0.641
	1.8	1.4	2.6	51.7	7159	3267		
4x150+1x70							0.124/0.268	0.206/0.443
4x150+1x95	1.8	1.6	2.6	53.3	7642	3393	0.124/0.193	0.206/0.320
4x150+1x120	1.8	1.6	2.7	54.4	7912	3510	0.124/0.153	0.206/0.253
4x185+1x70	2.0	1.4	2.7	57.1	8933	3924	0.0991/0.268	0.164/0.443
4x185+1x95	2.0	1.6	2.8	58.3	9246	4074	0.0991/0.193	0.164/0.320
4x185+1x120	2.0	1.6	2.8	59.1	9500	4177	0.0991/0.153	0.164/0.253
4x185+1x150	2.0	1.8	2.8	59.9	9791	4296	0.0991/0.124	0.164/0.206
4x240+1x70	2.2	1.4	2.9	63.3	11362	4909	0.0754/0.268	0.125/0.443
4x240+1x95	2.2	1.6	3.0	64.7	11694	5080	0.0754/0.193	0.125/0.320
4x240+1x120	2.2	1.6	3.0	65.3	11941	5175	0.0754/0.153	0.125/0.253
4x240+1x150	2.2	1.8	3.0	66.3	12248	5311	0.0754/0.124	0.125/0.206
4x240+1x185	2.2	2.0	3.1	67.4	12659	5494	0.0754/0.0991	0.125/0.164
4x300+1x120	2.4	1.6	3.2	71.4	14544	6242	0.0601/0.153	0.100/0.253
4x300+1x150	2.4	1.8	3.2	72.4	14857	6383	0.0601/0.124	0.100/0.206
4x300+1x185	2.4	2.0	3.2	73.4	15250	6549	0.0601/0.0991	0.100/0.164
4x300+1x240	2.4	2.2	3.3	74.9	15875	6819	0.0601/0.0754	0.100/0.125
4x400+1x120	2.6	1.6	3.4	79.2	18095	7683	0.0470/0.153	0.0778/0.25
4x400+1x150	2.6	1.8	3.5	80.2	18435	7851	0.0470/0.124	0.0778/0.20
4x400+1x185	2.6	2.0	3.5	81.1	18827	8017	0.0470/0.0991	0.0778/0.164
4x400+1x240	2.6	2.2	3.6	82.7	19473	8307	0.0470/0.0754	0.0778/0.12
4x500+1x150	2.8	1.8	3.7	88.2	22969	9635	0.0366/0.124	0.0605/0.200
4x500+1x185	2.8	2.0	3.7	89.2	23376	9815	0.0366/0.0991	0.0605/0.164
4x500+1x240	2.8	2.2	3.8	90.7	24026	10110	0.0366/0.0754	0.0605/0.125
4x500+1x300	2.8	2.4	3.8	91.9	24664	10369	0.0366/0.0601	0.0605/0.100





CU(AL)/PVC/PVC/SSTA/PVC 0.6/1(1.2) kV

Standards

AS/NZS 5000.1

DIN VDE 0276-603

IEC 60502-1

HD 603

Application

The cable is used for electricity supply in low voltage installation system, suitable for installation in indoors and outdoors, in cable ducts, under ground, in power and switching stations, local energy distributions, industrial plants, where there is no risk of mechanical damage.

AS/NZS 5000.1

Conductor: Copper/Aluminum

Insulation: PVCBedding: PVC

• Armour: Double Layer Stainless Steel Tape


Sheath: PVC

(Optional) Flame Retardant Property

(Optional) Fire Resistant Property

(Optional) Anti-Termite & Rodent Property

• (Optional) Water Resistant Property



Section	Insulation Thickness	Sheath Thickness	Overall Diameter	Cable	Weight	DC. Electrical Re	sistance at 20°C
2		The same of the sa	20.00	Cu	Al	Cu	Al
No.xmm ²	mm	mm	mm	kg	/km	Ω/	km
1x10	1.0	1.8	12.3	279	216	1.83	3.08
1x16	1.0	1.8	13.3	355	255	1.15	1.91
1x25	1.2	1.8	15.0	481	325	0.727	1.20
1x35	1.2	1.8	15.6	578	365	0.524	0.868
1x50	1.4	1.8	17.3	735	446	0.387	0.641
1x70	1.4	1.8	18.8	958	540	0.268	0.443
1x95	1.6	1.8	20.9	1254	673	0.193	0.320
1x120	1.6	1.8	22.4	1511	778	0.153	0.253
1x150	1.8	1.8	24.3	1818	915	0.124	0.206
1x185	2.0	1.8	26.3	2212	1081	0.0991	0.164
1x240	2.2	1.9	29.0	2813	1327	0.0754	0.125
1x300	2.4	2.0	31.8	3462	1598	0.0601	0.100
1x400	2.6	2.1	35.3	4343	1958	0.0470	0.0778
1x500	2.8	2.2	40.3	5860	2799	0.0366	0.0605
1x630	2.8	2.3	44.0	7321	3361	0.0283	0.0469
1x800	2.8	2.5	48.2	9112	4041	0.0221	0.0367





CU(AL)/PVC/PVC/STA/PVC 0.6/1(1.2) kV

Standards

AS/NZS 5000.1

DIN VDE 0276-603

• IEC 60502-1

HD 603

Application

The cable is used for electricity supply in low voltage installation system, suitable for installation in indoors and outdoors, in cable ducts, under ground, in power and switching stations, local energy distributions, industrial plants, where there is no risk of mechanical damage.

AS/NZS 5000.1

Conductor: Copper/Aluminum

Insulation: PVCBedding: PVC

• Armour: Double Layer Galvanized Steel Tape

Sheath: PVC

(Optional) Flame Retardant Property

(Optional) Fire Resistant Property

(Optional) Anti-Termite & Rodent Property

• (Optional) Water Resistant Property



Section	Insulation Thickness	Sheath Thickness	Overall Diameter		Weight		esistance at 20°C
No.xmm ²	mm	mm	mm	Cu	Al	Cu	Al
	11.00000		1000 CO	1100	/km	1000	/km
2x4	1.0	1.8	14.8	329	279	4.61	7.41
2x6	1.0	1.8	15.8	393	317	3.08	4.61
2x10	1.0	1.8	18.4	539	411	1.83	3.08
2x16	1.0	1.8	20.4	702	501	1.15	1.91
2x25	1.2	1.8	23.8	980	663	0.727	1.20
2x35	1.2	1.8	25.0	1184	751	0.524	0.868
2x50	1.4	1.8	28.4	1529	942	0.387	0.641
2x70	1.4	1.9	31.6	2022	1174	0.268	0.443
2x95	1.6	2.1	36.2	2700	1521	0.193	0.320
2x120	1.6	2.2	40.6	3663	2176	0.153	0.253
2x150	1.8	2.3	44.6	4404	2569	0.124	0.206
2x185	2.0	2.4	48.8	5334	3038	0.0991	0.164
2x240	2.2	2.6	54.6	6762	3745	0.0754	0.125
2x300	2.4	2.8	60.2	8274	4489	0.0601	0.100
2x400	2.6	3.1	67.4	10351	5511	0.0470	0.0778
2x500	2.8	3.3	74.6	12917	6702	0.0366	0.0605
3x4	1.0	1.8	15.5	393	317	4.61	7.41
3x6	1.0	1.8	16.6	478	365	3.08	4.61
3x10	1.0	1.8	19.4	668	478	1.83	3.08
3x16	1.0	1.8	21.5	890	588	1.15	1.91
3x25	1.2	1.8	25.2	1267	792	0.727	1.20
3x35	1.2	1.8	26.5	1559	909	0.524	0.868
3x50	1.4	1.9	30.4	2046	1166	0.387	0.641
3x70	1.4	2.0	33.8	2738	1465	0.268	0.443
3x95	1.6	2.2	40.0	4062	2294	0.193	0.320
3x120	1.6	2.3	43.4	4906	2675	0.153	0.253
3x150	1.8	2.4	47.7	5927	3175	0.124	0.206
3x185	2.0	2.6	52.4	7244	3801	0.0991	0.266
3x240	2.2	2.8	58.6	9236	4711	0.0754	0.104
3x300	2.4	2.9	64.5	11329	5651	0.0601	0.123
3x400	2.6	3.2	72.2	14223	6963	0.0470	0.100
3x500	2.8	3.4	79.9	17836	8513	0.0366	0.0776
	1.0	1.8					
4x4			16.6	466	366	4.61	7.41
4x6	1.0	1.8	17.8	575	424	3.08	4.61
4x10	1.0	1.8	21.0	816	563	1.83	3.08
4x16	1.0	1.8	23.4	1104	701	1.15	1.91
4x25	1.2	1.8	27.5	1587	953	0.727	1.20
4x35	1.2	1.8	28.9	1968	1101	0.524	0.868
4x50	1.4	2.0	33.5	2611	1438	0.387	0.641
4x70	1.4	2.1	38.5	3880	2182	0.268	0.443
4x95	1.6	2.3	44.0	5159	2801	0.193	0.320
4x120	1.6	2.4	47.8	6254	3281	0.153	0.253
4x150	1.8	2.6	52.8	7601	3932	0.124	0.206
4x185	2.0	2.7	57.8	9285	4694	0.0991	0.164
4x240	2.2	3.0	65.0	11912	4878	0.0754	0.125
4x300	2.4	3.2	71.7	1466	7096	0.0601	0.100
4x400	2.6	3.5	80.3	18442	8762	0.0470	0.0778
4x500	2.8	3.8	90.3	24095	11664	0.0366	0.0605
5x4	1.0	1.8	17.8	544	419	4.61	7.41
5x6	1.0	1.8	19.2	678	489	3.08	4.61
5x10	1.0	1.8	22.7	970	654	1.83	3.08
5x16	1.0	1.8	25.4	1324	821	1.15	1.91
5x25	1.2	1.8	30.0	1918	1127	0.727	1.20
5x35	1.2	1.9	31.8	2406	1323	0.524	0.868





CU(AL)/PVC/PVC/STA/PVC 0.6/1(1.2) kV Conductor: Copper/Aluminum Insulation: PVC

0000 Bedding: PVC
Armour: Double Layer Galvanized Steel Tape
Sheath: PVC

Section	Insulation	Inickness	Sheath Thickness	Overall Diameter		Weight	DC. Electrical Re	
No.xmm ²	m	m	mm	mm	Cu	Al	Cu O/	Al
5x50	1.		2.1	36.8	kg, 3193	/km 1727	Ω/I 0.387	km 0.641
5x70		4	2.3	42.4	4733	2611	0.268	0.443
5x95	1.		2.4	48.3	6289	3343	0.193	0.320
5x120		.6	2.6	52.8	7670	3953	0.153	0.253
5x150	1.		2.8	58.3	9329	4743	0.133	0.206
		.0	2.8	63.9				0.164
5x185					11416	5678	0.0991	
5x240		.2	3.2	71.8	14659	7117	0.0754	0.125
5x300		4	3.4	79.2	18067	8604	0.0601	0.100
5x400	2		3.8	90.1	23655	11555	0.0470	0.0778
5x500		.8	4.0	99.9	29675	14137	0.0366	0.0605
2x4+1x1.5	1.0	0.8	1.8	14.8	348	289	4.61/12.1	7.41/18.
2x4+1x2.5	1.0	0.8	1.8	14.9	360	295	4.61/7.41	7.41/12.
2x6+1x2.5	1.0	0.8	1.8	15.8	421	330	3.08/7.41	4.61/12.
2x6+1x4	1.0	1.0	1.8	16.2	448	348	3.08/4.61	4.61/7.4
2x10+1x4	1.0	1.0	1.8	18.4	582	431	1.83/4.61	3.08/7.4
2x10+1x6	1.0	1.0	1.8	18.5	604	440	1.83/3.08	3.08/4.6
2x16+1x6	1.0	1.0	1.8	20.4	765	526	1.15/3.08	1.91/4.6
2x16+1x10	1.0	1.0	1.8	20.8	814	550	1.15/1.83	1.91/3.0
2x25+1x6	1.2	1.0	1.8	24.2	1056	702	0.727/3.08	1.20/4.6
2x25+1x10	1,2	1.0	1.8	23.8	1080	700	0.727/1.83	1.20/3.0
2x25+1x16	1.2	1.0	1.8	24.1	1142	726	0.727/1.15	1.20/1.9
2x35+1x10	1.2	1.0	1.8	25.0	1284	789	0.524/1.83	0.868/3.0
2x35+1x16	1.2	1.0	1.8	25.1	1340	808	0.524/1.15	0.868/1.9
2x35+1x25	1.2	1.2	1.8	26.0	1455	866	0.524/0.727	0.868/1.2
2x50+1x16	1.4	1.0	1.8	28.4	1681	996	0.387/1.15	0.641/1.9
2x50+1x25	1.4	1.2	1.8	28.7	1777	1035	0.387/0.727	0.641/1.2
2x50+1x35	1.4	1.2	1.8	29.0	1869	1070	0.387/0.524	0.641/0.8
2x70+1x16	1.4	1.0	1.8	31.8	2176	1228	0.268/1.15	0.443/1.9
2x70+1x25	1.4	1.2	1.9	31.6	2260	1255	0.268/0.727	0.443/1.2
2x70+1x35	1.4	1.2	1.9	31.7	2345	1283	0.268/0.524	0.443/0.86
2x70+1x50	1.4	1.4	1.9	32.5	2488	1350	0.268/0.387	0.443/0.64
2x95+1x35	1.6	1.2	2.0	36.0	3003	1611	0.193/0.524	0.320/0.80
2x95+1x50	1.6	1.4	2.0	36.1	3119	1652	0.193/0.387	0.320/0.64
2x95+1x70	1.6	1.4	2.1	37.1	3351	1754	0.193/0.268	0.320/0.4
2x120+1x50	1.6	1.4	2.2	40.6	4094	2318	0.153/0.387	0.253/0.64
2x120+1x70	1.6	1.4	2.2	40.9	4292	2387	0.153/0.268	0.253/0.4
2x120+1x95	1.6	1.6	2.2	42.1	4595	2528	0.153/0.193	0.253/0.3
2x150+1x50	1.8	1.4	2.2	44.4	4815	2692	0.124/0.387	0.206/0.6
2x150+1x70	1.8	1.4	2.3	44.6	5016	2764	0.124/0.268	0.206/0.4
2x150+1x76	1.8	1.6	2.3	45.1	5281	2866	0.124/0.193	0.206/0.4
2x150+1x120	1.8	1.6	2.4	46.2	5566	2999	0.124/0.153	0.206/0.2
	2.0	1.4	2.4					
2x185+1x70				48.8	5946	3232	0.0991/0.268	0.164/0.4
2x185+1x95	2.0	1.6	2.4	48.8	6181	3305	0.0991/0.193	0.164/0.3
2x185+1x120	2.0	1.6	2.5	49.6	6451	3424	0.0991/0.153	0.164/0.2
2x185+1x150	2.0	1.8	2.5	50.6	6763	3564	0.0991/0.124	0.164/0.20
2x240+1x70	2.2	1.4	2.2	55.3	7411	3976	0.0754/0.268	0.125/0.4
2x240+1x95	2.2	1.6	2.6	54.6	7609	4011	0.0754/0.193	0.125/0.3
2x240+1x120	2.2	1.6	2.6	54.6	7820	4070	0.0754/0.153	0.125/0.2
2x240+1x150	2.2	1.8	2.6	55.3	8115	4194	0.0754/0.124	0.125/0.2
2x300+1x95	2.4	1.6	2.7	60.5	9131	4765	0.0601/0.193	0.100/0.3
2x300+1x120	2.4	1.6	2.7	60.0	9305	4788	0.0601/0.153	0.100/0.2
2x300+1x150	2.4	1.8	2.8	60.2	9579	4890	0.0601/0.124	0.100/0.2
2x300+1x185	2.4	2.0	2.8	61.0	9965	5049	0.0601/0.0991	0.100/0.1
2x300+1x240	2.4	2.2	2.9	62.4	10587	5316	0.0601/0.0754	0.100/0.1
2x400+1x120	2.6	1.6	2.9	67.9	11422	5849	0.0470/0.153	0.0778/0.2
2x400+1x150	2.6	1.8	2.9	67.0	11598	5854	0.0470/0.124	0.0778/0.2
2x400+1x185	2.6	2.0	3.0	67.2	11954	5983	0.0470/0.0991	0.0778/0.1
2x400+1x240	2.6	2.2	3.1	68.3	12561	6235	0.0470/0.0754	0.0778/0.1
2x500+1x150	2.8	1.8	3.1	75.2	14243	7124	0.0366/0.124	0.0605/0.2
2x500+1x185	2.8	2.0	3.1	74.2	14484	7138	0.0366/0.0991	0.0605/0.1
2x500+1x240	2.8	2.2	3.2	74.4	15023	7321	0.0366/0.0754	0.0605/0.1
2x500+1x300	2.8	2.4	3.3	75.6	15680	7600	0.0366/0.0601	0.0605/0.1
3x4+1x1.5	1.0	0.8	1.8	15.8	419	335	4.61/12.1	7.41/18.
3x4+1x2.5	1.0	0.8	1.8	16.0	434	343	4.61/7.41	7.41/12.
3x6+1x2.5	1.0	0.8	1.8	17.0	517	388	3.08/7.41	4.61/12.
3x6+1x4	1.0	1.0	1.8	17.5	547	409	3.08/4.61	4.61/7.4
3x10+1x4	1.0	1.0	1.8	19.9	727	512	1.83/4.61	3.08/7.4
	1.0	1.0	1.8	20.2	754	527	1.83/3.08	3.08/4.6
3v10+1v6						629		
3x10+1x6	10							
3x16+1x6	1.0	1.0	1.8	22.0	968		1.15/3.08	
	1.0 1.0 1.2	1.0 1.0	1.8 1.8 1.8	22.7 25.4	1027 1337	662 824	1.15/1.83 0.727/3.08	1.91/4.6 1.91/3.0 1.20/4.6





CU(AL)/PVC/PVC/STA/PVC 0.6/1(1.2) kV
Conductor: Copper/Aluminum
Insulation: PVC
Bedding: PVC
Armour: Double Layer Galvanized Steel Tape
Sheath: PVC

Section	Insulation	Thickness	Sheath Thickness	Overall Diameter		le Weight	DC. Electrical Re	
No.xmm ²	m	m	mm	mm	Cu	Al kg/km	Cu Ω/	Al km
3x25+1x16	1.2	1.0	1.8	26.4	1460	885	0.727/1.15	1.20/1.91
3x35+1x10	1.2	1.0	1.8	27.1	1680	968	0.524/1.83	0.868/3.08
3x35+1x16	1.2	1.0	1.8	27.5	1746	997	0.524/1.15	0.868/1.91
3x35+1x25	1.2	1.2	1.8	28.5	1866	1061	0.524/0.727	0.868/1.20
3x50+1x16	1.4	1.0	1.9	31.0	2221	1242	0.387/1.15	0.641/1.91
3x50+1x25	1.4	1.2	1.9	31.8	2337	1301	0.387/0.727	0.641/1.20
3x50+1x35	1.4	1.2	1.9	32.2	2434	1341	0.387/0.524	0.641/0.868
3x70+1x16	1.4	1.0	2.0	34.1	2903	1530	0.268/1.15	0.443/1.91
3x70+1x25	1.4	1.2	2.0	35.0	3025	1596	0.268/0.727	0.443/1.20
3x70+1x35	1.4	1.2	2.0	35.2	3115	1628	0.268/0.524	0.443/0.868
3x70+1x50	1.4	1.4	2.1	36.3	3280	1718	0.268/0.387	0.443/0.641
3x95+1x35	1.6	1.2	2.2	40.8	4425	2444	0.193/0.524	0.320/0.868
3x95+1x50	1.6	1.4	2.2	41.6	4582	2526	0.193/0.387	0.320/0.641
3x95+1x70	1.6	1.4	2.3	42.7	4834	2648	0.193/0.268	0.320/0.443
3x120+1x50	1.6	1.4	2.3	44.7	5413	2894	0.153/0.387	0.253/0.641
3x120+1x70	1.6	1.4	2.3	45.3	5360	2982	0.153/0.268	0.253/0.443
3x120+1x95	1.6	1.6	2.4	46.7	5958	3147	0.153/0.193	0.253/0.320
3x150+1x50	1.8	1.4	2.4	48.6	6414	3374	0.124/0.387	0.206/0.641
3x150+1x70	1.8	1.4	2.5	49.3	6649	3479	0.124/0.268	0.206/0.443
3x150+1x95	1.8	1.6	2.5	50.4	6954	3622	0.124/0.193	0.206/0.320
3x150+1x120	1.8	1.6	2.5	51.3	7223	3739	0.124/0.153	0.206/0.253
3x185+1x70	2.0	1.4	2.6	53,4	7923	4062	0.0991/0.268	0.164/0.443
3x185+1x95	2.0	1.6	2.6	54.4	8226	4202	0.0991/0.193	0.164/0.320
3x185+1x120	2.0	1.6	2.7	55.4	8515	4340	0.0991/0.153	0.164/0.253
	2.0		2.7					
3x185+1x150		1.8		56.4	8832	4485	0.0991/0.124	0.164/0.206
3x240+1x70	2.2	1.4	2.8	59.1	9885	4941	0.0754/0.268	0.125/0.443
3x240+1x95	2.2	1.6	2.8	60.0	10185	5079	0.0754/0.193	0.125/0.320
3x240+1x120	2.2	1.6	2.8	60.7	10447	5189	0.0754/0.153	0.125/0.253
3x240+1x150	2.2	1.8	2.9	61.8	10788	5359	0.0754/0.124	0.125/0.206
3x300+1x95	2.4	1.6	3.0	65.4	12258	6000	0.0601/0.193	0.100/0.320
3x300+1x120	2.4	1.6	3.0	66.2	12531	6122	0.0601/0.153	0.100/0.253
3x300+1x150	2.4	1.8	3.0	67.0	12842	6260	0.0601/0.124	0.100/0.206
3x300+1x185	2.4	2.0	3.1	68.2	13278	6469	0.0601/0.0991	0.100/0.164
3x300+1x240	2.4	2.2	3.1	69.2	13905	6741	0.0601/0.0754	0.100/0.125
3x400+1x120	2.6	1.6	3.2	72.8	15331	7338	0.0470/0.153	0.0778/0.25
3x400+1x150	2.6	1.8	3.2	73.6	15646	7482	0.0470/0.124	0.0778/0.206
3x400+1x185	2.6	2.0	3.3	75.0	16108	7717	0.0470/0.0991	0.0778/0.16
		2.2						
3x400+1x240	2.6		3.3	76.1	16709	7963	0.0470/0.0754	0.0778/0.12
3x500+1x150	2.8	1.8	3.4	80.6	19205	8978	0.0366/0.124	0.0605/0.20
3x500+1x185	2.8	2.0	3.5	81.7	19649	9196	0.0366/0.0991	0.0605/0.164
3x500+1x240	2.8	2.2	3.6	84.4	21134	10325	0.0366/0.0754	0.0605/0.12
3x500+1x300	2.8	2.4	3.6	85.7	21809	10621	0.0366/0.0601	0.0605/0.100
3x4+2x1.5	1.0	0.8	1.8	16.5	457	363	4.61/12.1	7.41/18.1
3x4+2x2.5	1.0	0.8	1.8	16.9	487	380	4.61/7.41	7.41/12.1
								4.61/12.1
3x6+2x2.5	1.0	0.8	1.8	17.8	568	423	3.08/7.41	
3x6+2x4	1.0	1.0	1.8	18.6	623	460	3.08/4.61	4.61/7.41
3x10+2x4	1.0	1.0	1.8	20.9	802	562	1.83/4.61	3.08/7.41
3x10+2x6	1.0	1.0	1.8	21.3	852	587	1.83/3.08	3.08/4.61
3x16+2x6	1.0	1.0	1.8	23.1	1068	690	1.15/3.08	1.91/4.61
3x16+2x10	1.0	1.0	1.8	24.3	1181	753	1.15/1.83	1.91/3.08
3x25+2x6	1.2	1.0	1.8	26.3	1432	882	0.727/3.08	
								1.20/4.61
3x25+2x10	1.2	1.0	1.8	27.3	1542	940	0.727/1.83	1.20/3.08
3x25+2x16	1.2	1.0	1.8	28.2	1680	1004	0.727/1.15	1.20/1.91
3x35+2x10	1.2	1.0	1.8	28.4	1829	1053	0.524/1.83	0.868/3.08
3x35+2x16	1.2	1.0	1.8	29.2	1964	1113	0.524/1.15	0.868/1.91
3x35+2x25	1.2	1.2	1.9	31.1	2214	1247	0.524/0.727	0.868/1.20
3x50+2x16	1.4	1.0	1.9	32.5	2436	1355	0.387/1.15	0.641/1.91
3x50+2x25	1.4	1.2	2.0	34.2	2684	1488	0.387/0.727	0.641/1.20
3x50+2x35	1.4	1.2	2.0	34.8	2874	1561	0.387/0.524	0.641/0.868
3x70+2x16	1.4	1.0	2.0	35.5	3118	1644	0.268/1.15	0.443/1.91
3x70+2x25	1.4	1.2	2.1	37.0	3362	1772	0.268/0.727	0.443/1.20
3x70+2x35	1.4	1.2	2.1	38.7	3916	2210	0.268/0.524	0.443/0.868
3x70+2x50	1.4	1.4	2.2	40.6	4255	2395	0.268/0.387	0.443/0.641
3x95+2x35	1.6	1.2	2.2	42.7	4863	2662	0.193/0.524	0.320/0.868
3x95+2x50	1.6	1.4	2.3	44.4	5197	2843	0.193/0.387	0.320/0.641
3x95+2x70	1.6	1.4	2.4	46.1	5676	3059	0.193/0.268	0.320/0.443
3x120+2x50	1.6	1.4	2.4	47.3	6024	3207	0.153/0.387	0.253/0.641
3x120+2x70	1.6	1.4	2.4	48.6	6474	3395	0.153/0.268	0.253/0.443
3x120+2x95	1.6	1.6	2.5	50.9	7107	3698	0.153/0.193	0.253/0.320
3x150+2x50	1.8	1.4	2.5	51.0	7022	3683	0.124/0.387	0.206/0.641
3x150+2x70	1.8	1.4	2.6	52.4	7492	3891	0.124/0.268	0.206/0.443
3x150+2x95	1.8	1.6	2.6	54.4	8104	4173	0.124/0.193	0.206/0.320
3x150+2x120	1.8	1.6	2.7	56.1	8660	4421	0.124/0.153	0.206/0.253
3x185+2x70	2.0	1.4	2.7	56.2	8758	4466	0.0991/0.268	0.164/0.443





CU(AL)/PVC/PVC/STA/PVC 0.6/1(1.2) kV

Conductor: Copper/Aluminum
Insulation: PVC
Bedding: PVC
Armour: Double Layer Galvanized Steel Tape

000

Sheath: PVC

Section	insulation	Thickness	Sheath Thickness	Overall Diameter		ble Weight		Resistance at 20°C
No.xmm ²	m	m	mm	mm	Cu	Al kg/km	Cu	Al Ω/km
3x185+2x120	2.0	1.6	2.8	59.7	9924	4994	0.0991/0.153	0.164/0.25
3x185+2x150	2.0	1.8	2.9	61.7	10586	5308	0.0991/0.124	0.164/0.20
3x240+2x70	2.2	1.4	2.8	61.4	10685	5311	0.0754/0.268	0.125/0.44
3x240+2x95	2.2	1.6	2.9	63.4	11325	5621	0.0754/0.193	0.125/0.32
3x240+2x120	2.2	1.6	2.9	64.5	11837	5825	0.0754/0.153	0.125/0.25
3x240+2x150	2.2	1.8	3.0	66.6	12517	6157	0.0754/0.124	0.125/0.20
3x240+2x185	2.2	2.0	3.1	68.6	13354	6533	0.0754/0.0991	0.125/0.16
3x300+2x120	2.4	1.6	3.1	69.7	13917	6753	0.0601/0.153	0.100/0.25
3x300+2x150	2.4	1.8	3.1	71.2	14543	7031	0.0601/0.124	0.100/0.20
3x300+2x185	2.4	2.0	3.2	73.4	15407	7434	0.0601/0.0991	0.100/0.16
3x300+2x240	2.4	2.2	3.3	76.2	16691	7996	0.0601/0.0754	0.100/0.12
3x400+2x120	2.6	1.6	3.3	76.1	16721	7975	0.0470/0.153	0.0778/0.25
3x400+2x150	2.6	1.8	3.3	77.6	17355	8261	0.0470/0.124	0.0778/0.20
		2.0		79.5			0.0470/0.0991	
3x400+2x185	2.6		3.4		18206	6850		0.0778/0.16
3x400+2x240	2.6	2.2	3.5	82.3	19506	9230	0.0470/0.0754	0.0778/0.12
3x500+2x150	2.8	1.8	3.5	84.3	20912	9755	0.0366/0.124	0.0605/0.20
3x500+2x185	2.8	2.0	3.6	87.3	22619	11001	0.0366/0.0991	0.0605/0.16
3x500+2x240	2.8	2.2	3.7	89.8	23933	11593	0.0366/0.0754	0.0605/0.12
3x500+2x300	2.8	2.4	3.8	92.5	25341	12233	0.0366/0.0601	0.0605/0.10
4x4+1x1.5	1.0	0.8	1.8	17,1	499	389	4.61/12.1	7.41/18.1
4x4+1x2.5	1.0	0.8	1.8	17.3	513	398		7.41/12.1
							4.61/7.41	
4x6+1x2.5	1.0	0.8	1.8	18.4	620	453	3.08/7.41	4.61/12.1
4x6+1x4	1.0	1.0	1.8	18.9	650	474	3.08/4.61	4.61/7.41
4x10+1x4	1.0	1.0	1.8	21.8	885	607	1.83/4.61	3.08/7.41
4x10+1x6	1.0	1.0	1.8	22.0	910	619	1.83/3.08	3.08/4.61
4x16+1x6	1.0	1.0	1.8	24.2	1193	753	1.15/3.08	1.91/4.61
4x16+1x10	1.0	1.0	1.8	24.8	1249	784	1.15/1.83	1.91/3.08
4x25+1x6	1.2	1.0	1.8	27.9	1664	993	0.727/3.08	1.20/4.61
4x25+1x10	1.2	1.0	1.8	28.6	1726	1030	0.727/1.83	1.20/3.08
4x25+1x16	1.2	1.0	1.8	29.1	1796	1064	0.727/1.15	1.20/1.91
4x35+1x10	1.2	1.0	1.9	30.1	2117	1189	0.524/1.83	0.868/3.08
4x35+1x16	1.2	1.0	1.9	30.6	2188	1223	0.524/1.15	0.868/1.91
4x35+1x25	1.2	1.2	1.9	31.4	2304	1282	0.524/0.727	0.868/1.20
4x50+1x16	1.4	1.0	2.0	34.5	2804	1532	0.387/1.15	0.641/1.91
4x50+1x25	1.4	1.2	2.0	35.3	2922	1593	0.387/0.727	0.641/1.20
4x50+1x35	1.4	1.2	2.0	35.7	3020	1634	0.387/0.524	0.641/0.86
4x70+1x16	1.4	1.0	2.1	39.2	4070	2273		
							0.268/1.15	0.443/1.91
4x70+1x25	1.4	1.2	2.2	40.2	4217	2363	0.268/0.727	0.443/1.20
4x70+1x35	1.4	1.2	2.2	40.6	4320	2409	0.268/0.524	0.443/0.86
4x70+1x50	1.4	1.4	2.2	41.3	4472	2485	0.268/0.387	0.443/0.64
4x95+1x35	1.6	1.2	2.3	45.3	5555	2984	0.193/0.524	0.320/0.86
4x95+1x50	1.6	1.4	2.4	46.4	7541	3095	0.193/0.387	0.320/0.64
4x95+1x70	1.6	1.4	2.4	47.1	5966	3190	0.193/0.268	0.320/0.44
4x120+1x50	1.6	1.4	2.5	49.9	6827	3564	0.153/0.387	0.253/0.64
4x120+1x70	1.6	1.4	2.5	50.6	7053	3661	0.153/0.268	0.253/0.44
4x120+1x95	1.6	1.6	2.6	51.9	7382	3828	0.153/0.193	0.253/0.32
4x150+1x50	1.8	1.4	2.6	54.3	8133	4175	0.124/0.387	0.206/0.64
4x150+1x70	1.8	1.4	2.7	55.2	8368	4299	0.124/0.268	0.206/0.44
4x150+1x95	1.8	1.6	2.7	56.3	8697	4447	0.124/0.193	0.206/0.32
4x150+1x120	1.8	1.6	2.7	57.0	8957	4555	0.124/0.153	0.206/0.25
4x185+1x70	2.0	1.4	2.8	59.9	10059	5050	0.0991/0.268	0.164/0.44
4x185+1x95	2.0	1.6	2.8	60.9	10367	5196	0.0991/0.193	0.164/0.32
4x185+1x120	2.0	1.6	2.9	61.9	10664	5341	0.0991/0.153	0.164/0.25
4x185+1x150	2.0	1.8	2.9	62.7	10972	5477	0.0991/0.124	0.164/0.20
4x240+1x70	2.2	1.4	3.0	66.1	12609	6157	0.0754/0.268	0.125/0.44
4x240+1x95	2.2	1.6	3.0	67,3	12939	6324	0.0754/0.193	0.125/0.32
4x240+1x120	2.2	1.6	3.1	68.1	13227	6461	0.0754/0.153	0.125/0.25
4x240+1x150	2.2	1.8	3.1	69.1	13555	6617	0.0754/0.124	0.125/0.20
4x240+1x185	2.2	2.0	3.1	70.0	13955	6790	0.0754/0.0991	0.125/0.16
	2.4		3.2					
4x300+1x120		1.6		74.0	15918	7615	0.0601/0.153	0.100/0.25
4x300+1x150	2.4	1.8	3.3	75.2	16283	7810	0.0601/0.124	0.100/0.20
4x300+1x185	2.4	2.0	3.3	76.2	16697	7996	0.0601/0.0991	0.100/0.16
4x300+1x240	2.4	2.2	3.4	77.7	17351	8294	0.0601/0.0754	0.100/0.12
4x400+1x120	2.6	1.6	3.5	82.0	19656	9243	0.0470/0.153	0.0778/0.25
4x400+1x150	2.6	1.8	3.6	84.2	20834	10250	0.0470/0.124	0.0778/0.20
4x400+1x185	2.6	2.0	3.6	85.1	21255	10444	0.0470/0.0991	0.0778/0.16
	2.6	2.2	3.7	86.7	21945	10779		
4x400+1x240							0.0470/0.0754	0.0778/0.12
4x500+1x150	2.8	1.8	3.8	92.2	25609	12274	0.0366/0.124	0.0605/0.20
4x500+1x185	2.8	2.0	3.8	93.2	26046	12485	0.0366/0.0991	0.0605/0.16
4x500+1x240	2.8	2.2	3.9	94.7	26739	12822	0.0366/0.0754	0.0605/0.12
		2.4	3.9	95.9	27414	13119	0.0366/0.0601	0.0605/0.10





CU(AL)/PVC/PVC/AWA/PVC 0.6/1(1.2) kV

Standards

AS/NZS 5000.1

• HD 603

DIN VDE 0276-603



Application

The cable is used for electricity supply in low voltage installation system, suitable for installation in indoors and outdoors, in cable ducts, underground, in power and switching stations, local energy distributions, industrial plants, where there is no risk of mechanical damage.

AS/NZS 5000.1

• Conductor: Copper/Aluminum

Insulation: PVCBedding: PVC

Armour: Aluminum Wire

Sheath: PVC

(Optional) Flame Retardant Property

(Optional) Fire Resistant Property

(Optional) Anti-Termite & Rodent Property

(Optional) Water Resistant Property



Section	Insulation Thickness	Sheath Thickness	Overall Diameter	Cable	Weight	DC. Electrical Re	sistance at 20°C
N12		20.00	20.00	Cu	Al	Cu	Al
No.xmm ²	mm	mm	mm	kg	/km	Ω/	km
1x10	1.0	1.8	12.3	279	216	1.83	3.08
1x16	1.0	1.8	15.3	389	289	1.15	1.91
1x25	1.2	1.8	17.0	496	345	0.727	1.20
1x35	1.2	1.8	17.6	607	397	0.524	0.868
1x50	1.4	1.8	20.2	833	544	0.387	0.641
1x70	1.4	1.8	21.7	1068	648	0.268	0.443
1x95	1.6	1.8	23.8	1363	788	0.193	0.320
1x120	1.6	1.8	26.0	1680	955	0.153	0.253
1x150	1.8	1.8	27.9	2028	1117	0.124	0.206
1x185	2.0	1.8	29.9	2400	1281	0.0991	0.164
1x240	2.2	1.9	32.8	3025	1560	0.0754	0.125
1x300	2.4	2.0	36.4	3755	1936	0.0601	0.100
1x400	2.6	2.1	39.9	4782	2394	0.0470	0.0778
1x500	2.8	2.2	43.5	5930	2883	0.0366	0.0605
1x630	2.8	2.4	47.4	7409	3431	0.0283	0.0469
1v800	2.8	2.5	53.0	9333	4268	0.0221	0.0367





CU(AL)/PVC/PVC/SWA/PVC 0.6/1(1.2) kV

Standards

AS/NZS 5000.1

DIN VDE 0276-603

• IEC 60502-1

HD 603

Application

The cable is used for electricity supply in low voltage installation system, suitable for installation in indoors and outdoors, in cable ducts, underground, in power and switching stations, local energy distributions, industrial plants, where there is no risk of mechanical damage.

AS/NZS 5000.1

Conductor: Copper/Aluminum

Insulation: PVCBedding: PVC

Armour: Galvanized Steel Wire

Sheath: PVC

• (Optional) Flame Retardant Property

• (Optional) Fire Resistant Property

(Optional) Anti-Termite & Rodent Property

(Optional) Water Resistant Property



Section	Insulation Thickness	Sheath Thickness	Overall Diameter		Weight		sistance at 20°C
No.xmm ²	mm	mm	mm	Cu	Al	Cu	Al
		W. W			/km		km.
2x4	1.0	1.8	18.0	503	453	4.61	7.41
2x6	1.0	1.8	19.9	712	636	3.08	4.61
2x10	1.0	1.8	22.5	905	778	1.83	3.08
2x16	1.0	1.8	24.5	1109	908	1.15	1.91
2x25	1.2	1.8	28.6	1615	1298	0.727	1.20
2x35	1.2	1.8	29.8	1863	1430	0.524	0.868
2x50	1.4	1.9	33.4	2304	1718	0.387	0.641
2x70	1.4	2.0	37.4	3135	2286	0.268	0.443
2x95	1.6	2.2	42.0	3954	2775	0.193	0.320
2x120	1.6	2.3	45.2	4649	3162	0.153	0.253
2x150	1.8	2.4	50.6	5964	4130	0.124	0.206
2x185	2.0	2.6	55.0	7064	4769	0.0991	0.164
2x340	2.2	2.8	60.8	8665	5648	0.0754	0.125
2x300	2.4	2.9	66.6	10416	6631	0.0601	0.100
2x400	2.6	3.2	73.8	12735	7895	0.0470	0.0778
2x500	2.8	3.4	82.7	16537	10322	0.0366	0.0605
3x4	1.0	1.8	19.6	703	627	4.61	7.41
3x6	1.0	1.8	20.7	813	700	3.08	4.61
3x10	1.0	1.8	23.5	1060	870	1.83	3.08
3x16	1.0	1.8	25.6	1322	1020	1.15	1.91
3x25	1.2	1.8	30.0	1945	1469	0.727	1.20
3x35	1.2	1.8	31.3	2264	1614	0.524	0.868
3x50	1,4	2.0	35.4	2865	1985	0.387	0.641
3x70	1.4	2.1	39.6	3922	2649	0.268	0.443
3x95	1.6	2.2	44.4	5012	3244	0.193	0.320
3x120	1.6	2.3	47.8	5911	3681	0.153	0.253
3x150	1.8	2.5	53.7	7569	4818	0.124	0.206
3x185	2.0	2.7	58.4	9032	5589	0.0991	0.164
3x240	2.2	2.9	65.0	11320	6794	0.0754	0.125
3x300	2.4	3.1	71.1	13651	7973	0.0601	0.100
3x400	2.6	3.4	80.5	17774	10514	0.0470	0.0778
3x500	2.8	3.6	88.2	21753	12430	0.0366	0.0605
4x4	1.0	1.8	20.7	801	701	4.61	7.41
4x6	1.0	1.8	21.9	934	783	3.08	4.61
4x10	1.0	1.8	25.1	1241	988	1.83	3.08
4x16	1.0	1.8	28.2	1741	1338	1.15	1.91
4x25	1.2	1.8	32.3	2320	1686	0.727	1.20
4x35	1,2	1.9	33.9	2758	1891	0.524	0.868
4x50	1.4	2.1	39.3	3770	2579	0.387	0.641
4x70	1.4	2.2	43.1	4815	3117	0.268	0.443
4x95	1.6	2.4	50.0	6687	4330	0.193	0.320
4x120	1.6	2.5	53.8	7895	4922	0.153	0.253
4x150	1.8	2.7	58.8	9423	5754	0.124	0.206
4x185	2.0	2.9	64.4	11361	6770	0.0991	0.206
4x240	2.2	3.1	71.4	14202	8168	0.0754	0.104
4x240 4x300	2.4	3.3	78.1	17200	9630	0.0601	0.123
	2.6						
4x400	2.8	3.6	88.4	22322	12642	0.0470	0.0778
4x500	1.0	3,9	97.2	27510	15080	0.0366	0.0605
5x4		1.8	21.9	904	778	4.61	7.41
5x6	1.0	1.8	23.3	1062	873	3.08	4.61
5x10	1.0	1.8	27.5	1577	1261	1.83	3.08
5x16	1.0	1.8	30.2	2001	1498	1.15	1.91





CU(AL)/PVC/PVC/SWA/PVC 0.6/1(1.2) kV Conductor: Copper/Aluminum Insulation: PVC Bedding: PVC Armour: Galvanized Steel Wire

Sheath: PVC

Section	Insulation	inickness	Sheath Thickness	Overall Diameter		Weight	DC. Electrical Re	
No.xmm ²	mr	n	mm	mm	Cu	Al /km	Cu O/	Al km
5x25	1.2)	1.9	35.0	2737	1945	0.727	1.20
5x35	1,2		2.0	37.6	3518	2435	0.524	0.868
5x50	1.4		2.2	42.6	4470	3004	0.387	0.641
5x70	1.4		2.3	46.8	5728	3606	0.268	0.443
	1.6							
5x95			2.5	54.3	7963	5017	0.193	0.320
5x120	1.6		2.7	58.8	9492	5775	0.153	0.253
5x150	1.8		2.9	64.7	11376	6790	0.124	0.206
5x185	2.0		3.0	70.3	13676	7937	0.0991	0.164
5x240	2.2		3.3	79.9	18180	10638	0.0754	0.125
5x300	2.4	1	3.6	87.5	21928	12466	0.0601	0.100
5x400	2.6	5	3.9	97.0	27076	14976	0.0470	0.0778
5x500	2.8	3	4.2	107.2	33554	18016	0.0366	0.0605
2x4+1x1.5	1.0	0.8	1.8	18.0	522	462	4.61/12.1	7.41/18.1
2x4+1x2.5	1.0	0.8	1.8	18.1	537	472	4.61/7.41	7.41/12.1
2x6+1x2.5	1.0	0.8	1.8	19.9	740	649	3.08/7.41	4.61/12.1
2x6+1x4	1.0	1.0	1.8	20.3	775	647	3.08/4.61	4.61/7.41
2x10+1x4	1.0	1.0	1.8	22.5	949	798	1.83/4.61	3.08/7.41
2x10+1x6	1.0	1.0	1.8		980			
				22.6		816	1.83/3.08	3.08/4.61
2x16+1x6	1.0	1.0	1.8	24.5	1173	934	1.15/3.08	1.91/4.61
2x16+1x10	1.0	1.0	1.8	24.9	1229	966	1.15/1.83	1.91/3.08
2x25+1x6	1.2	1.0	1.8	29.0	1705	1351	0.727/3.08	1.20/4.61
2x25+1x10	1.2	1.0	1.8	28.6	1715	1336	0.727/1.83	1.20/3.08
2x25+1x16	1.2	1.0	1.8	28.9	1792	1376	0.727/1.15	1.20/1.91
2x35+1x10	1.2	1.0	1.8	29.8	1963	1467	0.524/1.83	0.868/3.08
2x35+1x16	1.2	1.0	1.8	29.9	2018	1486	0.524/1.15	0.868/1.91
2x35+1x25	1.2	1.2	1.8	30.8	2146	1557	0.524/0.727	0.868/1.20
2x50+1x16	1.4	1.0	1.8	33.2	2443	1757	0.387/1.15	0.641/1.91
2x50+1x25	1.4	1.2	1.9	33.7	2551	1809	0.387/0.727	0.641/1.20
2x50+1x35	1.4	1.2	1.9	34.0	2659	1859	0.387/0.524	0.641/0.868
2x70+1x16	1.4	1.0	1.9	36.8	3036	2088	0.268/1.15	0.443/1.91
2x70+1x25	1.4	1.2	2.0	36.6	3123	2118	0.268/0.727	0.443/1.20
2x70+1x35	1.4	1.2	2.0	36.7	3208	2146	0.268/0.524	0.443/0.868
2x70+1x50	1.4	1.4	2.1	38.5	3639	2502	0.268/0.387	0.443/0.641
2x95+1x35	1.6	1.2	2.1	41.8	4254	2862	0.193/0.524	0.320/0.868
2x95+1x50	1.6	1.4	2.2	42.1	4388	2921	0.193/0.387	0.320/0.64
2x95+1x70	1.6	1.4	2.2	42.9	4626	3030	0.193/0.268	0.320/0.443
2x120+1x50	1.6	1.4	2.2	45.0	5060	3285	0.153/0.387	0.253/0.64
2x120+1x70	1.6	1.4	2.3	45.5	5274	3369	0.153/0.268	0.253/0.443
2x120+1x95	1.6	1.6	2.3	46.7	5610	3543	0.153/0.193	0.253/0.320
2x150+1x50	1.8	1.4	2.3	49.0	5873	3750	0.124/0.387	0.206/0.64
2x150+1x70	1.8	1.4	2.3	49.0	6055	3802	0.124/0.268	0.206/0.44
2x150+1x95	1.8	1.6	2.4	51.1	6834	4419		
							0.124/0.193	0.206/0.320
2x150+1x120	1.8	1.6	2.5	52.2	7149	4582	0.124/0.153	0.206/0.253
2x185+1x70	2.0	1.4	2.5	54.8	7653	4939	0.0991/0.268	0.164/0.44
2x185+1x95	2.0	1.6	2.5	54.8	7888	5012	0.0991/0.193	0.164/0.320
2x185+1x120	2.0	1.6	2.6	55.6	8153	5125	0.0991/0.153	0.164/0.253
2x185+1x150	2.0	1.8	2.6	56.6	8490	5291	0.0991/0.124	0.164/0.20
2x240+1x70	2.2	1.4	2.6	61.3	9313	5878	0.0754/0.268	0.125/0.443
2x240+1x95	2.2	1.6	2.7	60.6	9486	5888	0.0754/0.193	0.125/0.320
2x240+1x120	2.2	1.6	2.7	60.6	9697	5947	0.0754/0.153	0.125/0.25
2x240+1x150	2.2	1.8	2.8	61.9	10098	6177	0.0754/0.124	0.125/0.206
2x240+1x185	2.2	2.0	2.8	66.9	11264	6899	0.0754/0.0991	0.125/0.164
2x300+1x120	2.4	1.6	2.8	66.4	11445	6928	0.0601/0.153	0.100/0.253
	2.4	1.8	2.9	66.6		7033		
2x300+1x150					11721		0.0601/0.124	0.100/0.206
2x300+1x185	2.4	2.0	2.9	67.4	12137	7221	0.0601/0.0991	0.100/0.164
2x300+1x240	2.4	2.2	3.0	68.8	12786	7515	0.0601/0.0754	0.100/0.125
2x400+1x120	2.6	1.6	3.0	74.3	13829	8257	0.0470/0.153	0.0778/0.25
2x400+1x150	2.6	1.8	3.1	73.6	14009	8265	0.0470/0.124	0.0778/0.20
2x400+1x185	2.6	2.0	3.1	73.6	14336	8365	0.0470/0.0991	0.0778/0.16
2x400+1x240	2.6	2.2	3.2	74.7	14974	8648	0.0470/0.0754	0.0778/0.12
2x500+1x150	2.8	1.8	3.2	81.6	16886	9767	0.0366/0.124	0.0605/0.20
2x500+1x185	2.8	2.0	3.3	80.8	17135	9789	0.0366/0.0991	0.0605/0.16
2x500+1x240	2.8	2.2	3.4	82.7	18675	10974	0.0366/0.0754	0.0605/0.12
2x500+1x240 2x500+1x300	2.8	2.4	3.4	83.7	19351	11271	0.0366/0.0601	0.0605/0.12
								AND DESCRIPTION OF THE PROPERTY OF THE PROPERT
3x4+1x1.5	1.0	0.8	1.8	19.9	738	653	4.61/12.1	7.41/18.1
3x4+1x2.5	1.0	0.8	1.8	20.1	761	671	4.61/7.41	7.41/12.1
3x6+1x2.5	1.0	8.0	1.8	21.1	860	731	3.08/7.41	4.61/12.1
3x6+1x4	1.0	1.0	1.8	21.6	898	760	3.08/4.61	4.61/7.41
3x10+1x4	1.0	1.0	1.8	24.0	1126	912	1.83/4.61	3.08/7.41
3x10+1x6	1.0	1.0	1.8	24.3	1163	936	1.83/3.08	3.08/4.61
3x16+1x6	1.0	1.0	1.8	26.8	1562	1223	1.15/3.08	1.91/4.61
3x16+1x10	1.0	1.0	1.8	27.5	1634	1270	1.15/1.83	1.91/3.08
3x25+1x6					2014			
	1.2	1.0	1.8	30.2	2014	1501	0.727/3.08	1.20/4.61
3x25+1x10	1.2	1.0	1.8	30.7	2081	1544	0.727/1.83	1.20/3.08





CU(AL)/PVC/PVC/SWA/PVC 0.6/1(1.2) kV Conductor: Copper/Aluminum Insulation: PVC Bedding: PVC Armour: Galvanized Steel Wire

Sheath: PVC

Section	Insulation	Thickness	Sheath Thickness	Overall Diameter		Weight	DC. Electrical Re	
No.xmm ²	m	m	mm	mm	Cu	Al /km	Cu O/	Al km
3x35+1x10	1.2	1.0	1.8	31.9	2398	1686	0.524/1.83	0.868/3.08
3x35+1x16	1.2	1.0	1.9	32.5	2493	1744	0.524/1.15	0.868/1.91
3x35+1x25	1.2	1.2	1.9	33.5	2642	1836	0.524/0.727	0.868/1.20
3x50+1x16	1.4	1.0	2.0	36.0	3054	2075	0.387/1.15	0.641/1.91
3x50+1x25	1.4	1.2	2.0	37.6	3449	2413	0.387/0.727	0.641/1.20
3x50+1x35	1.4	1.2	2.0	38.0	3569	2477	0.387/0.524	0.641/0.868
3x70+1x16	1.4	1.0	2.1	39.9	4085	2713	0.268/1.15	0.443/1.91
3x70+1x10	1.4	1.2	2.1	40.8	4256	2825	0.268/0.727	0.443/1.20
3x70+1x35	1.4	1.2	2.1	41.0	4344	2857	0.268/0.524	0.443/0.868
3x70+1x50	1.4	1.4	2.2	42.0	4533	2971	0.268/0.387	0.443/0.641
3x95+1x35	1.6	1.2	2.3	45.4	5408	3427	0.193/0.524	0.320/0.868
3x95+1x50	1.6	1.4	2.3	46.2	5579	3522	0.193/0.387	0.320/0.641
3x95+1x70	1.6	1.4	2.3	47.1	5825	3638	0.193/0.268	0.320/0.443
3x120+1x50	1.6	1.4	2.4	50.7	6972	4453	0.153/0.387	0.253/0.641
3x120+1x70	1.6	1.4	2.5	51.5	7243	4595	0.153/0.268	0.253/0.443
3x120+1x95	1.6	1.6	2.5	52.7	7574	4763	0.153/0.193	0.253/0.320
3x150+1x50	1.8	1.4	2.5	54.6	8084	5043	0.124/0.387	0.206/0.641
3x150+1x70	1.8	1.4	2.6	55.3	8354	5184	0.124/0.268	0.206/0.443
3x150+1x95	1.8	1.6	2.6	56.4	8684	5352	0.124/0.193	0.206/0.320
3x150+1x120	1.8	1.6	2.7	57.5	9006	5522	0.124/0.153	0.206/0.253
3x185+1x70	2.0	1.4	2.7	59.4	9777	5915	0.0991/0.268	0.164/0.443
3x185+1x95	2.0	1.6	2.7	60.4	10105	6082	0.0991/0.193	0.164/0.320
3x185+1x120	2.0	1.6	2.8	61.8	10105	6300	0.0991/0.193	0.164/0.253
3x185+1x150	2.0	1.8	2.8	62.8	10819	6472	0.0991/0.124	0.164/0.206
3x240+1x70	2.2	1.4	2.9	65.5	11961	7018	0.0754/0.268	0.125/0.443
3x240+1x95	2.2	1.6	2.9	66.4	12330	7224	0.0754/0.193	0.125/0.320
3x240+1x120	2.2	1.6	2.9	67.1	12583	7325	0.0754/0.153	0.125/0.253
1x240+1x150	2.2	1.8	3.0	68.2	12955	7525	0.0754/0.124	0.125/0.206
3x300+1x95	2.4	1.6	3.1	71.8	14583	8325	0.0601/0.193	0.100/0.320
3x300+1x120	2.4	1.6	3.1	72.6	14846	8436	0.0601/0.153	0.100/0.253
3x300+1x150	2.4	1.8	3.1	73.4	15186	8605	0.0601/0.124	0.100/0.206
x300+1x185	2.4	2.0	3.2	74.6	15692	8883	0.0601/0.0991	0.100/0.164
3x300+1x240	2.4	2.2	3.2	76.1	16339	9176	0.0601/0.0754	0.100/0.125
8x400+1x120	2.6	1.6	3.4	81.1	18938	10946	0.0470/0.153	0.0778/0.253
8x400+1x150	2.6	1.8	3.4	81.9	19244	11081	0.0470/0.124	0.0778/0.200
3x400+1x185	2.6	2.0	3.4	83.1	19786	11395	0.0470/0.0991	0.0778/0.164
3x400+1x163	2.6	2.2	3.5	84.4	20474	11728	0.0470/0.0754	0.0778/0.125
	2.8	1.8	3.6	88.9	23177	12950		
3x500+1x150							0.0366/0.124	0.0605/0.200
3x500+1x185	2.8	2.0	3.6	89.8	23638	13185	0.0366/0.0991	0.0605/0.164
3x500+1x240	2.8	2.2	3.7	91.3	24352	13543	0.0366/0.0754	0.0605/0.125
3x500+1x300	2.8	2.4	3.7	92.6	25060	13873	0.0366/0.0601	0.0605/0.100
3x4+2x1.5	1.0	0.8	1.8	20.3	792	698	4.61/12.1	7.41/18.1
3x4+2x2.5	1.0	0.8	1.8	21.0	830	724	4.61/7.41	7.41/12.1
3x6+2x2.5	1.0	0.8	1.8	21.9	928	783	3.08/7.41	4.61/12.1
3x6+2x4	1.0	1.0	1.8	22.7	999	836	3.08/4.61	4.61/7.41
3x10+2x4	1.0	1.0	1.8	25.0	1218	978	1.83/4.61	3.08/7.41
3x10+2x6	1.0	1.0	1.8	26.1	1433	1168	1.83/3.08	3.08/4.61
3x16+2x6	1.0	1.0	1.8	27.9	1690	1312	1.15/3.08	1.91/4.61
3x16+2x10	1.0	1.0	1.8	29.1	1830	1402	1.15/1.83	1.91/3.08
3x25+2x6	1.2	1.0	1.8	31.1	2138	1587	0.727/3.08	1.20/4.61
3x25+2x10	1.2	1.0	1.8	32.1	2275	1674	0.727/1.83	1.20/3.08
3x25+2x16	1.2	1.0	1.8	33.0	2442	1766	0.727/1.15	1.20/1.91
	1.2						0.727/1.15	0.868/3.08
3x35+2x10		1.0	1.8	33.4	2604	1828		
3x35+2x16	1.2	1.0	1.8	34.2	2753	1902	0.524/1.15	0.868/1.91
3x35+2x25	1.2	1.2	1.9	36.1	3063	2096	0.524/0.727	0.868/1.20
3x50+2x16	1.4	1.0	1.9	38.3	3571	2490	0.387/1.15	0.641/1.91
3x50+2x25	1.4	1.2	2.0	40.0	3866	2670	0.387/0.727	0.641/1.20
3x50+2x35	1.4	1.2	2.0	40.6	4079	2766	0.387/0.524	0.641/0.868
3x70+2x16	1.4	1.0	2.1	41.3	4346	2871	0.268/1.15	0.443/1.91
3x70+2x25	1.4	1.2	2.1	42.8	4638	3048	0.268/0.727	0.443/1.20
3x70+2x35	1.4	1.2	2.1	43.3	4849	3142	0.268/0.524	0.443/0.868
3x70+2x50	1.4	1.4	2.2	45.2	5241	3381	0.268/0.387	0.443/0.641
3x95+2x35	1.6	1.2	2.2	47.3	5859	3694	0.193/0.524	0.320/0.868
3x95+2x50	1.6	1.4	2.3	50.4	6760	4405	0.193/0.387	0.320/0.641
3x95+2x70	1.6	1.4	2.3	52.1	7260	4644	0.193/0.268	0.320/0.443
3x120+2x50	1.6	1.4	2.4	53.3	7671	4855	0.153/0.387	0.253/0.641
3x120+2x70	1.6	1.4	2.5	54.6	8144	5065	0.153/0.268	0.253/0.443
3x120+2x95	1.6	1.6	2.5	56.9	8870	5461	0.153/0.193	0.253/0.320
3x150+2x50	1.8	1.4	2.5	57.0	8783	5455	0.124/0.387	0.206/0.641
3x150+2x70	1.8	1.4	2.6	58.4	9279	5679	0.124/0.268	0.206/0.443
3x150+2x95	1.8	1.6	2.6	60.4	9983	6053	0.124/0.193	0.206/0.320
	1.8	1.6	2.7	62.5	10650	6412	0.124/0.153	0.206/0.253





CU(AL)/PVC/PVC/SWA/PVC 0.6/1(1.2) kV Conductor: Copper/Aluminum Insulation: PVC Bedding: PVC Armour: Galvanized Steel Wire Sheath: PVC

Section	Insulation	Inickness	Sheath Thickness	Overall Diameter		Weight	DC. Electrical Re	
No.xmm ²	m	m	mm	mm	Cu ko	Al g/km	Cu Ω/I	Al (m
3x185+2x70	2.0	1.4	2.7	62.6	10747	6455	0.0991/0.268	0.164/0.443
3x185+2x95	2.0	1.6	2.8	64.4	11408	6786	0.0991/0.193	0.164/0.320
3x185+2x120	2.0	1.6	2.8	66.1	12033	7103	0.0991/0.153	0.164/0.253
3x185+2x150	2.0	1.8	2.8	68.1	12754	7476	0.0991/0.124	0.164/0.206
3x240+2x70							0.0754/0.268	
	2.2	1.4	2.9	67.8	12852	7478		0.125/0.443
3x240+2x95	2.2	1.6	3.0	69.8	13551	7847	0.0754/0.193	0.125/0.320
3x240+2x120	2.2	1.6	3.0	70.9	14129	8117	0.0754/0.153	0.125/0.253
3x240+2x150	2.2	1.8	3.1	73.0	14886	8506	0.0754/0.124	0.125/0.206
3x240+2x185	2.2	2.0	3.2	75.0	15763	8942	0.0754/0.0991	0.125/0.164
3x300+2x120	2.4	1.6	3.2	76.1	16352	9188	0.0601/0.153	0.100/0.253
3x300+2x150	2.4	1.8	3.1	77.8	17072	9560	0.0601/0.124	0.100/0.206
3x300+2x185	2.4	2.0	3.4	81.7	19007	11034	0.0601/0.0991	0.100/0.164
3x300+2x240	2.4	2.2	3.5	84.5	20455	11760	0.0601/0.0754	0.100/0.125
3x400+2x120	2.6	1.6	3.4	84.2	20450	11703	0.0470/0.153	0.0778/0.25
3x400+2x150	2.6	1.8	3.5	85.9	21167	12072	0.0470/0.124	0.0778/0.20
3x400+2x185	2.6	2.0	3.6	87.8	22127	12572	0.0470/0.0991	0.0778/0.16
3x400+2x240	2.6	2.2	3.7	90.6	23528	13251	0.0470/0.0754	0.0778/0.12
3x500+2x150	2.8	1.8	3.7	92,6	25037	13880	0.0366/0.124	0.0605/0.20
3x500+2x185	2.8	2.0	3.7	94.2	25961	14343	0.0366/0.0991	0.0605/0.164
3x500+2x240	2.8	2.2	3.8	96.7	27353	15013	0.0366/0.0754	0.0605/0.125
3x500+2x300	2.8	2.4	3.9	99.4	28834	15726	0.0366/0.0601	0.0605/0.100
4x4+1x1.5	1.0	0.8	1.8	21.2	841	732	4.61/12.1	7.41/18.1
4x4+1x2.5	1.0	0.8	1.8	21.4	865	750	4.61/7.41	7.41/12.1
4x6+1x2.5	1.0	0.8	1.8	22.5	987	820	3.08/7.41	4.61/12.1
		1.0				859		
4x6+1x4	1.0		1.8	23.0	1035		3.08/4.61	4.61/7.41
4x10+1x4	1.0	1.0	1.8	26.6	1480	1202	1.83/4.61	3.08/7.41
4x10+1x6	1.0	1.0	1.8	26.8	1504	1214	1.83/3.08	3.08/4.61
4x16+1x6	1.0	1.0	1.8	29.0	1842	1403	1.15/3.08	1.91/4.61
4x16+1x10	1.0	1.0	1.8	29.6	1912	1148	1.15/1.83	1.91/3.08
4x25+1x6	1.2	1.0	1.8	32.7	2411	1741	0.727/3.08	1.20/4.61
4x25+1x10	1.2	1.0	1.9	33.6	2501	1805	0.727/1.83	1.20/3.08
4x25+1x16	1.2	1.0	1.9	34.1	2586	1853	0.727/1.15	1.20/1.91
4x35+1x10	1.2	1.0	1.9	34.9	2923	1994	0.524/1.83	0.868/3.08
4x35+1x16	1.2	1.0	2.0	35.6	3023	2058	0.524/1.15	0.868/1.91
4x35+1x25	1.2	1.2	2.0	36.4	3152	2130	0.524/0.727	0.868/1.20
4x50+1x16	1.4	1.0	2.1	40.3	4010	2738	0.387/1.15	0.641/1.91
4x50+1x25	1.4	1.2	2.1	41.1	4150	2822	0.387/0.727	0.641/1.20
4x50+1x35	1.4	1.2	2.2	41.7	4290	2904	0.387/0.524	0.641/0.868
4x70+1x16	1.4	1.0	2.2	43.8	5021	3224	0.268/1.15	0.443/1.91
4x70+1x25	1.4	1.2	2.2	44.6	5164	3310	0.268/0.727	0.443/1.20
4x70+1x35	1.4	1.2	2.3	45.2	5306	3395	0.268/0.524	0.443/0.868
4x70+1x50	1.4	1.4	2.3	45.9	5473	3486	0.268/0.387	0.443/0.641
4x95+1x35	1.6	1.2	2.4	51.3	7145	4574	0.193/0.524	0.320/0.868
4x95+1x50	1.6	1.4	2.5	52.4	7361	4715	0.193/0.387	0.320/0.641
4x95+1x70	1.6	1.4	2.5	53.1	7616	4841	0.193/0.268	0.320/0.443
4x120+1x50	1.6	1.4	2.6	55.9	8563	5301	0.153/0.387	0.253/0.641
4x120+1x70	1.6	1.4	2.6	56.6	8780	5389	0.153/0.268	0.253/0.443
4x120+1x95	1.6	1.6	2.7	57.9	9177	5622	0.153/0.193	0.253/0.320
4x150+1x50	1.8	1.4	2.7	60.3	10014	6056	0.124/0.387	0.206/0.641
4x150+1x70	1.8	1.4	2.8	61.6	10384	6261	0.124/0.268	0.206/0.443
4x150+1x95	1.8	1.6	2.8	62.7	10685	6435	0.124/0.193	0.206/0.320
4x150+1x120	1.8	1.6	2.8	63.4	10976	6574	0.124/0.153	0.206/0.253
4x185+1x70	2.0	1.4	2.9	66.3	12166	7157	0.0991/0.268	0.164/0.443
4x185+1x95	2.0	1.6	2.9	67.3	12540	7369	0.0991/0.193	0.164/0.320
4x185+1x120	2.0	1.6	3.0	68.3	12870	7546	0.0991/0.153	0.164/0.253
4x185+1x150	2.0	1.8	3.0	69.1	13207	7712	0.0991/0.124	0.164/0.206
4x240+1x70	2.2	1.4	3.1	72.5	14926	8474	0.0754/0.268	0.125/0.443
4x240+1x95	2.2	1.6	3.1	73.7	15319	8705	0.0754/0.193	0.125/0.320
4x240+1x120	2.2	1.6	3.2	74.5	15642	8876	0.0754/0.153	0.125/0.253
4x240+1x150	2.2	1.8	3.2	75.5	15997	9060	0.0754/0.124	0.125/0.206
			3.2					
4x240+1x185	2.2	2.0		76.4	16426	9261	0.0754/0.0991	0.125/0.164
4x300+1x120	2.4	1.6	3.4	82.3	19575	11273	0.0601/0.153	0.100/0.253
4x300+1x150	2.4	1.8	3.4	83.3	19959	11486	0.0601/0.124	0.100/0.206
4x300+1x185	2.4	2.0	3.5	84.5	20461	11760	0.0601/0.0991	0.100/0.164
4x300+1x240	2.4	2.2	3.5	85.8	21129	12073	0.0601/0.0754	0.100/0.125
4x400+1x120	2.6	1.6	3.7	90.3	23681	13268	0.0470/0.153	0.0778/0.25
4x400+1x150	2.6	1.8	3.7	91.1	24056	13472	0.0470/0.124	0.0778/0.20
4x400+1x185	2.6	1	3.7	92.0	24520	13709	0.0470/0.0991	0.0778/0.164
								TO CONTRACT AND CO
4x400+1x240	2.6	2.2	3.8	93.6	25245	14079	0.0470/0.0754	0.0778/0.12
4x500+1x150	2.8	1.8	3.9	99.1	29108	15774	0.0366/0.124	0.0605/0.20
4x500+1x185	2.8	2.0	4.0	100.3	29630	16069	0.0366/0.0991	0.0605/0.16
4x500+1x240	2.8	2.2	4.0	101.6	30316	16400	0.0366/0.0754	0.0605/0.125
44300+14240								





CU(AL)/XLPE/PVC 0.6/1(1.2) kV

Standards

AS/NZS 5000.1
 DIN VDE 0276-603

IEC 60502-1 • NF C 32-321

Application

The cable is used for electricity supply in low voltage installation system, suitable for installation in indoors and outdoors, in cable ducts, underground, in power and switching stations, local energy distributions, industrial plants, where there is no risk of mechanical damage.

AS/NZS 5000.1

• Conductor: Copper/Aluminum

Insulation: PVC

• Sheath: PVC/PE(Optional)

• (Optional) Flame Retardant Property

• (Optional) Fire Resistant Property

• (Optional) Anti-Termite & Rodent Property

• (Optional) Water Resistant Property



Section	Insulation Thickness	Sheath Thickness	Overall Diameter	Cable	Weight	DC. Electrical Resistance at 20°C	
No.xmm ²	mm	mm	mm	Cu kg	Al /km	Cu Ω/	Al km
1x0.5	0.7	1.4	5.0	32		36.0	-
1x0.75	0.7	1.4	5.2	36	. 70	24.9	170
1x1.5	0.7	1.4	5.6	47	38	12.1	18.1
1x2.5	0.7	1.4	6.0	59	44	7.41	12.1
1x4	0.7	1.4	6.5	77	53	4.61	7.41
1x6	0.7	1.4	7.0	100	63	3.08	4.61
1x10	0.7	1.4	8.3	148	86	1.83	3.08
1x16	0.7	1.4	9.3	210	111	1.15	1.91
1x25	0.9	1.4	11.0	311	155	0.727	1.20
1x35	0.9	1.4	11.6	400	186	0.524	0.868
1x50	1.0	1.4	13.1	525	236	0.387	0.641
1x70	1.1	1.4	14.8	731	313	0.268	0.443
1x95	1.1	1.5	16.7	989	409	0.193	0.320
1x120	1.2	1.5	18.4	1229	497	0.153	0.253
1x150	1.4	1.6	20.5	1514	610	0.124	0.206
1x185	1.6	1.7	22.7	1884	753	0.0991	0.164
1x240	1.7	1.8	25.4	2443	957	0.0754	0.125
1x300	1.8	1.8	27.8	3026	1162	0.0601	0.100
1x400	2.0	2.0	31.5	3860	1476	0.0470	0.0778
1x500	2.2	2.1	35.1	4917	1855	0.0366	0.0605
1x630	2.4	2.2	39.2	6306	2347	0.0283	0.0469
1x800	2.6	2.3	43.8	8018	2948	0.0221	0.0367
2x0.5	0.7	1.8	9.2	82	2	36.0	_
2x0.75	0.7	1.8	9.6	92	=	24.9	
2x1.5	0.7	1.8	10.4	116	97	12.1	18.1
2x2.5	0.7	1.8	11.2	145	113	7.41	12.1
2x4	0.7	1.8	12.2	185	135	4.61	7.41
2x6	0.7	1.8	13.2	236	161	3.08	4.61
2x10	0.7	1.8	15.8	348	221	1.83	3.08
2x16	0.7	1.8	17.8	487	286	1.15	1.91
2x25	0.9	1.8	21.2	718	401	0.727	1.20
2x35	0.9	1.8	22.4	907	473	0.524	0.868
2x50	1.0	1.8	25.4	1189	603	0.387	0.641
2x70	1,1	1.8	28.8	1642	793	0.268	0.443
2x95	1.1	2.0	32.6	2220	1041	0.193	0.320
2x120	1.2	2.1	36.2	2769	1282	0.153	0.253
2x150	1.4	2.2	40.2	3404	1570	0.124	0.206
2x185	1.6	2.3	44.8	4222	1926	0.0991	0.164
2x240	1.7	2.5	49.8	5472	2455	0.0754	0.125
2x300	1.8	2.7	55.0	6804	3018	0.0601	0.100
2x400	2.0	2.9	62.0	8654	3814	0.0470	0.0778
2x500	2.2	3.1	69.2	11010	4795	0.0366	0.0605
3x0.5	0.7	1.8	9.6	94	-	36.0	-
3x0.75	0.7	1.8	10.0	106	+	24.9	(#)
3x1.5	0.7	1.8	10.8	137	109	12.1	18.1
3x2.5	0.7	1.8	11.7	176	129	7.41	12.1
3x4	0.7	1.8	12.8	232	157	4.61	7.41
3x6	0.7	1.8	13.9	303	190	3.08	4.61
3x10	0.7	1.8	16.7	454	265	1.83	3.08
3x16	0.7	1.8	18.8	648	346	1.15	1.91
3x25	0.9	1.8	22.5	969	494	0.727	1.20
3x35	0.9	1.8	23.8	1243	593	0.524	0.868
3x50	1.0	1.8	27.0	1640	760	0.387	0.641





CU(AL)/XLPE/PVC 0.6/1(1.2) kV Conductor: Copper/Aluminum Insulation: XLPE

Sheath: PVC

Section	Insulation Thicknes	s Sheath Thickness	Overall Diameter		Weight		esistance at 20°C
No.xmm ²	mm	mm	mm	Cu	/km	Cu	'km
3x70	1.1	1.9	30.9	2301	1028	0.268	0.443
3x95	1.1	2.0	34.8	3107	1340	0.193	0.320
3x120	1.2	2.1	38.7	3886	1656	0.153	0.253
3x150	1.4	2.3	43.2	4802	2050	0.124	0.206
3x185	1.6	2.4	47.7	5965	2522	0.0991	0.164
3x240	1.7	2.6	53.5	7748	3222	0.0754	0.125
3x300	1.8	2.8	59.1	9646	3969	0.0601	0.100
3x400	2.0	3.1	66.8	12306	5046	0.0470	0.0778
3x500	2.2	3.3	74.5	15676	6353	0.0366	0.0605
4x0.5	0.7	1.8	10.1	106	-	36.0	
4x0.75	0.7	1.8	10.6	122	_	24.9	_
4x1.5	0.7						
		1.8	11.6	164	126	12.1	18.1
4x2.5	0.7	1.8	12.5	212	150	7.41	12.1
4x4	0.7	1.8	13.8	285	185	4.61	7.41
4x6	0.7	1.8	15.0	377	225	3.08	4.61
4x10	0.7	1.8	18.1	571	318	1.83	3.08
4x16	0.7	1.8	20.5	824	422	1.15	1.91
4x25	0.9	1.8	24.6	1241	607	0.727	1.20
	0.9						
4x35		1.8	26.1	1603	737	0.524	0.868
4x50	1.0	1.9	29.9	2136	963	0.387	0.641
4x70	1.1	2.0	34.2	3003	1305	0.268	0.443
4x95	1.1	2.1	38.6	4065	1707	0.193	0.320
4x120	1.2	2.3	43.1	5103	2130	0.153	0.253
4x150	1.4	2.4	47.9	6282	2613	0.124	0.206
	1.6						0.164
4x185		2.6	53.1	7832	3241	0.0991	
4x240	1.7	2.8	59.6	10179	4145	0.0754	0.125
4x300	1.8	3.0	65.8	12673	5103	0.0601	0.100
4x400	2.0	3.3	74.4	16166	6486	0.0470	0.0778
4x500	2.2	3.5	83.0	20604	8173	0.0366	0.0605
5x0.5	0.7	1.8	10.7	120	+	36.0	(*)
5x0.75	0.7	1.8	11.3	140		24.9	
5x1.5	0.7	1.8	12.4	191	144	12.1	18.1
5x2.5	0.7	1.8	13.4	250	172	7.41	12.1
5x4	0.7	1.8	14.8	339	214	4.61	7.41
5x6	0.7	1.8	16.1	451	262	3.08	4.61
5x10	0.7	1.8	19.7	693	377	1.83	3.08
5x16	0.7	1.8	22.4	1007	504	1.15	1.91
5x25	0.9	1.8	26.9				1.20
				1522	730	0.727	
5x35	0.9	1.8	28.6	1973	891	0.524	0.868
5x50	1.0	2.0	33.0	2646	1180	0.387	0.641
5x70	1.1	2.1	37.8	3725	1603	0.268	0.443
5x95	1.1	2.3	42.8	5062	2115	0.193	0.320
5x120	1.2	2.4	47.6	6333	2616	0.153	0.253
5x150	1.4	2.6	53.1	7820	3233	0.124	0.206
5x185	1.6	2.8	58.9	9749	4011	0.0991	0.164
5x240	1.7	3.0	66.1	12670	5218	0.0754	0.125
5x300	1.8	3.2	73.0	15776	6313	0.0601	0.100
5x400	2.0	3.6	82.7	20154	8054	0.0470	0.0778
5x500	2.2	3.8	92.3	25687	10149	0.0366	0.0605
2x1+1x0.5	0.7 0.7	1.8	10.0	108	9	18.1/36.0	-
2x1+1x0.75	0.7 0.7	1.8	10.1	112	-	18.1/24.9	
							-
2x1.5+1x1	0.7 0.7	1.8	10.6	130	-	12.1/18.1	
2x2.5+1x1.5	0.7 0.7	1.8	11.4	163	122	7.41/12.1	12.1/18.
2x4+1x1.5	0.7 0.7	1.8	12.2	201	141	0.387/12.1	7.41/12.
2x4+1x2.5	0.7 0.7	1.8	12.4	212	147	0.387/7.41	7.41/7.4
2x6+1x2.5	0.7 0.7	1.8	13.2	260	169	3.08/7.41	4.61/7.4
2x6+1x4	0.7 0.7	1.8	13.5	278	178	3.08/0.387	4.61/4.6
2x10+1x4	0.7 0.7	1.8	15.8	385	234	1.83/0.387	3.08/4.6
2x10+1x6	0.7 0.7	1.8	15.9	405	241	1.83/3.08	3.08/3.0
2x16+1x6	0.7 0.7	1.8	17.8	542	303	1.15/3.08	1.91/3.0
2x16+1x10	0.7 0.7	1.8	18.1	581	318	1.15/1.83	1.91/1.9
2x25+1x6	0.9 0.7	1.8	21.9	788	434	0.727/3.08	1.20/3.0
2x25+1x10	0.9 0.7	1.8	21.2	806	427	0.727/1.83	1.20/1.9
2x25+1x16	0.9 0.7	1.8	21.4	861	445	0.727/1.15	1.20/1.9
2x35+1x10	0.9 0.7	1.8	22.4	995	500	0.524/1.83	0.868/1.9
2x35+1x16	0.9 0.7	1.8	22.5	1048	516	0.524/1.15	0.868/1.9
2x35+1x25	0.9 0.9	1.8	23.3	1146	557	0.524/0.727	0.868/1.2
2x50+1x16	1.0 0.7	1.8	25.4	1328	643	0.387/1.15	0.641/1.9
2x50+1x25	1.0 0.9	1.8	25.7	1416	673	0.387/0.727	0.641/1.2
2x50+1x35	1.0 0.9	1.8	26.0	1503	703	0.387/0.524	0.641/0.8
2x70+1x16	1.1 0.7	1.8	29.4	1798	850	0.268/1.15	0.443/1.9
2x70+1x25	1.1 0.9	1.8	28.8	1861	856	0.268/0.727	0.443/1.2
2x70+1x35	1.1 0.9	1.8	28.8	1941	879	0.268/0.524	0.443/0.8
2x70+1x50	1.1 1.0	1.9	29.7	2077	940	0.268/0.387	0.443/0.6
2x95+1x35	1.1 0.9	1.9	32.4	2505	1113	0.193/0.524	0.320/0.8
CCALTCCA			32,4				
2x95+1x50	1.1 1.0	1.9	32.5	2612	1144	0.193/0.387	0.320/0.6





CU(AL)/XLPE/PVC 0.6/1(1.2) kV
Conductor: Copper/Aluminum
Insulation: XLPE
Sheath: PVC

				Sneath: PVC				
Section	Insulation	Thickness	Sheath Thickness	Overall Diameter		Weight	DC. Electrical Re	
No.xmm ²	m	m	mm	mm	Cu ka	'km	Cu Al Ω/km	
2x120+1x50	1.2	1.0	2.0	36.0	3156	1381	0.153/0.387	0.253/0.641
2x120+1x70	1.2	1.1	2.1	36.5	3361	1457	0.153/0.268	0.253/0.443
2x120+1x95	1.2	1.1	2.1	37.4	3615	1547	0.153/0.193	0.253/0.320
2x150+1x50	1.4	1.0	2.1	40.2	3798	1674	0.124/0.387	0.206/0.641
2x150+1x70	1.4	1.1	2.2	40.2	3987	1734	0.124/0.268	0.206/0.443
2x150+1x95	1.4	1.1	2.2	40.7	4228	1812	0.124/0.193	0.206/0.320
2x150+1x120	1.4	1.2	2.2	41.6	4470	1903	0.124/0.153	0.206/0.253
2x185+1x70	1.6	1.1	2.2	44.2	4785	2071	0.0991/0.268	0.164/0.443
2x185+1x95	1.6	1.1	2.3	44.4	5026	2150	0.0991/0.193	0.164/0.320
2x185+1x120	1.6		2.3	45.0	5259	2231		
		1.2					0.0991/0.153	0.164/0.253
2x185+1x150	1.6	1.4	2.4	46.1	5554	2355	0.0991/0.124	0.164/0.206
2x240+1x70	1.7	1.1	2.4	50.5	6074	2639	0.0754/0.268	0.125/0.443
2x240+1x95	1.7	1.1	2.4	49.6	6255	2657	0.0754/0.193	0.125/0.320
2x240+1x120	1.7	1.2	2.5	49.8	6485	2735	0.0754/0.153	0.125/0.253
2x240+1x150	1.7	1.4	2.5	50.5	6754	2833	0.0754/0.124	0.125/0.206
2x300+1x95	1.8	1.1	2.5	55.3	7595	3229	0.0601/0.193	0.100/0.320
2x300+1x120	1.8	1.2	2.6	54.8	7792	3275	0.0601/0.153	0.100/0.253
2x300+1x150	1.8	1.4	2.6	54.8	8029	3341	0.0601/0.124	0.100/0.206
2x300+1x185	1.8	1.6	2.7	55.7	8404	3489	0.0601/0.0991	0.100/0.164
2x300+1x240	1.8	1.7	2.7	56.9	8954	3683	0.0601/0.0754	0.100/0.125
2x400+1x120	2.0	1.2	2.8	62.6	9685	4113	0.0470/0.153	0.0778/0.253
2x400+1x150	2.0	1.4	2.8	61.8	9877	4133	0.0470/0.124	0.0778/0.206
2x400+1x185	2.0	1.6	2.8	61.8	10193	4222	0.0470/0.0991	0.0778/0.164
2x400+1x240	2.0	1.7	2.9	62.8	10753	4427	0.0470/0.0754	0.0778/0.125
2x500+1x150	2.2	1.4	2.9	69.7	12256	5137	0.0366/0.124	0.0605/0.206
2x500+1x185	2.2	1.6	3.0	69.0	12545	5199	0.0366/0.0991	0.0605/0.164
2x500+1x240	2.2	1.7	3.1	69.2	13063	5362	0.0366/0.0754	0.0605/0.125
2x500+1x240	2.2	1.8	3.1	69.8	13620	5540	0.0366/0.0601	0.0605/0.100
3x1+1x0.5	0.7	0.7	1.8	10.7	128	3340		0.0003/0.100
						_	18.1/36.0	-
3x1+1x0.75	0.7	0.7	1.8	10.8	132	-	18.1/24.9	*
3x1.5+1x1	0.7	0.7	1.8	11.4	156		12.1/18.1	-
3x2.5+1x1.5	0.7	0.7	1.8	12.3	200	144	7.41/12.1	12.1/18.1
3x4+1x1.5	0.7	0.7	1.8	13.2	254	169	0.387/12.1	7.41/18.1
3x4+1x2.5	0.7	0.7	1.8	13.4	265	175	0.387/7.41	7.41/12.1
3x6+1x2.5	0.7	0.7	1.8	14.4	335	206	3.08/7.41	4.61/12.1
3x6+1x4	0.7	0.7	1.8	14.6	351	213	3.08/0.387	4.61/7.41
3x10+1x4	0.7	0.7	1.8	17.1	499	284	1.83/0.387	3.08/7.41
3x10+1x6	0.7	0.7	1.8	17.3	520	293	1.83/3.08	3.08/4.61
3x16+1x6	0.7	0.7	1.8	19.2	711	371	1.15/3.08	1.91/4.61
3x16+1x10	0.7	0.7	1.8	19.9	759	395	1.15/1.83	1.91/3.08
3x25+1x6	0.9	0.7	1.8	22.5	1024	512	0.727/3.08	1.20/4.61
3x25+1x10	0.9	0.7	1.8	23.1	1072	534	0.727/1.83	1.20/3.08
3x25+1x16	0.9	0.7	1.8	23.6	1134	559	0.727/1.15	1.20/1.91
3x35+1x10	0.9	0.7	1.8	24.2	1341	629	0.524/1.83	0.868/3.08
3x35+1x16	0.9	0.7	1.8	24.7	1404	655	0.524/1.15	0.868/1.91
3x35+1x25	0.9	0.7	1.8	25.7	1508	703	0.524/0.727	0.868/1.20
3x50+1x16	1.0	0.7	1.8	26.7	1772	793	0.387/1.15	0.641/1.91
3x50+1x16	1.0	0.7	1.8	27.6	1795	816		
3x50+1x16	1.0	0.7	1.8	26.7	1851	815	0.387/1.15	0.641/1.91
							0.387/0.727	
3x50+1x25	1.0	0.9	1.8	28.4	1896	860	0.387/0.727	0.641/1.20
3x50+1x35	1.0	0.9	1.8	26.7	1931	838	0.387/0.524	0.641/0.868
3x50+1x35	1.0	0.9	1.8	28.8	1987	894	0.387/0.524	0.641/0.868
3x70+1x16	1.1	0.7	1.9	31.2	2441	1069	0.268/1.15	0.443/1.91
3x70+1x16	1.1	0.7	1.9	31.0	2443	1071	0.268/1.15	0.443/1.91
3x70+1x25	1.1	0.9	1.9	31.2	2521	1092	0.268/0.727	0.443/1.20
3x70+1x25	1.1	0.9	1.9	31.9	2550	1121	0.268/0.727	0.443/1.20
3x70+1x35	1,1	0.9	1.9	31.2	2601	1115	0.268/0.524	0.443/0.868
3x70+1x35	1.1	0.9	1.9	32.1	2636	1149	0.268/0.524	0.443/0.868
3x70+1x50	1.1	1.0	2.0	31.4	2719	1157	0.268/0.387	0.443/0.641
3x70+1x50	1.1	1.0	2.0	33.2	2782	1220	0.268/0.387	0.443/0.641
3x95+1x35	1.1	0.9	2.0	35.6	3416	1435	0.193/0.524	0.320/0.868
3x95+1x35	1.1	0.9	2.0	35.6	3433	1452	0.193/0.524	0.320/0.868
3x95+1x50	1.1	1.0	2.1	35.8	3536	1479	0.193/0.387	0.320/0.641
3x95+1x50	1.1	1.0	2.1	36.5	3577	1520	0.193/0.387	0.320/0.641
3x95+1x70	1.1	1.1	2.1	35.8	3715	1528	0.193/0.268	0.320/0.443
							0.193/0.268	
3x95+1x70	1.1	1.1	2.1	37.5	3790	1604		0.320/0.443
3x120+1x50	1.2	1.0	2.2	39.6	4311	1792	0.153/0.387	0.253/0.641
3x120+1x50	1.2	1.0	2.2	39.9	4343	1824	0.153/0.387	0.253/0.641
3x120+1x70	1.2	1.1	2.2	39.6	4490	1841	0.153/0.268	0.253/0.443
3x120+1x70	1.2	1.1	2.2	40.9	4560	1911	0.153/0.268	0.253/0.443
3x120+1x95	1.2	1.1	2.2	39.6	4712	1901	0.153/0.193	0.253/0.320
3x120+1x95	1.2	1,1	2.2	41.6	4809	1998	0.153/0.193	0.253/0.320
	1.4	1.0	2.3	43.5	5198	2158	0.124/0.387	0.206/0.641
3x150+1x50								





Section	insulation	Thickness	Sheath Thickness	Overall Diameter		e Weight	DC. Electrical Re	
No.xmm ²	m	m	mm	mm	Cu k	Al g/km	Cu Ω/	Al km
3x150+1x70	1.4	1.1	2.3	43.5	5377	2207	0.124/0.268	0.206/0.443
3x150+1x70	1.4	1.1	2.3	44.6	5441	2271	0.124/0.268	0.206/0.443
3x150+1x95	1.4	1.1	2.4	43.7	5619	2286	0.124/0.193	0.206/0.320
3x150+1x95	1.4	1.1	2,4	45.6	5716	2384	0.124/0.193	0.206/0.320
3x150+1x120	1.4	1.2	2.4	43.7	5827	2343	0.124/0.153	0.206/0.253
3x150+1x120	1.4	1.2	2.4	46.7	5972	2488	0.124/0.153	0.206/0.253
3x185+1x70	1.6	1.1	2.5	49.7	6604	2743	0.0991/0.268	0.164/0.443
3x185+1x70	1.6	1.1	2.5	48.9	6613	2751	0.0991/0.268	0.164/0.443
3x185+1x95	1.6	1.1	2.5	49.7	6826	2802	0.0991/0.193	0.164/0.320
3x185+1x95	1.6	1.1	2.5	49.6	6867	2843	0.0991/0.193	0.164/0.320
3x185+1x120	1.6	1.2	2.5	49.7	7034	2859	0.0991/0.153	0.164/0.253
3x185+1x120	1.6	1.2	2.5	50.6	7121	2946	0.0991/0.153	0.164/0.253
3x185+1x150	1.6	1.4	2.6	49.9	7293	2946	0.0991/0.124	0.164/0.206
3x185+1x150	1.6	1.4	2.6	51.8	7428	3081	0.0991/0.124	0.164/0.206
3x240+1x70	1.7	1.1	2.6	55.2	8360	3417	0.0754/0.268	0.125/0.443
3x240+1x70	1.7	1.1	2.6	53.9	8349	3406	0.0754/0.268	0.125/0.443
3x240+1x95	1.7	1.1	2.6	55.2	8582	3476	0.0754/0.193	0.125/0.320
3x240+1x95	1.7	1.1	2.6	54.6	8606	3500	0.0754/0.193	0.125/0.320
3x240+1x120	1.7	1.2	2.7	55.4	8815	3557	0.0754/0.153	0.125/0.253
3x240+1x120	1.7	1.2	2.7	55.7	8884	3626	0.0754/0.153	0.125/0.253
3x240+1x150	1.7	1.4	2.7	55.4	9052	3623	0.0754/0.124	0.125/0.206
3x240+1x150	1.7	1.4	2.7	56.5	9163	3733	0.0754/0.124	0.125/0.206
3x300+1x95	1.8	1.1	2.8	59.6	10477	4219	0.0601/0.268	0.100/0.320
3x300+1x120	1.8	1.2	2.8	60.5	10735	4325	0.0601/0.153	0.100/0.253
3x300+1x150	1.8	1.4	2.9	61.5	11043	4462	0.0601/0.124	0.100/0.206
3x300+1x185	1.8	1.6	2.9	62.7	11427	4619	0.0601/0.0991	0.100/0.164
3x300+1x240	1.8	1.7	3.0	64.1	12012	4848	0.0601/0.0754	0.100/0.125
3x400+1x120	2.0	1.2	3.0	67.2	13326	5333	0.0470/0.153	0.0778/0.25
3x400+1x150	2.0	1.4	3.1	68.2	13642	5478	0.0470/0.124	0.0778/0.20
3x400+1x185	2.0	1.6	3.1	69.3	14026	5635	0.0470/0.0991	0.0778/0.16
3x400+1x240	2.0	1.7	3.2	70.6	14614	5868	0.0470/0.0754	0.0778/0.12
3x500+1x150	2.2	1.4	3.3	75.2	16973	6746	0.0366/0.124	0.0778/0.20
3x500+1x185	2.2	1.6	3.3	76.1	17350	6896	0.0366/0.0991	0.0778/0.16
3x500+1x240	2.2	1.7	3.4	77.5	17955	7146	0.0366/0.0754	0.0778/0.12
3x500+1x300	2.2	1.8	3.4	78.8	18565	7378	0.0366/0.0601	0.0778/0.10
3x1+2x0.5	0.7	0.7	1.8	11.2	141	1,50,50	18.1/36.0	
3x1+2x0.75		0.7	1.8	11.4	149	2	18.1/24.9	-
	0.7							
3x1.5+2x1	0.7	0.7	1.8	12.0	176		12.1/18.1	-7.
3x2.5+2x1.5	0.7	0.7	1.8	13.0	226	161	7.41/12.1	12.1/18.1
3x4+2x1.5	0.7	0.7	1.8	13.9	280	186	0.387/12.1	7.41/18.1
3x4+2x2.5	0.7	0.7	1.8	14.3	304	198	0.387/7.41	7.41/7.41
3x6+2x2.5	0.7	0.7	1.8	15.1	372	227	3.08/7.41	4.61/7.41
3x6+2x4	0.7	0.7	1.8	15.6	407	243	3.08/0.387	4.61/4.61
3x10+2x4	0.7	0.7	1.8	17.9	552	312	1.83/0.387	3.08/4.61
3x10+2x6	0.7	0.7	1.8	18.3	596	330	1.83/3.08	3.08/3.08
3x16+2x6	0.7	0.7	1.8	20.1	786	408	1.15/3.08	1.91/3.08
3x16+2x10	0.7	0.7	1.8	21.3	880	452	1.15/1.83	1.91/1.91
3x25+2x6	0.9	0.7	1.8	23.3	1099	548	0.727/3.08	1.20/3.08
3x25+2x10	0.9	0.7	1.8	24.3	1192	590	0.727/1.83	1.20/1.91
3x25+2x16	0.9	0.7	1.8	25.2	1316	640	0.727/1.15	1.20/1.91
3x35+2x10	0.9	0.7	1.8	25.4	1463	687	0.524/1.83	0.868/1.91
3x35+2x16	0.9	0.7	1.8	26.3	1588	737	0.524/1.15	0.868/1.91
3x35+2x25	0.9	0.9	1.8	27.9	1792	825	0.524/0.727	0.868/1.20
3x50+2x16	1.0	0.7	1.8	28.9	1974	893	0.387/1.15	0.641/1.91
3x50+2x25	1.0	0.9	1,9	30.6	2192	995	0.387/0.727	0.641/1.20
3x50+2x35	1.0	0.9	1.9	31.3	2375	1062	0.387/0.524	0.641/0.868
3x70+2x16	1.1	0.7	1.9	32.4	2629	1155	0.268/1.15	0.443/1.91
3x70+2x25	1.1	0.9	2.0	33.9	2847	1257	0.268/0.727	0.443/1.20
3x70+2x35	1.1	0.9	2.0	34.4	3025	1319	0.268/0.524	0.443/0.868
			2.1	36.0	3299	1439		
3x70+2x50	1.1	1.0					0.268/0.387	0.443/0.641
3x95+2x35	1.1	0.9	2.1	37.6	3820	1619	0.193/0.524	0.320/0.868
3x95+2x50	1.1	1.0	2.2	39.2	4099	1744	0.193/0.387	0.320/0.641
3x95+2x70	1.1	1.1	2.2	40.8	4522	1906	0.193/0.268	0.320/0.443
3x120+2x50	1.2	1.1	2.2	42.3	4851	2035	0.153/0.387	0.253/0.641
3x120+2x70	1.2	1.1	2.3	43.8	5286	2207	0.153/0.268	0.253/0.443
3x120+2x95	1.2	1.1	2.4	45.7	5828	2419	0.153/0.193	0.253/0.320
			2.3	45.9	5733	2395	0.124/0.387	0.206/0.641
3x150+2x50	1.4	1.1						
3x150+2x70	1.4	1.1	2.4	47.5	6177	2577	0.124/0.268	0.206/0.443
3x150+2x95	1.4	1.1	2.5	49.3	6722	2791	0.124/0.193	0.206/0.320
3x150+2x120	1.4	1.2	2.5	50.8	7214	2976	0.124/0.153	0.206/0.253
3x185+2x70	1.6	1.1	2.5	51.4	7330	3038	0.0991/0.268	0.164/0.443
3x185+2x95	1.6	1.1	2.6	52.9	7866	3244	0.0991/0.193	0.164/0.320
3x185+2x120	1.6	1.2	2.7	54.7	8392	3462	0.0991/0.153	0.164/0.253
			2.7	56.6	8972	3694		
3x185+2x150	1.6	1.4					0.0991/0.124	0.164/0.206
3x240+2x70	1.7	1.1	2.7	56.3	9086	3712	0.0754/0.268	0.125/0.443
3x240+2x95	1.7	1.1	2.7	57.6	9605	3901	0.0754/0.193	0.125/0.320
	4.7	1.2	2.8	59.3	10134	4122	0.0754/0.153	0.125/0.253
3x240+2x120	1.7	1.2	2.0	00.0				





CU(AL)/XLPE/PVC 0.6/1(1.2) kV
Conductor: Copper/Aluminum
Insulation: XLPE
Sheath: PVC

Section	Insulation	Thickness	Sheath Thickness	Overall Diameter		ble Weight		I Resistance at 20°C
No.xmm ²	m	m	mm	mm	Cu	kg/km	Cu	Al Ω/km
3x240+2x185	1.7	1.6	2.9	63.2	11492	4671	0.0601/0.193	0.100/0.320
3x300+2x120	1.8	1.2	2.9	63.9	11989	4825	0.0601/0.153	0.100/0.253
3x300+2x150	1.8	1.4	3.0	65.8	12600	5088	0.0601/0.124	0.100/0.206
3x300+2x185	1.8	1.6	3.1	57.7	13374	5401	0.0601/0.0991	0.100/0.164
3x300+2x240	1.8	1.7	3.1	70.1	14516	5821	0.0601/0.0754	0.100/0.125
3x400+2x120	2.0	1.2	3.1	70.4	14589	5842	0.0470/0.153	0.0778/0.253
3x400+2x150	2.0	1.4	3.2	72.0	15192	6098	0.0470/0.124	0.0778/0.206
3x400+2x185	2.0	1.6	3.3	73.8	15971	6416	0.0470/0.0991	0.0778/0.164
3x400+2x240	2.0	1.7	3.3	76.3	17133	6856	0.0470/0.0754	0.0778/0.125
3x500+2x150	2.2	1.4	3.3	78.6	18500	7342	0.0366/0.124	0.0605/0.206
3x500+2x185	2.2	1.6	3.4	80.3	19283	7665	0.0366/0.0991	0.0605/0.164
3x500+2x240	2.2	1.7	3.5	82.7	20472	8132	0.0366/0.0754	0.0605/0.125
3x500+2x300	2.2	1.8	3.6	85.0	21721	8613	0.0366/0.0601	0.0605/0.100
4x1+1x0.5	0.7	0.7	1.8	11.4	149	-	18.1/36.0	+
4x1+1x0.75	0.7	0.7	1.8	11.5	152	-	18.1/24.9	- 5
4x1.5+1x1	0.7	0.7	1.8	12.2	183		12.1/18.1	-
4x2.5+1x1.5	0.7	0.7	1.8	13.2	238	166	7.41/12.1	12.1/18.1
4x4+1x1.5	0.7	0.7	1.8	14.3	309	199		7.41/18.1
							0.387/12.1	
4x4+1x2.5	0.7	0.7	1.8	14.5	321	205	0.387/7.41	7.41/7.41
4x6+1x2.5	0.7	0.7	1.8	15.6	411	244	3.08/7.41	4.61/7.41
4x6+1x4	0.7	0.7	1.8	15.8	428	252	3.08/0.387	4.61/4.61
4x10+1x4	0.7	0.7	1.8	18.7	620	342	1.83/0.387	3.08/4.61
4x10+1x6	0.7	0.7	1.8	18.9	641	351	1.83/3.08	3.08/3.08
4x16+1x6	0.7	0.7	1.8	21.2	894	454	1.15/3.08	1.91/3.08
4x16+1x10	0.7	0.7	1.8	21.8	941	476	1.15/1.83	1.91/1.91
4x25+1x6	0.9	0.7	1.8	24.9	1303	632	0.727/3.08	1.20/3.08
4x25+1x10	0.9	0.7	1.8	25.5	1352	656	0.727/1.83	1.20/1.91
4x25+1x16	0.9	0.7	1.8	26.0	1415	682	0.727/1.15	1.20/1.91
4x35+1x10	0.9	0.7	1.8	26.9	1713	784	0.524/1.83	0.868/1.91
4x35+1x16	0.9	0.7	1.8	37.3	1774	808	0.524/1.15	0.868/1.91
4x35+1x25	0.9	0.9	1.8	28.2	1878	855	0.524/0.727	0.868/1.20
			1.9	30.9				
4x50+1x16	1.0	0.7			2304	1032	0.387/1.15	0.641/1.91
4x50+1x25	1.0	0.9	1.9	31.7	2408	1079	0.387/0.727	0.641/1.20
4x50+1x35	1.0	0.9	1.9	32.0	2497	1111	0.387/0.524	0.641/0.868
4x70+1x16	1.1	0.7	2.0	34.8	3162	1365	0.268/1.15	0.443/1.91
4x70+1x25	1.1	0.9	2.0	35.7	3271	1417	0.268/0.727	0.443/1.20
4x70+1x35	1.1	0.9	2.1	36.1	3373	1462	0.268/0.524	0.443/0.868
4x70+1x50	1.1	1.0	2.1	36.8	3502	1515	0.268/0.387	0.443/0.641
4x95+1x35	1.1	0.9	2.2	40.1	4429	1858	0.193/0.524	0.320/0.868
4x95+1x50	1.1	1.0	2.2	40.8	4559	1913	0.193/0.387	0.320/0.641
4x95+1x70	1.1	1.1	2.2	41.6	4769	1994	0.193/0.268	0.320/0.443
4x120+1x50	1.2	1.0	2.3	44.8	5576	2314	0.153/0.387	0.253/0.641
4x120+1x70	1.2	1.1	2.4	45.7	5804	2412	0.153/0.268	0.253/0.443
4x120+1x95	1.2	1.1	2.4	46.7	6069	2515	0.153/0.193	0.253/0.320
4x150+1x50	1.4	1.1	2.5	49.3	6760	2802	0.124/0.387	0.206/0.641
4x150+1x70	1.4	1.1	2.5	50.1	6976	2889	0.124/0.268	0.206/0.443
4x150+1x95	1.4	1.1	2.5	51.0	7240	2990	0.124/0.193	0.206/0.320
4x150+1x120	1.4	1.2	2.6	52.1	7513	3112	0.124/0.153	0.206/0.253
4x185+1x70	1.6	1.1	2.7	55.0	8522	3513	0.0991/0.268	0.164/0.443
4x185+1x95	1.6	1.1	2.7	55.8	8785	3613	0.0991/0.193	0.164/0.320
4x185+1x120	1.6	1.2	2.7	56.6	9035	3711	0.0991/0.153	0.164/0.253
4x185+1x150	1.6	1.4	2.8	57.8	9349	3855	0.0991/0.124	0.164/0.206
4x240+1x70	1.7	1.1	2.8	60.6	10816	4364	0.0754/0.268	0.125/0.443
4x240+1x95	1.7	1.1	2.9	61.7	11115	4500	0.0754/0.193	0.125/0.320
4x240+1x120	1.7	1.2	2.9	62.6	11374	4608	0.0754/0.153	0.125/0.253
4x240+1x150			2.9	63.5				
	1.7	1.4			11663	4726	0.0754/0.124	0.125/0.206
4x240+1x185	1.7	1.6	3.0	64.8	12071	4906	0.0601/0.193	0.100/0.320
4x300+1x120	1.8	1.2	3.1	68.1	13843	5541	0.0601/0.153	0.100/0.253
4x300+1x150	1.8	1.4	3.1	69.1	14143	5669	0.0601/0.124	0.100/0.206
4x300+1x185	1.8	1.6	3.1	70.1	14521	5821	0.0601/0.0991	0.100/0.164
4x300+1x240	1.8	1.7	3.2	71.5	15117	6061	0.0601/0.0754	0.100/0.125
4x400+1x120	2.0	1.2	3.3	76.0	17288	6878	0.0470/0.153	0.0778/0.253
4x400+1x150	2.0	1.4	3.4	77.0	17614	7030	0.0470/0.124	0.0778/0.206
4x400+1x185	2.0	1.6	3.4	77.9	17993	7182	0.0470/0.0991	0.0778/0.164
4x400+1x163 4x400+1x240	2.0	1.7	3.4	79.2	18573	7407	0.0470/0.0754	0.0778/0.125
4x500+1x150	2.2	1.4	3.6	85.0	22026	8692	0.0366/0.124	0.0605/0.206
4x500+1x185	2.2	1.6	3.6	86.0	22419	8858	0.0366/0.0991	0.0605/0.164
4x500+1x163 4x500+1x240	2.2	1.7	3.7	87.4	23038	9122	0.0366/0.0754	0.0605/0.125





CU(AL)/XLPE/PVC/SSTA/PVC 0.6/1(1.2) kV

Standards

AS/NZS 5000.1

DIN VDE 0276-603

• IEC 60502-1

HD 603

Application

The cable is used for electricity supply in low voltage installation system, suitable for installation in indoors and outdoors, in cable ducts, underground, in power and switching stations, local energy distributions, industrial plants, where there is no risk of mechanical damage.

AS/NZS 5000.1

• Conductor: Copper/Aluminum

Insulation: XLPEBedding: PVC

• Armour: Double Layer Stainless Steel Tape

• Sheath: PVC/PE(Optional)

(Optional) Flame Retardant Property

(Optional) Fire Resistant Property

(Optional) Anti-Termite & Rodent Property



Section	Insulation Thickness	Sheath Thickness	Overall Diameter	Cable	Weight	DC, Electrical Re	esistance at 20°C
				Cu	Al	Cu Al	
No.xmm²	mm	mm	mm	kg	/km	Ω/	km
1x10	0.7	1.8	11.7	254	192	1.83	3.08
1x16	0.7	1.8	12.7	327	228	1.15	1.91
1x25	0.9	1.8	14.4	448	292	0.727	1.20
1x35	0.9	1.8	15.0	543	330	0.524	0.868
1x50	1.0	1.8	16.5	686	397	0.387	0.641
1x70	1.1	1.8	18.2	911	493	0.268	0.443
1x95	1.1	1.8	19.9	1182	601	0.193	0.320
1x120	1.2	1.8	21.6	1440	708	0.153	0.253
1x150	1.4	1.8	23.5	1737	833	0.124	0.206
1x185	1.6	1.8	25.5	2118	987	0.0991	0.164
1x240	1.7	1.8	28.0	2692	1206	0.0754	0.125
1x300	1.8	1.9	30.6	3311	1447	0.0601	0.100
1x400	2.0	2.0	34.1	4166	1782	0.0470	0.0778
1x500	2.2	2.1	38.9	5626	2564	0.0366	0.0605
1x630	2.4	2.3	43.2	7114	3154	0.0283	0.0469
1000	2.6	2.4	47.0	0010	2040	0.0221	0.0267





CU(AL)/XLPE/PVC/STA/PVC 0.6/1(1.2) kV

Standards

AS/NZS 5000.1

DIN VDE 0276-603

• IEC 60502-1

HD 603

Application

The cable is used for electricity supply in low voltage installation system, suitable for installation in indoors and outdoors, in cable ducts, underground, in power and switching stations, local energy distributions, industrial plants, where there is no risk of mechanical damage.

AS/NZS 5000.1

• Conductor: Copper/Aluminum

Insulation: XLPEBedding: PVC

Armour: Double Layer Galvanized Steel Tape


• Sheath: PVC/PE(Optional)

(Optional) Flame Retardant Property

(Optional) Fire Resistant Property

(Optional) Anti-Termite & Rodent Property

(Optional) Water Resistant Property



Section	Insulation Thickness	Sheath Thickness	Overall Diameter		Weight	DC. Electrical Re	
No.xmm ²	mm	mm	mm	Cu	Al Al	Cu	Al .
2-4	0.7	1.0	12.6		/km	2020	km 7.41
2x4		1.8	13.6	285	235	4.61	7.41
2x6	0.7	1.8	14.6	346	270	3.08	4.61
2x10	0.7	1.8	17.2	482	356	1.83	3.08
2x16	0.7	1.8	19.2	641	439	1.15	1.91
2x25	0.9	1.8	22.6	904	588	0.727	1.20
2x35	0.9	1.8	23.8	1105	672	0.524	0.868
2x50	1.0	1.8	26.8	1416	830	0.387	0.641
2x70	1.1	1.9	30.4	1915	1067	0.268	0.443
2x95	1.1	2.0	34.0	2514	1336	0.193	0.320
2x120	1.2	2.1	38.8	3465	1978	0.153	0.253
2x150	1.4	2.3	43.0	4197	2362	0.124	0.206
2x185	1.6	2.4	47.2	5098	2802	0.0991	0.164
2x240	1.7	2.6	52.6	6453	3436	0.0754	0.125
2x300	1.8	2.7	57.6	7861	4076	0.0601	0.100
2x400	2.0	3.0	64.8	9875	5036	0.0470	0.0778
2x500	2.2	3.2	72.0	12374	6159	0.0366	0.0605
3x4	0.7	1.8	14.2	338	263	4.61	7.41
3x6	0.7	1.8	15.3	419	308	3.08	4.61
3x10	0.7	1.8	18.1	598	408	1.83	3.08
3x16	0.7	1.8	20.2	811	509	1.15	1.91
3x25	0.9	1.8	23.9	1168	693	0.727	1.20
3x35	0.9	1.8	25.2	1455	805	0.524	0.868
3x50	1.0	1.8	28.4	1883	1003	0.387	0.641
3x70	1.1	1.9	32.3	2580	1307	0.268	0.443
3x95	1.1	2.1	36.4	3439	1671	0.193	0.320
3x120	1.2	2.2	41.5	4650	2420	0.153	0.253
3x150	1.4	2.4	46.0	5652	2901	0.124	0.206
3x185	1.6	2.5	50.5	6906	3463	0.0991	0.164
3x240	1.7	2.7	56.3	8802	4277	0.0754	0.125
3x300	1.8	2.9	61.9	10810	5133	0.0601	0.100
3x400	2.0	3.1	69.4	13590	6330	0.0470	0.0778
3x500	2.2	3.3	77.1	17109	7786	0.0366	0.0605
4x4	0.7	1.8	15.2	400	300	4.61	7.41
4x6	0.7	1.8	16.4	504	352	3.08	4.61
4x10	0.7	1.8	19.5	728	475	1.83	3.08
4x16	0.7	1.8	21.9	1004	602	1.15	1.91
	0.9	1.8	26.0	1461	827	0.727	1.20
4x25 4x35	0.9	1.8	27.5	1837	971	0.524	0.868
4x50	1.0	1.8	31.3	2405	1233	0.524	0.641
4x70	1.1	2.0	35.6	3312	1615	0.268	0.443
4x95	1.1	2.2	41.4	4827	2470	0.193	0.320
4x120	1.2	2.4	45.9	5952	2979	0.153	0.253
4x150	1.4	2.5	50.7	7227	3558	0.124	0.206
4x185	1.6	2.7	55.9	8878	4287	0.0991	0.164
4x240	1.7	2.9	62.4	11353	5320	0.0754	0.125
4x300	1.8	3.1	68.6	13970	6400	0.0601	0.100
4x400	2.0	3.4	77.2	17631	7951	0.0470	0.0778
4x500	2.2	3.7	87.2	23128	10698	0.0366	0.0605
5x4	0.7	1.8	16.2	464	339	4.61	0.641
5x6	0.7	1.8	17.5	589	400	3.08	0.443
5x10	0.7	1.8	21.1	865	549	1.83	3.08
5x16	0.7	1.8	23.8	1206	703	1.15	1.91





CU(AL)/XLPE/PVC/STA/PVC 0.6/1(1.2) kV Conductor: Copper/Aluminum Insulation: XLPE Bedding: PVC Armour: Double Layer Galvanized Steel Tape Sheath: PVC

Section	Insulation	Thickness	Sheath Thickness	Overall Diameter		Weight	DC. Electrical Re	
No.xmm ²	m	m	mm	mm	Cu	Al	Cu	AI
	0.	0	4.0	20.2		km 072		km
5x25	0.		1.8	28.3	1763	972	0.727	1.20
5x35			1.9	30.2	2245	1162	0.524	0.868
5x50	1.		2.0	34.4	2945	1479	0.387	0.641
5x70	1.		2.2	40.6	4471	2349	0.268	0.443
5x95	1.		2.3	45.4	5885	2939	0.193	0.320
5x120	1.		2.5	50.4	7272	3555	0.153	0.253
5x150	1.		2.7	55.9	8866	4280	0.124	0.206
5x185	1.		2.9	61.7	10909	5171	0.0991	0.164
5x240	1.	.7	3.1	68.9	13973	6430	0.0754	0.125
5x300	1.	.8	3.3	75.8	17215	7752	0.0601	0.100
5x400	2.	.0	3.7	83.7	22627	10527	0.0470	0.0778
5x500	2.	.2	4.0	96.5	28492	12954	0.0366	0.0605
2x4+1x1.5	0.7	0.7	1.8	13.6	301	241	0.387/12.1	7.41/12.1
2x4+1x2.5	0.7	0.7	1.8	13.8	314	249	0.387/7.41	7.41/7.41
2x6+1x2.5	0.7	0.7	1.8	14.6	370	279	3.08/7.41	4.61/7.41
2x6+1x4	0.7	0.7	1.8	14.9	390	290	3.08/0.387	4.61/4.61
2x10+1x4	0.7	0.7	1.8	17.2	520	369	1.83/0.387	3.08/4.61
2x10+1x6	0.7	0.7	1.8	17.3	540	376		
							1.83/3.08	3.08/3.08
2x16+1x6	0.7	0.7	1.8	19.2	696	457	1.15/3.08	1.91/3.08
2x16+1x10	0.7	0.7	1.8	19.5	738	475	1.15/1.83	1.91/1.91
2x25+1x6	0.9	0.7	1.8	23.3	981	627	0.727/3.08	1.20/3.08
2x25+1x10	0.9	0.7	1.8	22.6	993	614	0.727/1.83	1.20/1.91
2x25+1x16	0.9	0.7	1.8	22.8	1050	634	0.727/1.15	1.20/1.91
2x35+1x10	0.9	0.7	1.8	23.8	1194	698	0.524/1.83	0.868/1.91
2x35+1x16	0.9	0.7	1.8	23.9	1248	715	0.524/1.15	0.868/1.91
2x35+1x25	0.9	0.9	1.8	24.7	1353	764	0.524/0.727	0.868/1.20
2x50+1x16	1.0	0.7	1.8	26.8	1556	870	0.387/1.15	0.641/1.91
2x50+1x25	1.0	0.9	1.8	27.1	1646	903	0.387/0.727	0.641/1.20
2x50+1x35	1.0	0.9	1.8	27.4	1736	937	0.387/0.524	0.641/0.868
2x70+1x16	1.1	0.7	1.8	30.8	2064	1116	0.268/1.15	0.443/1.91
2x70+1x25	1.1	0.9	1.8	30.2	2121	1116	0.268/0.727	0.443/1.20
2x70+1x25	1.1	0.9	1.9	30.4	2215	1152	0.268/0.524	0.443/1.20
2x70+1x50	1.1	1.0	1.9	31.1	2345	1207	0.268/0.387	0.443/0.641
2x95+1x35	1.1	0.9	1.9	33.8	2799	1407	0.193/0.524	0.320/0.868
2x95+1x50	1.1	1.0	2.0	34.1	2921	1454	0.193/0.387	0.320/0.641
2x95+1x70	1.1	1.1	2.0	35.0	3137	1541	0.193/0.268	0.320/0.443
2x120+1x50	1.2	1.0	2.1	37.6	3500	1724	0.153/0.387	0.253/0.641
2x120+1x70	1.2	1.1	2.1	39.1	4063	2158	0.153/0.268	0.253/0.443
2x120+1x95	1.2	1.1	2.2	40.2	4352	2285	0.153/0.193	0.253/0.320
2x150+1x50	1.4	1.0	2.2	43.0	4593	2469	0.124/0.387	0.206/0.641
2x150+1x70	1.4	1.1	2.2	42.8	4760	2507	0.124/0.268	0.206/0.443
2x150+1x95	1.4	1.1	2.3	43.5	5030	2615	0.124/0.193	0.206/0.320
2x150+1x120	1.4	1.2	2.3	44.4	5291	2725	0.124/0.153	0.206/0.253
2x185+1x70	1.6	1.1	2.3	47.0	5659	2946	0.0991/0.268	0.164/0.443
2x185+1x95	1.6	1.1	2.4	47.2	5902	3026	0.0991/0.193	0.164/0.320
2x185+1x120	1.6	1.2	2.4	47.8	6147	3120	0.0991/0.153	0.164/0.253
2x185+1x150	1.6	1.4	2.4	48.7	6441	3242	0.0991/0.124	0.164/0.206
2x240+1x70	1.7	1.1	2.4	53.1	7049	3614	0.0754/0.268	0.125/0.443
2x240+1x95	1.7	1.1	2.5	52.4	7235	3637	0.0754/0.193	0.125/0.320
x240+1x120	1.7	1.2	2.5	52.4	7443	3694	0.0754/0.153	0.125/0.253
x240+1x150	1.7	1.4	2.6	53.3	7750	3829	0.0754/0.124	0.125/0.206
2x300+1x95	1.8	1.1	2.6	58.1	8690	4324	0.0601/0.193	0.100/0.320
x300+1x120	1.8	1.2	2.6	57.4	8848	4331	0.0601/0.153	0.100/0.253
x300+1x150	1.8	1.4	2.7	57.6	9111	4422	0.0601/0.124	0.100/0.206
2x300+1x185	1.8	1.6	2.7	58.3	9476	4560	0.0601/0.0991	0.100/0.164
x300+1x240	1.8	1.7	2.8	59.7	10076	4805	0.0601/0.0754	0.100/0.125
x400+1x120	2.0	1.2	2.8	65.2	10893	5321	0.0470/0.153	0.0778/0.25
2x400+1x150	2.0	1.4	2.9	64.6	11097	5353	0.0470/0.124	0.0778/0.200
x400+1x185	2.0	1.6	2.9	64.6	11412	5442	0.0470/0.0991	0.0778/0.164
x400+1x240	2.0	1.7	3.0	65.6	11990	5664	0.0470/0.0754	0.0778/0.12
2x500+1x150	2.2	1.4	3.0	72.5	13636	6517	0.0366/0.124	0.0605/0.206
	2.2		3.1	71.8	13908		0.0366/0.0991	
x500+1x185		1.6				6562		0.0605/0.164
2x500+1x240	2.2	1.7	3.1	71.8	14396	6694	0.0366/0.0754	0.0605/0.12
x500+1x300	2.2	1.8	3.2	72.6	14996	6916	0.0366/0.0601	0.0605/0.100
3x4+1x1.5	0.7	0.7	1.8	14.6	363	279	0.387/12.1	7.41/18.1
3x4+1x2.5	0.7	0.7	1.8	14.8	377	286	0.387/7.41	7.41/12.1
3x6+1x2.5	0.7	0.7	1.8	15.8	456	327	3.08/7.41	4.61/12.1
3x6+1x4	0.7	0.7	1.8	16.0	474	336	3.08/0.387	4.61/7.41
3x10+1x4	0.7	0.7	1.8	18.5	646	432	1.83/0.387	3.08/7.41
3x10+1x6	0.7	0.7	1.8	18.7	669	442	1.83/3.08	3.08/4.61
3x16+1x6	0.7	0.7	1.8	20.6	878	539	1.15/3.08	1.91/4.61
3x16+1x10	0.7	0.7	1.8	21.3	933	569	1.15/1.83	1.91/3.08
3x25+1x6	0.9	0.7	1.8	23.9	1223	711	0.727/3.08	1.20/4.61
JAZJT IXO						711		
3x25+1x10	0.9	0.7	1.8	24.5	1277		0.727/1.83	1.20/3.08





CU(AL)/XLPE/PVC/STA/PVC 0.6/1(1.2) kV Conductor: Copper/Aluminum Insulation: XLPE

000

Bedding: PVC
 Armour: Double Layer Galvanized Steel Tape
 Sheath: PVC

Section	Insulation	Thickness	Sheath Thickness	Overall Diameter		ble Weight		esistance at 20°C
No.xmm ²	m	m	mm	mm	Cu	Al kg/km	Cu Ω	/km
3x35+1x10	0.9	0.7	1.8	25.6	1557	845	0.524/1.83	0.868/3.08
3x35+1x16	0.9	0.7	1.8	26.1	1625	876	0.524/1.15	0.868/1.91
3x35+1x25	0.9	0.7	1.8	27.1	1739	933	0.524/0.727	0.868/1.20
3x50+1x16	1.0	0.7	1.8	28.1	2011	1033	0.387/1.15	0.641/1.91
3x50+1x16	1.0	0.7	1.8	29.0	2044	1065	0.387/1.15	0.641/1.91
3x50+1x25	1.0	0.9	1.8	28.1	2091	1055	0.387/0.727	0.641/1.20
3x50+1x25	1.0	0.9	1.8	29.8	2153	1117	0.387/0.727	0.641/1.20
3x50+1x35	1.0	0.9	1.9	28.3	2183	1090	0.387/0.524	0.641/0.868
3x50+1x35	1.0	0.9	1.9	30.4	2261	1168	0.387/0.524	0.641/0.868
3x70+1x16	1.1	0.7	1.9	32.6	2724	1351	0.268/1.15	0.443/1.91
3x70+1x16	1.1	0.7	1.9	32.4	2723	1351	0.268/1.15	0.443/1.91
3x70+1x25	1.1	0.9	1.9	32.6	2803	1374	0.268/0.727	0.443/1.20
3x70+1x25	1.1	0.9	1.9	33.3	2839	1409	0.268/0.727	0.443/1.20
	1.1	0.9	2.0	32.8	2898	1411		
3x70+1x35							0.268/0.524	0.443/0.868
3x70+1x35	1.1	0.9	2.0	33.7	2941	1455	0.268/0.524	0.443/0.868
3x70+1x50	1.1	1.0	2.0	32.8	3002	1440	0.268/0.387	0.443/0.641
3x70+1x50	1.1	1.0	2.0	34.6	3082	1520	0.268/0.387	0.443/0.641
3x95+1x35	1.1	0.9	2.1	37.2	3756	1774	0.193/0.524	0.320/0.868
3x95+1x35	1.1	0.9	2.1	27.2	3773	1791	0.193/0.524	0.320/0.868
3x95+1x50	1.1	1.0	2.1	38.4	4223	2166	0.193/0.387	0.320/0.641
3x95+1x50	1.1	1.0	2.1	39.1	4278	2222	0.193/0.387	0.320/0.641
3x95+1x70	1.1	1.1	2.2	38.6	4419	2233	0.193/0.268	0.320/0.443
3x95+1x70	1.1	1.1	2.2	40.3	4530	2344	0.193/0.268	0.320/0.443
3x120+1x50	1.2	1.0	2.2	42.2	5072	2553	0.153/0.387	0.253/0.641
3x120+1x50	1.2	1.0	2.2	42.5	5111	2591	0.153/0.387	0.253/0.641
3x120+1x70	1.2	1.1	2.3	42.4	5269	2621	0.153/0.268	0.253/0.443
	1.2			43.7				
3x120+1x70		1.1	2.3		5366	2718	0.153/0.268	0.253/0.443
3x120+1x95	1.2	1.1	2.3	42.4	5492	2681	0.153/0.193	0.253/0.320
3x120+1x95	1.2	1.1	2.3	44.4	5630	2819	0.153/0.193	0.253/0.320
3x150+1x50	1.4	1.0	2.4	46.3	6056	3015	0.124/0.387	0.206/0.641
3x150+1x50	1.4	1.0	2.4	46.7	6099	3058	0.124/0.387	0.206/0.641
3x150+1x70	1.4	1.1	2.4	46.3	6235	3065	0.124/0.268	0.206/0.443
3x150+1x70	1.4	1.1	2.4	47.4	6321	3151	0.124/0.268	0.206/0.443
3x150+1x95	1.4	1.1	2.4	46.3	6457	3124	0.124/0.193	0.206/0.320
3x150+1x95	1.4	1.1	2.4	48.2	6593	3261	0.124/0.193	0.206/0.320
3x150+1x120	1.4	1.2	2.5	46.5	6686	3201	0.124/0.153	0.206/0.253
3x150+1x120	1.4	1.2	2.5	49.5	6892	3408	0.124/0.153	0.206/0.253
3x185+1x70	1.6	1.1	2.5	52.3	7560	3699	0.0991/0.268	0.164/0.443
3x185+1x70	1.6	1.1	2.5	51.5	7553	3692	0.0991/0.268	0.164/0.443
3x185+1x95	1.6	1.1	2.6	52.5	7805	3781	0.0991/0.193	0.164/0.320
3x185+1x95	1.6	1.1	2.6	52.4	7844	3820	0.0991/0.193	0.164/0.320
	1.6	1.2	2.6	52.5	8014	3838		
3x185+1x120							0.0991/0.153	0.164/0.253
3x185+1x120	1.6	1.2	2.6	53.4	8119	3943	0.0991/0.153	0.164/0.253
3x185+1x150	1.6	1.4	2.6	52.5	8251	3904	0.0991/0.124	0.164/0.206
3x185+1x150	1.6	1.4	2.0	54.4	5424	4077	0.0991/0.124	0.164/0.206
3x240+1x70	1.7	1.1	2.7	58.0	9450	4507	0.0754/0.268	0.125/0.443
3x240+1x70	1.7	1.1	2.7	56.7	9412	4469	0.0754/0.268	0.125/0.443
3x240+1x95	1.7	1.1	2.7	58.0	9672	4566	0.0754/0.193	0.125/0.320
3x240+1x95	1.7	1.1	2.7	57.4	9684	4578	0.0754/0.193	0.125/0.320
3x240+1x120	1.7	1.2	2.8	58.2	9906	4648	0.0754/0.153	0.125/0.253
3x240+1x120	1.7	1.2	2.8	58.5	9981	4723	0.0754/0.153	0.125/0.253
3x240+1x150	1.7	1.4	2.8	58.2	10143	4714	0.0754/0.124	0.125/0.206
3x240+1x150	1.7	1.4	2.8	59.3	10276	4847	0.0754/0.124	0.125/0.206
3x300+1x95	1.8	1.1	2.9	62.4	11652	5394	0.0601/0.268	0.100/0.320
3x300+1x120	1.8	1.2	2.9	63.3	11928	5518	0.0601/0.153	0.100/0.253
3x300+1x150	1.8	1.4	2.9	64.1	12226	5645	0.0601/0.124	0.100/0.206
				65.5				
3x300+1x185	1.8	1.6	3.0		12663	5854	0.0601/0.0991	0.100/0.164
3x300+1x240	1.8	1.7	3.0	66.7	13244	6081	0.0601/0.0754	0.100/0.125
3x400+1x120	2.0	1.2	3.1	70.0	14651	6659	0.0470/0.153	0.0778/0.253
3x400+1x150	2.0	1.4	3.2	71.0	14985	6821	0.0470/0.124	0.0778/0.206
3x400+1x185	2.0	1.6	3.2	72.1	15392	7001	0.0470/0.0991	0.0778/0.164
3x400+1x240	2.0	1.7	3.2	73.2	15972	7226	0.0470/0.0754	0.0778/0.125
3x500+1x150	2.2	1.4	3.3	77.8	18420	8194	0.0366/0.124	0.0778/0.206
3x500+1x185	2.2	1.6	3.4	78.9	18850	8396	0.0366/0.0991	0.0778/0.164
3x500+1x240	2.2	1.7	3.4	80.1	19446	8636	0.0366/0.0754	0.0778/0.125
3x500+1x300	2.2	1.8	3.5	81.6	20118	8930	0.0366/0.0601	0.0778/0.100
3x4+2x1.5	0.7	0.7	1.8	15.3	396	302	0.387/12.1	7.41/18.1
3x4+2x2.5	0.7	0.7	1.8	15.7	424	318	0.387/7.41	7.41/7.41
3x6+2x2.5	0.7	0.7	1.8	16.5	499	355	3.08/7.41	4.61/7.41
3x6+2x4	0.7	0.7	1.8	17.0	539	376	3.08/0.387	4.61/4.61
3x10+2x4	0.7	0.7	1.8	19.3	707	467	1.83/0.387	3.08/4.61
3x10+2x6	0.7	0.7	1.8	19.7	755	489	1.83/3.08	3.08/3.08





CU(AL)/XLPE/PVC/STA/PVC 0.6/1(1.2) kV Conductor: Copper/Aluminum Insulation: XLPE Bedding: PVC Armour: Double Layer Galvanized Steel Tape Sheath: PVC

	Insulation Thickness		Sheath Thickness	Overall Diameter		Weight	DC. Electrical Resistance at 20°C	
No.xmm²	m	ım	mm	mm	Cu	Al g/km	Cu O/	Al km
3x16+2x6	0.7	0.7	1.8	21.5	962	584	1.15/3.08	1.91/3.08
3x16+2x10	0.7	0.7	1.8	22.7	1068	640	1.15/1.83	1.91/1.91
3x25+2x6	0.9	0.7	1.8	24.7	1306	755	0.727/3.08	1.20/3.08
3x25+2x10	0.9	0.7	1.8	25.7	1409	807	0.727/1.83	1.20/1.91
3x25+2x16	0.9	0.7	1.8	26.6	1542	865	0.727/1.15	1.20/1.91
3x35+2x10	0.9	0.7	1.8	26.8	1690	914	0.524/1.83	0.868/1.9
3x35+2x16	0.9	0.7	1.8	27.7	1824	973	0.524/1.15	0.868/1.9
3x35+2x25	0.9	0.9	1.8	29.3	2043	1077	0.524/0.727	0.868/1.2
3x50+2x16	1.0	0.7	1.8	30.3	2235	1155	0.387/1.15	0.641/1.9
	1.0	0.9						
3x50+2x25			1.9	32.0	2468	1272	0.387/0.727	0.641/1.2
3x50+2x35	1.0	0.9	1.9	32.7	2658	1345	0.387/0.524	0.641/0.86
3x70+2x16	1.1	0.7	1.9	33.8	2923	1449	0.268/1.15	0.443/1.9
3x70+2x25	1.1	0.9	2.0	35.3	3154	1564	0.268/0.727	0.443/1.2
3x70+2x35	1.1	0.9	2.0	35.8	3337	1631	0.268/0.524	0.443/0.86
3x70+2x50	1.1	1.0	2.1	38.6	3990	2131	0.268/0.387	0.443/0.64
3x95+2x35	1.1	0.9	2.2	40.4	4561	2360	0.193/0.524	0.320/0.86
3x95+2x50	1.1	1.0	2.2	41.8	4852	2497	0.193/0.387	0.320/0.64
3x95+2x70	1,1	1.1	2.3	43.6	5327	2710	0.193/0.268	0.320/0.44
3x120+2x50	1.2	1.1	2.3	45.1	5687	2870	0.153/0.387	0.253/0.64
3x120+2x70	1.2	1.1	2.4	46.6	6149	3071	0.153/0.268	0.253/0.44
3x120+2x95	1.2	1.1	2.4	48.3	6706	3297	0.153/0.193	0.253/0.32
3x150+2x50	1.4	1.1	2.4	48.7	6640	3301	0.124/0.387	0.206/0.64
3x150+2x70	1.4	1.1	2.5	50.3	7114	3514		
							0.124/0.268	0.206/0.44
3x150+2x95	1.4	1.1	2.6	52.1	7693	3762	0.124/0.193	0.206/0.32
3x150+2x120	1.4	1.2	2.6	53.6	8216	3978	0.124/0.153	0.206/0.25
3x185+2x70	1.6	1.1	2.6	54.2	8344	4052	0.0991/0.268	0.164/0.44
3x185+2x95	1.6	1.1	2.7	55.7	8908	4587	0.0991/0.193	0.164/0.32
3x185+2x120	1.6	1.2	2.7	57.3	9444	4514	0.0991/0.153	0.164/0.25
	1.6	1.4	2.8	59.4	10087	4810		
3x185+2x150							0.0991/0.124	0.164/0.20
3x240+2x70	1.7	1.1	2.7	58.9	10170	4795	0.0754/0.268	0.125/0.44
3x240+2x95	1.7	1.1	2.8	60.4	10741	5037	0.0754/0.193	0.125/0.32
3x240+2x120	1.7	1.2	2.9	62.1	11302	5290	0.0754/0.153	0.125/0.25
3x240+2x150	1.7	1.4	2.9	63.9	11921	5561	0.0754/0.124	0.125/0.20
3x240+2x185	1.7	1.6	3.0	66.0	12737	5916	0.0601/0.193	0.100/0.32
8x300+2x120	1.8	1.2	3.0	66.7	13249	6085	0.0601/0.153	0.100/0.25
3x300+2x150	1.8	1.4	3.1	68.6	13897	6385	0.0601/0.124	0.100/0.20
3x300+2x185	1.8	1.6	3,1	70.3	14676	6703	0.0601/0.0991	0.100/0.16
3x300+2x240	1.8	1.7	3.2	72.9	15898	7203	0.0601/0.0754	0.100/0.12
3x400+2x120	2.0	1.2	3.2	73.2	15977	7230	0.0470/0.153	0.0778/0.2
3x400+2x150	2.0	1.4	3.2	74.6	16578	7484	0.0470/0.124	0.0778/0.2
3x400+2x185	2.0	1.6	3.3	76.4	17391	7835	0.0470/0.0991	0.0778/0.1
3x400+2x240	2.0	1.7	3.4	79.1	18637	8360	0.0470/0.0754	0.0778/0.1
3x500+2x150	2.2	1.4	3.4	81.4	20051	8894	0.0366/0.124	0.0605/0.2
8x500+2x185	2.2	1.6	3.5	83.1	20867	9249	0.0366/0.0991	0.0605/0.1
3x500+2x240	2.2	1.7	3.6	86.7	22949	10609	0.0366/0.0754	0.0605/0.1
3x500+2x300	2.2	1.8	3.7	89.0	24265	11157	0.0366/0.0601	0.0605/0.1
4x4+1x1.5	0.7	0.7	1.8	15.7	429	319	0.387/12.1	
								7.41/18.1
4x4+1x2.5	0.7	0.7	1.8	15.9	442	327	0.387/7.41	7.41/7.4
4x6+1x2.5	0.7	0.7	1.8	17.0	544	377	3.08/7.41	4.61/7.41
4x6+1x4	0.7	0.7	1.8	17.2	562	386	3.08/0.387	4.61/4.61
4x10+1x4	0.7	0.7	1.8	20.1	782	505	1.83/0.387	3.08/4.6
4x10+1x6	0.7	0.7	1.8	20.3	806	516	1.83/3.08	3.08/3.08
4x16+1x6	0.7	0.7	1.8	22.6	1081	641	1.15/3.08	1.91/3.08
4x16+1x10	0.7	0.7	1.8	23.2	1134	669	1.15/1.83	1.91/1.9
4x25+1x6	0.9	0.7	1.8	26.3	1526	855	0.727/3.08	1.20/3.08
4x25+1x10	0.9	0.7	1.8	26.9	1580	885	0.727/1.83	1.20/1.91
4x25+1x16	0.9	0.7	1.8	27.4	1648	916	0.727/1.15	1.20/1.91
4x35+1x10	0.9	0.7	1.8	28.3	1955	1026	0.524/1.83	0.868/1.9
4x35+1x16	0.9	0.7	1.8	28.7	2020	1054	0.524/1.15	0.868/1.9
4x35+1x25	0.9	0.9	1.8	29.6	2132	1110	0.524/0.727	0.868/1.2
4x50+1x16	1.0	0.7	1.9	32.3	2584	1312	0.387/1.15	0.641/1.9
4x50+1x25	1.0	0.9	2.0	33.3	2709	1380	0.387/0.727	0.641/1.2
4x50+1x35	1.0	0.9	2.0	33.6	2801	1415	0.387/0.524	0.641/0.86
4x70+1x16	1.1	0.7	2.0	36.2	3477	1680	0.268/1.15	0.443/1.9
4x70+1x25	1.1	0.9	2.1	37.3	3612	1758	0.268/0.727	0.443/1.2
4x70+1x35	1.1	0.9	2.1	38.7	4067	2156	0.268/0.524	0.443/0.86
4x70+1x50	1.1	1.0	2.2	39.6	4227	2240	0.268/0.387	0.443/0.64
4x95+1x35	1.1	0.9	2.3	42.9	5219	2648	0.193/0.524	0.320/0.86
4x95+1x50	1.1	1.0	2.3	43.6	5364	2718	0.193/0.387	0.320/0.64
4x95+1x70	1.1	1.1	2.3	44.4	5590	2815	0.193/0.268	0.320/0.44
	1.2	1.0	2.4	47.6	6460	3198	0.153/0.200	0.253/0.64
	1.2	1.0						
4x120+1x50		4.4						
4x120+1x50 4x120+1x70	1.2	1.1	2.4	48.3	6683	3291	0.153/0.268	
4x120+1x50		1.1 1.1	2.4 2.5	48.3 49.5	6989	3435	0.153/0.268	0.253/0.44 0.253/0.32





CU(AL)/XLPE/PVC/STA/PVC 0.6/1(1.2) kV
Conductor: Copper/Aluminum
Insulation: XLPE
Bedding: PVC
Armour: Double Layer Galvanized Steel Tape

Sheath: PVC

Section	Insulation Thickness mm		Sheath Thickness mm	Overall Diameter	Cable Weight		DC. Electrical Resistance at 20°C	
No.xmm²					Cu	Al	Cu	Al
				mm	kg/km		Ω/km	
4x150+1x95	1.4	1.1	2.6	53.8	8246	3996	0.124/0.193	0.206/0.320
4x150+1x120	1.4	1.2	2.6	54.7	8515	4114	0.124/0.153	0.206/0.253
4x185+1x70	1.6	1.1	2.7	57.6	9580	4571	0.0991/0.268	0.164/0.443
4x185+1x95	1.6	1.1	2.8	58.6	9884	4713	0.0991/0.193	0.164/0.320
4x185+1x120	1.6	1.2	2.8	59.4	10150	4827	0.0991/0.153	0.164/0.253
4x185+1x150	1.6	1.4	2.8	60.4	10460	4966	0.0991/0.124	0.164/0.206
4x240+1x70	1.7	1.1	2.9	63.4	12011	5559	0.0754/0.268	0.125/0.443
4x240+1x95	1.7	1.1	2.9	64.3	12302	5687	0.0754/0.193	0.125/0.320
4x240+1x120	1.7	1.2	3.0	65.4	12608	5841	0.0754/0.153	0.125/0.253
4x240+1x150	1.7	1.4	3.0	66.3	12915	5978	0.0754/0.124	0.125/0.206
4x240+1x185	1.7	1.6	3.0	67.4	13318	6153	0.0601/0.193	0.100/0.320
4x300+1x120	1.8	1.2	3.1	70.7	15153	6951	0.0601/0.153	0.100/0.253
4x300+1x150	1.8	1.4	3.2	71.9	15504	7031	0.0601/0.124	0.100/0.206
4x300+1x185	1.8	1.6	3.2	72.9	15903	7203	0.0601/0.0991	0.100/0.164
4x300+1x240	1.8	1.7	3.3	74.3	16525	7469	0.0601/0.0754	0.100/0.125
4x400+1x120	2.0	1.2	3.4	78.8	18786	8373	0.0470/0.153	0.0778/0.253
4x400+1x150	2.0	1.4	3.4	79.6	19095	8511	0.0470/0.124	0.0778/0.206
4x400+1x185	2.0	1.6	3.5	80.7	19527	8716	0.0470/0.0991	0.0778/0.164
4x400+1x240	2.0	1.7	3.5	82.0	20134	8968	0.0470/0.0754	0.0778/0.125
4x500+1x150	2.2	1.4	3.7	89.0	24571	11236	0.0366/0.124	0.0605/0.206
4x500+1x185	2.2	1.6	3.7	90.0	24994	11433	0.0366/0.0991	0.0605/0.164
4x500+1x240	2.2	1.7	3.8	91.4	25653	11736	0.0366/0.0754	0.0605/0.125
4x500+1x300	2.2	1.8	3.8	92.3	26271	11976	0.0366/0.0601	0.0605/0.100





CU(AL)/XLPE/PVC/AWA/PVC 0.6/1(1.2) kV

Standards

AS/NZS 5000.1

DIN VDE 0276-603

• IEC 60502-1

HD 603

Application

The cable is used for electricity supply in low voltage installation system, suitable for installation in indoors and outdoors, in cable ducts, underground, in power and switching stations, local energy distributions, industrial plants, where there is no risk of mechanical damage.

AS/NZS 5000.1

• Conductor: Copper/Aluminum

Insulation: XLPEBedding: PVC

Armour: Aluminum WireSheath: PVC/PE(Optional)

(Optional) Flame Retardant Property

(Optional) Fire Resistant Property

(Optional) Anti-Termite & Rodent Property

(Optional) Water Resistant Property



Section	Insulation Thickness	Sheath Thickness	Overall Diameter	Cable	Weight	DC. Electrical Resistance at 20°C	
N12				Cu	Al	Cu	Al
No.xmm ²	mm	mm	mm	kg	/km	Ω/km	
1x10	0.7	1.8	13.7	277	215	1.83	3.08
1x16	0.7	1.8	14.7	352	252	1.15	1.91
1x25	0.9	1.8	16.4	454	304	0.727	1.20
1x35	0.9	1.8	17.0	562	352	0.524	0.868
1x50	1.0	1.8	19.4	774	485	0.387	0.641
1x70	1.1	1.8	21.1	1010	590	0.268	0.443
1x95	1.1	1.8	22.8	1275	700	0.193	0.320
1x120	1.2	1.8	25.2	1592	867	0.153	0.253
1x150	1.4	1.8	27.1	1929	1017	0.124	0.206
1x185	1.6	1.8	29.1	2289	1170	0.0991	0.164
1x240	1.7	1.9	31.8	2886	1421	0.0754	0.125
1x300	1.8	1.9	34.2	3475	1657	0.0601	0.100
1x400	2.0	2.1	38.7	4588	2200	0.0470	0.0778
1x500	2.2	2.2	42.3	5699	2652	0.0366	0.0605
1x630	2.4	2.3	46.4	7073	3141	0.0283	0.0469
1x800	2.6	2.5	52.6	9039	4025	0.0221	0.0367





CU(AL)/XLPE/PVC/SWA/PVC 0.6/1(1.2) kV

Standards

• AS/NZS 5000.1 • DIN VDE 0276-603

IEC 60502-1

HD 603

Application

The cable is used for electricity supply in low voltage installation system, suitable for installation in indoors and outdoors, in cable ducts, under ground, in power and switching stations, local energy distributions, industrial plants, where there is no risk of mechanical damage.

IEC 60502-1

• Conductor: Copper/Aluminum

Insulation: XLPEBedding: PVC

Armour: Galvanized Steel WireSheath: PVC/PE(Optional)

(Optional) Flame Retardant Property(Optional) Fire Resistant Property

• (Optional) Anti-Termite & Rodent Property

• (Optional) Water Resistant Property



Section	Insulation Thickness	Sheath Thickness	Overall Diameter		Weight	DC. Electrical Resistance at 20°C		
No.xmm ²	mm	mm	mm	Cu	Al /km	Cu	Al km	
2x4	0.7	1.8	16.8	447	397	4.61	7.41	
2x4 2x6	0.7	1.8	17.8	520	444	3.08	4.61	
2x10	0.7	1.8	21.3	835	708	1.83	3.08	
2x16	0.7	1.8	23.3	1024	823	1.15	1.91	
2x25	0.9	1.8	27.4	1512	1195	0.727	1.20	
2x35	0.9	1.8	28.6	1740	1307	0.524	0.868	
2x50	1.0	1.8	31.6	2136	1550	0.387	0.641	
2x70	1.1	2.0	35.4	2735	1886	0.268	0.443	
2x95	1.1	2.1	39.8	3697	2518	0.193	0.320	
2x120	1.2	2.2	43.4	4396	2909	0.153	0.253	
2x150	1.4	2.3	47.4	5208	3374	0.124	0.206	
2x185	1.6	2.5	53.2	6747	4451	0.0991	0.164	
2x240	1.7	2.7	58.6	8278	5261	0.0754	0.104	
2x300	1.8	2.8	64.0	9912	6127	0.0601	0.123	
2x400	2.0	3.1	71.2	12168	7328	0.0470	0.0778	
2x500	2.2	3.3	80.1	15893	9678	0.0366	0.0605	
3x4	0.7	1.8	17.4	505	430	4.61	7.41	
3x6	0.7	1.8	18.5	598	485	3.08	4.61	
3x10	0.7	1.8	22.2	966	776	1.83	3.08	
3x16	0.7	1.8	24.3	1220	918	1.15	1.91	
3x25	0.9	1.8	28.7	1803	1328	0.727	1.20	
3x35	0.9	1.8	30.0	2133	1483	0.524	0.868	
3x50	1.0	1.9	33.4	2658	1779	0.324	0.641	
3x70	1.1	2.0	38.1	3716	2442	0.268	0.443	
3x95	1.1	2.2	42.2	4692	2924	0.193	0.320	
3x120	1.2	2.3	46.1	5649	3418	0.153	0.320	
3x150	1.4	2.5	52.0	7239	4487	0.124	0.206	
3x185	1.6	2.6	56.5	8634	5191	0.0991	0.164	
3x240	1.7	2.8	62.7	10790	6265	0.0754	0.104	
3x300	1.8	3.0	68.3	13016	7338	0.0601	0.100	
3x400	2.0	3.2	75.8	16028	8768	0.0470	0.0778	
3x500	2.2	3.5	85.4	20926	11603	0.0366	0.0605	
4x4	0.7	1.8	18.4	580	480	4.61	7.41	
4x6	0.7	1.8	20.5	839	688	3.08	4.61	
4x10	0.7	1.8	23.6	1119	866	1.83	3.08	
4x16	0.7	1.8	26.7	1599	1196	1.15	1.91	
4x25	0.9	1.8	30.8	2151	1518	0.727	1.20	
4x35	0.9	1.9	32.5	2584	1718	0.524	0.868	
4x50	1.0	2.0	36.3	3254	2081	0.387	0.641	
4x70	1.1	2.2	41.6	4558	2860	0.268	0.443	
4x95	1.1	2.3	46.0	5827	3469	0.193	0.320	
4x120	1.2	2.5	51.9	7540	4566	0.153	0.253	
4x150	1.4	2.6	56.7	8993	5324	0.124	0.206	
4x185	1.6	2.8	62.3	10871	6281	0.0991	0.164	
4x240	1.7	3.0	68.8	13552	7519	0.0754	0.125	
4x300	1.8	3.2	75.0	16379	8809	0.0601	0.123	
4x400	2.0	3.5	85.3	21416	11736	0.0470	0.0778	
4x500	2.2	3.8	94.1	26417	13986	0.0366	0.0605	
5x4	0.7	1.8	20.3	791	666	4.61	7.41	
5x6	0.7	1.8	21.6	940	751	3.08	4.61	
5x10	0.7	1.8	25.2	1290	973	1.83	3.08	
5x16	0.7	1.8	28.6	1841	1338	1.15	1.91	





CU(AL)/XLPE/PVC/SWA/PVC 0.6/1(1.2) kV Conductor: Copper/Aluminum Insulation: XLPE Bedding: PVC Armour: Galvanized Steel Wire Sheath: PVC

Section	Insulation Thickness		Sheath Thickness	Overall Diameter	Cable Weight		DC. Electrical Resistance at 20°C	
No.xmm ²	m	ım	mm	mm	Cu kg	'km	Cu Ω/I	Al cm
5x25	0.	.9	1.8	33.1	2525	1733	0.727	1.20
5x35	0.	.9	1.9	35.0	3050	1967	0.524	0.868
5x50	1.	.0	2.1	40.2	4151	2685	0.387	0.641
5x70	1.	.1	2.3	45.2	5457	3335	0.268	0.443
5x95	1.	.1	2.5	51.6	7496	4550	0.193	0.320
5x120	1.	.2	2.6	56.4	9002	5285	0.153	0.253
5x150	1.	.4	2.8	62.3	10859	6273	0.124	0.206
5x185	1.	.6	3.0	68.1	13077	7339	0.0991	0.164
5x240	1.	.7	3.2	75.3	16378	8835	0.0754	0.125
5x300	1.	.8	3.4	83.9	20884	11421	0.0601	0.100
5x400	2	.0	3.8	93.6	25926	13826	0.0470	0.0778
5x500	2.	.2	4.1	103.8	32247	16709	0.0366	0.0605
2x4+1x1.5	0.7	0.7	1.8	16.8	463	403	0.387/12.1	7.41/18.1
2x4+1x2.5	0.7	0.7	1.8	17.0	480	414	0.387/7.41	7.41/12.1
2x6+1x2.5	0.7	0.7	1.8	17.8	544	453	3.08/7.41	4.61/12.1
2x6+1x4	0.7	0.7	1.8	18.1	567	467	3.08/0.387	4.61/7.41
2x10+1x4	0.7	0.7	1.8	21.3	872	721	1.83/0.387	3.08/7.41
2x10+1x6	0.7	0.7	1.8	21.4	892	728	1.83/3.08	3.08/4.61
2x16+1x6	0.7	0.7	1.8	23.3	1079	840	1.15/3.08	1.91/4.61
2x16+1x10	0.7	0.7	1.8	23.6	1130	866	1.15/1.83	1.91/3.08
2x25+1x6 2x25+1x10	0.9	0.7	1.8	27.4 26.7	1446	1092 1072	0.727/3.08	1.20/4.61
2x25+1x10 2x25+1x16	0.9	0.7 0.7	1.8 1.8		1451	1241	0.727/1.83	1.20/3.08
				27.6	1657		0.727/1.15	1.20/1.91
2x35+1x10	0.9	0.7	1.8	28.6	1829	1334	0.524/1.83	0.868/3.08
2x35+1x16	0.9	0.7	1.8	28.7	1882	1350	0.524/1.15	0.868/1.91
2x35+1x25	0.9	0.9	1.8	29.5	2017	1428	0.524/0.727	0.868/1.20
2x50+1x16	1.0	0.7	1.8	31.6	2275	1590	0.387/1.15	0.641/1.91
2x50+1x25	1.0	0.9	1.8	31.9	2364	1622	0.387/0.727	0.641/1.20
2x50+1x35	1.0	0.9	1.9	32.4	2483	1684	0.387/0.524	0.641/0.868
2x70+1x16	1.1	0.7	1.9	35.8	2895	1947	0.268/1.15	0.443/1.91
2x70+1x25	1,1	0.9	1.9	35.2	2939	1934	0.268/0.727	0.443/1.20
2x70+1x35	1.1	0.9	1.9	35.2	3019	1957	0.268/0.524	0.443/0.868
2x70+1x50	1.1	1.0	2.0	36.1	3194	2057	0.268/0.387	0.443/0.641
2x95+1x35	1,1	0.9	2.0	39.6	3979	2587	0.193/0.524	0.320/0.868
2x95+1x50	1.1	1.0	2.1	39.9	4104	2636	0.193/0.387	0.320/0.641
2x95+1x70	1.1	1.1	2.1	40.8	4367	2770	0.193/0.268	0.320/0.443
2x120+1x50	1.2	1.0	2.2	43.4	4799	3023	0.153/0.387	0.253/0.641
2x120+1x70	1.2	1.1	2.2	43.7	5015	3110	0.153/0.268	0.253/0.443
2x120+1x95	1.2	1.1	2.2	44.6	5299	3232	0.153/0.193	0.253/0.320
2x150+1x50	1.4	1.0	2.3	47.6	5620	3497	0.124/0.387	0.206/0.641
2x150+1x70	1.4	1.1	2.3	47.4	5790	3538	0.124/0.268	0.206/0.443
2x150+1x95	1.4	1.1	2.3	47.9	6060	3645	0.124/0.193	0.206/0.320
2x150+1x120	1.4	1.2	2.4	50.4	6854	4287	0.124/0.153	0.206/0.253
2x185+1x70	1.6	1.1	2.4	53.0	7306	4592	0.0991/0.268	0.164/0.443
2x185+1x95	1.6	1.1	2.5	53.2	7551	4675	0.0991/0.193	0.164/0.320
2x185+1x120	1.6	1.2	2.5	53.8	7788	4760	0.0991/0.153	0.164/0.253
2x185+1x150	1.6	1.4	2.6	54.9	8133	4932	0.0991/0.124	0.164/0.206
2x240+1x70	1.7	1.1	2.5	59.1	8896	5461	0.0754/0.268	0.125/0.443
2x240+1x95	1.7	1.1	2.6	58.4	9057	5459	0.0754/0.193	0.125/0.320
2x240+1x120	1.7	1.2	2.6	58.4	9265	5516		
							0.0754/0.153	0.125/0.253
2x240+1x150	1.7	1.4	2.7	59.3	9565	5644	0.0754/0.124	0.125/0.206
2x300+1x95	1.8	1.1	2.7	64.1	10678	6312	0.0601/0.193	0.100/0.320
2x300+1x120	1.8	1.2	2.8	63.6	10834	6317	0.0601/0.153	0.100/0.253
2x300+1x150	1.8	1.4	2.8	64.0	11162	6473	0.0601/0.124	0.100/0.206
2x300+1x185	1.8	1.6	2.8	64.7	11558	6642	0.0601/0.0991	0.100/0.164
2x300+1x240	1.8	1.7	2.9	66.1	12185	6914	0.0601/0.0754	0.100/0.125
2x400+1x120	2.0	1.2	2.9	71.6	13210	7638	0.0470/0.153	0.0778/0.253
2x400+1x150	2.0	1.4	3.0	71.0	13387	7644	0.0470/0.124	0.0778/0.206
2x400+1x185	2.0	1.6	3.0	71.0	13703	7732	0.0470/0.0991	0.0778/0.164
2x400+1x240	2.0	1.7	3.1	72.0	14313	7987	0.0470/0.0754	0.0778/0.125
2x500+1x150	2.2	1.4	3.1	78.9	16189	9070	0.0366/0.124	0.0605/0.206
2x500+1x185	2.2	1.6	3.2	78.2	16435	9089	0.0366/0.0991	0.0605/0.164
2x500+1x240	2.2	1.7	3.2	78.2	16923	9221	0.0366/0.0754	0.0605/0.125
2x500+1x300	2.2	1.8	3.3	80.7	18571	10491	0.0366/0.0601	0.0605/0.100
3x4+1x1.5	0.7	0.7	1.8	17.8	537	453	0.387/12.1	7.41/18.1
3x4+1x2.5	0.7	0.7	1.8	18.0	550	459	0.387/7.41	7.41/12.1
3x6+1x2.5	0.7	0.7	1.8	19.9	775	646	3.08/7.41	4.61/12.1
3x6+1x4	0.7	0.7	1.8	20.1	802	664	3.08/0.387	4.61/7.41
3x10+1x4	0.7	0.7	1.8	22.6	1022	808	1.83/0.387	3.08/7.41
3x10+1x6	0.7	0.7	1.8	22.8	1045	818	1.83/3.08	3.08/4.61
3x16+1x6	0.7	0.7	1.8	24.7	1295	956	1.15/3.08	1.91/4.61
3x16+1x10	0.7	0.7	1.8	25.4	1357	992	1.15/1.83	1.91/3.08
3x25+1x6	0.9	0.7	1.8	28.7	1858	1345	0.727/3.08	1.20/4.61
3x25+1x10	0.9	0.7	1.8	29.3	1941	1404	0.727/1.83	1.20/3.08
3x25+1x16	0.9	0.7	1.8	29.8	2022	1448	0.727/1.15	1.20/1.91





CU(AL)/XLPE/PVC/SWA/PVC 0.6/1(1.2) kV Conductor: Copper/Aluminum Insulation: XLPE Bedding: PVC Armour: Galvanized Steel Wire Sheath: PVC

Section	Insulation	Thickness	Sheath Thickness	Overall Diameter		e Weight		sistance at 20°C
No.xmm²	m	ım	mm	mm	Cu	g/km	Cu Ω/	Al km
3x35+1x10	0.9	0.7	1.8	30.4	2249	1537	0.524/1.83	0.868/3.08
3x35+1x16	0.9	0.7	1.8	30.9	2331	1582	0.524/1.15	0.868/1.91
3x35+1x25	0.9	0.7	1.8	31.9	2457	1651	0.524/0.727	0.868/1.20
3x50+1x16	1.0	0.7	1.9	33.1	2772	1793	0.387/1.15	0.641/1.91
3x50+1x16	1.0	0.7	1.9	34.0	2833	1854	0.387/1.15	0.641/1.91
3x50+1x25	1.0	0.9	1.9	33.1	2852	1816	0.387/0.727	0.641/1.20
3x50+1x25	1.0	0.9	1.9	34.8	2971	1936	0.387/0.727	0.641/1.20
3x50+1x35	1.0	0.9	2.0	33.3	2946	1853	0.387/0.524	0.641/0.86
3x50+1x35	1.0	0.9	2.0	35.4	3080	1987	0.387/0.524	0.641/0.86
3x70+1x16	1.1	0.7	2.0	38.4	3858	2486	0.268/1.15	0.443/1.91
3x70+1x16	1.1	0.7	2.0	38.2	3859	2486	0.268/1.15	0.443/1.91
3x70+1x25	1.1	0.9	2.1	38.6	3954	2525	0.268/0.727	0.443/1.20
	1.1	0.9	2.1	39.3	4013	2583		
3x70+1x25							0.268/0.727	0.443/1.20
3x70+1x35	1.1	0.9	2.1	38.6	4034	2548	0.268/0.524	0.443/0.86
3x70+1x35	1.1	0.9	2.1	39.5	4125	2639	0.268/0.524	0.443/0.86
3x70+1x50	1.1	1.0	2.1	38.6	4138	2576	0.268/0.387	0.443/0.64
3x70+1x50	1.1	1.0	2.1	40.4	4288	2726	0.268/0.387	0.443/0.64
3x95+1x35	1,1	0.9	2.2	43.0	5056	3075	0.193/0.524	0.320/0.86
3x95+1x35	1.1	0.9	2.2	43.0	5073	3092	0.193/0.524	0.320/0.86
3x95+1x50	1.1	1.0	2.2	43.0	5160	3103	0.193/0.387	0.320/0.64
3x95+1x50	1.1	1.0	2.2	43.7	5230	3174	0.193/0.387	0.320/0.64
3x95+1x70	1.1	1.1	2.3	43.2	5357	3171	0.193/0.268	0.320/0.44
3x95+1x70	1.1	1.1	2.3	44.9	5495	3309	0.193/0.268	0.320/0.44
3x120+1x50	1.2	1.0	2.3	46.8	6086	3567	0.153/0.387	0.253/0.64
3x120+1x50	1.2	1.0	2.3	47.1	6120	3604	0.153/0.387	0.253/0.64
3x120+1x70	1.2	1.1	2.4	47.0	6285	3637	0.153/0.268	0.253/0.44
3x120+1x70	1.2	1.1	2.4	48.3	6414	3766	0.153/0.268	0.253/0.44
3x120+1x95	1.2	1.1	2.4	48.4	6962	4151	0.153/0.193	0.253/0.32
3x120+1x95	1.2	1.1	2.4	50.4	7193	4382	0.153/0.193	0.253/0.32
3x150+1x50	1.4	1.0	2.5	52.3	7677	4637	0.124/0.387	0.206/0.64
3x150+1x50	1.4	1.0	2.5	52.7	7715	4674	0.124/0.387	0.206/0.64
3x150+1x70	1.4	1.1	2.5	52.3	7856	4686	0.124/0.268	0.206/0.44
3x150+1x70	1.4	1.1	2.5	53.4	7967	4798	0.124/0.268	0.206/0.44
3x150+1x95	1.4	1.1	2.5	52.3	8078	4746	0.124/0.193	0.206/0.32
3x150+1x95	1.4	1.1	2.5	54.2	8268	4936	0.124/0.193	0.206/0.32
3x150+1x120	1.4	1.2	2.6	52.5	8309	4825	0.124/0.153	0.206/0.25
3x150+1x120	1.4	1.2	2.6	55.5	8595	5110	0.124/0.153	0.206/0.25
3x185+1x70	1.6	1.1	2.6	58.3	9384	5522	0.0991/0.268	0.164/0.44
3x185+1x70	1.6	1.1	2.6	57.5	9347	5486	0.0991/0.268	0.164/0.44
	1.6	1.1	2.7	58.5	9631	5607	0.0991/0.193	
3x185+1x95								0.164/0.32
3x185+1x95	1.6	1.1	2.7	58.4	9631	5607	0.0991/0.193	0.164/0.32
3x185+1x120	1.6	1,2	2.7	58.5	9839	5664	0.0991/0.153	0.164/0.25
3x185+1x120	1.6	1.2	2.7	59.4	9972	5797	0.0991/0.153	0.164/0.25
3x185+1x150	1.6	1.4	2.7	58.5	10077	5730	0.0991/0.124	0.164/0.20
3x185+1x150	1.6	1.4	2.7	60.4	10303	5956	0.0991/0.124	0.164/0.20
3x240+1x70	1.7	1.1	2.8	64.4	11496	6553	0.0754/0.268	0.125/0.44
3x240+1x70	1.7	1.1	2.8	63.1	11435	6491	0.0754/0.268	0.125/0.44
3x240+1x95	1.7	1.1	2.8	64.4	11718	6612	0.0754/0.193	0.125/0.32
3x240+1x95	1.7	1.1	2.8	63.8	11737	6631	0.0754/0.193	0.125/0.32
3x240+1x120	1.7	1.2	2.9	64.6	11954	6697	0.0754/0.153	0.125/0.25
3x240+1x120	1.7	1.2	2.9	64.9	12066	6808	0.0754/0.153	0.125/0.25
3x240+1x150	1.7	1.4	2.9	64.6	12191	6762	0.0754/0.124	0.125/0.20
3x240+1x150	1.7	1.4	2.9	65.7	12390	6961	0.0754/0.124	0.125/0.20
3x300+1x95	1.8	1.1	3.0	68.8	13851	7593	0.0601/0.268	0.100/0.32
3x300+1x120	1.8	1.2	3.0	69.7	14155	7746	0.0601/0.153	0.100/0.25
3x300+1x150	1.8	1.4	3.0	70.5	14483	7902	0.0601/0.124	0.100/0.20
3x300+1x185	1.8	1.6	3.1	71.9	14986	8178	0.0601/0.0991	0.100/0.16
3x300+1x240	1.8	1.7	3.1	73.1	15592	8429	0.0601/0.0754	0.100/0.12
3x400+1x120	2.0	1.2	3.2	76.4	17121	9129	0.0470/0.153	0.0778/0.25
3x400+1x150	2.0	1.4	3.3	77.4	17487	9324	0.0470/0.124	0.0778/0.20
3x400+1x185	2.0	1.6	3.3	80.2	18909	10519	0.0470/0.0991	0.0778/0.16
3x400+1x240	2.0	1.7	3.4	81.5	19575	10829	0.0470/0.0754	0.0778/0.12
3x500+1x150	2.2	1.4	3.5	86.1	22229	12003	0.0366/0.124	0.0778/0.20
3x500+1x185	2.2	1.6	3.5	87.0	22677	12224	0.0366/0.0991	0.0778/0.16
3x500+1x240	2.2	1.7	3.6	88.4	23360	12551	0.0366/0.0754	0.0778/0.12
3x500+1x300	2.2	1.8	3.6	89.7	24108	12921	0.0366/0.0601	0.0778/0.10
							0.387/12.1	
3x4+2x1.5	0.7	0.7	1.8	18.5	576	482		7.41/18.1
3x4+2x2.5	0.7	0.7	1.8	19.8	744	637	0.387/7.41	7.41/12.1
3x6+2x2.5	0.7	0.7	1.8	20.6	835	690	3.08/7.41	4.61/12.1
3x6+2x4	0.7	0.7	1.8	21.1	882	719	3.08/0.387	4.61/7.41
3x10+2x4	0.7	0.7	1.8	23.4	1100	860	1.83/0.387	3.08/7.41





CU(AL)/XLPE/PVC/SWA/PVC 0.6/1(1.2) kV Conductor: Copper/Aluminum Insulation: XLPE Bedding: PVC Armour: Galvanized Steel Wire Sheath: PVC

Section	Insulation	Thickness	Sheath Thickness	Overall Diameter		Weight	DC. Electrical Re	
No.xmm²	m	ım	mm	mm	Cu	/km	Cu Ω/	AI km
3x16+2x6	0.7	0.7	1.8	25.6	1394	1017	1,15/3,08	1.91/4.61
3x16+2x10	0.7	0.7	1.8	27.5	1675	1247	1.15/1.83	1.91/3.08
3x25+2x6	0.9	0.7	1.8	29.5	1970	1419	0.727/3.08	1.20/3.08
3x25+2x10	0.9	0.7	1.8	30.5	2100	1499	0.727/1.83	
								1.20/1.91
3x25+2x16	0.9	0.7	1.8	31.4	2262	1586	0.727/1.15	1.20/1.91
3x35+2x10	0.9	0.7	1.8	31.6	2410	1633	0.524/1.83	0.868/1.91
3x35+2x16	0.9	0.7	1.8	32.5	2572	1721	0.524/1.15	0.868/1.91
3x35+2x25	0.9	0.9	1.9	34.3	2848	1882	0.524/0.727	0.868/1.20
3x50+2x16	1.0	0.7	1.9	35.3	3052	1972	0.387/1.15	0.641/1.91
3x50+2x25	1.0	0.9	2.0	37.0	3330	2134	0.387/0.727	0.641/1.20
3x50+2x35	1.0	0.9	2.1	38.7	3809	2496	0.387/0.524	0.641/0.868
3x70+2x16	1.1	0.7	2.1	39.8	4121	2646	0.268/1.15	0.443/1.91
3x70+2x25	1.1	0.9	2.1	41.1	4382	2792	0.268/0.727	0.443/1.20
3x70+2x35	1.1	0.9	2.1	41.6	4589	2883	0.268/0.524	0.443/0.868
3x70+2x50	1.1	1.0	2.2	43.2	4924	3065	0.268/0.387	0.443/0.641
3x95+2x35	1.1	0.9	2.2	44.8	5505	3304	0.193/0.524	0.320/0.868
3x95+2x50	1.1	1.0	2.3	46.4	5846	3491	0.193/0.387	0.320/0.641
3x95+2x70	1.1	1.1	2.4	48.2	6376	3759	0.193/0.268	0.320/0.443
3x120+2x50	1.2	1.1	2.4	51.1	7240	4424	0.153/0.387	0.253/0.641
3x120+2x70	1.2	1.1	2.5	52.6	7767	4688	0.153/0.268	0.253/0.443
3x120+2x95	1.2	1.1	2.5	54.3	8380	4971	0.153/0.193	0.253/0.320
3x150+2x50	1.4	1.1	2.5	54.7	8308	4970	0.124/0.387	0.206/0.641
3x150+2x70	1.4	1.1	2.6	56.3	8846	5245	0.124/0.268	0.206/0.443
3x150+2x95	1.4	1.1	2.7	58.1	9484	5554	0.124/0.193	0.206/0.320
3x150+2x120	1.4	1.2	2.7	59.6	10067	5828	0.124/0.153	0.206/0.253
3x185+2x70	1.4		2.7	60.2				
		1.1			10226	5934	0.0991/0.268	0.164/0.443
3x185+2x95	1.6	1.1	2.8	62.1	10904	6282	0.0991/0.193	0.164/0.320
3x185+2x120	1.6	1.2	2.8	63.7	11498	6569	0.0991/0.153	0.164/0.253
3x185+2x150	1.6	1.4	2.9	65.8	12200	6922	0.0991/0.124	0.164/0.206
3x240+2x70	1.7	1,1	2.8	65.3	12244	6870	0.0754/0.268	0.125/0.443
3x240+2x95	1.7	1.1	2.9	66.8	12881	7177	0.0754/0.193	0.125/0.320
3x240+2x120	1.7	1.2	3.0	68.5	13505	7493	0.0754/0.153	0.125/0.253
3x240+2x150	1.7	1.4	3.0	70.3	14180	7821	0.0754/0.124	0.125/0.206
3x240+2x185	1.7	1.6	3.1	72.4	15055	8234	0.0601/0.193	0.100/0.320
	1.8	1.2	3.1	73.1		8433		
3x300+2x120	1.8				15598		0.0601/0.153	0.100/0.253
3x300+2x150		1.4	3.2	75.0	16305	8793	0.0601/0.124	0.100/0.206
3x300+2x185	1.8	1.6	3.2	76.7	17143	9170	0.0601/0.0991	0.100/0.164
3x300+2x240	1.8	1.7	3.4	81.2	19504	10810	0.0601/0.0754	0.100/0.125
3x400+2x120	2.0	1.2	3.3	81.3	19545	10798	0.0470/0.153	0.0778/0.25
3x400+2x150	2.0	1.4	3.4	82.9	20228	11134	0.0470/0.124	0.0778/0.20
3x400+2x185	2.0	1.6	3.5	84.7	21152	11597	0.0470/0.0991	0.0778/0.16
3x400+2x240	2.0	1.7	3.6	87.4	22500	12223	0.0470/0.0754	0.0778/0.12
3x500+2x150	2.2	1.4	3.6	89.7	24077	24203	0.0366/0.124	0.0605/0.20
3x500+2x185	2.2	1.6	3.6	91.2	24903	13284	0.0366/0.0991	0.0605/0.164
3x500+2x240	2.2	1.7	3.7	93.6	26241	13902	0.0366/0.0754	0.0605/0.12
3x500+2x240	2.2	1.8	3.8	95.9	27640	14532	0.0366/0.0601	0.0605/0.10
4x4+1x1.5	0.7	0.7	1.8	19.8	748	638	0.387/12.1	7.41/18.1
4x4+1x2.5	0.7	0.7	1.8	20.0	761	645	0.387/7.41	7,41/12.1
4x6+1x2.5	0.7	0.7	1.8	21.1	887	720	3.08/7.41	4.61/12.1
4x6+1x4	0.7	0.7	1.8	21.3	914	738	3.08/0.387	4.61/7.41
4x10+1x4	0.7	0.7	1.8	24.2	1191	914	1.83/0.387	3.08/7.41
4x10+1x6	0.7	0.7	1.8	24.4	1214	924	1.83/3.08	3.08/4.61
4x16+1x6	0.7	0.7	1.8	27.4	1689	1249	1.15/3.08	1.91/4.61
4x16+1x10	0.7	0.7	1.8	28.0	1755	1290	1.15/1.83	1.91/3.08
4x25+1x6	0.9	0.7	1.8	31.1	2231	1560	0.727/3.08	1.20/3.08
4x25+1x10				31.7	2299			
	0.9	0.7	1.8			1604	0.727/1.83	1.20/1.91
4x25+1x16	0.9	0.7	1.8	32.2	2381	1649	0.727/1.15	1.20/1.91
4x35+1x10	0.9	0.7	1.9	33.3	2731	1802	0.524/1.83	0.868/1.91
4x35+1x16	0.9	0.7	1.9	33.7	2794	1829	0.524/1.15	0.868/1.91
4x35+1x25	0.9	0.9	1.9	34.6	2935	1913	0.524/0.727	0.868/1.20
4x50+1x16	1.0	0.7	2.0	38.1	3719	2447	0.387/1.15	0.641/1.91
4x50+1x25	1.0	0.9	2.1	39.1	3869	2541	0.387/0.727	0.641/1.20
4x50+1x35	1.0	0.9	2.1	39.4	3960	2574	0.387/0.524	0.641/0.868
4x70+1x16	1.1	0.7	2.2	42.2	4746	2949	0.268/1.15	0.443/1.91
4x70+1x15	1.1		2.2	43.1				
		0.9			4912	3058	0.268/0.727	0.443/1.20
4x70+1x35	1.1	0.9	2.2	43.3	5000	3089	0.268/0.524	0.443/0.868
4x70+1x50	1.1	1.0	2.2	44.0	5157	3171	0.268/0.387	0.443/0.641
4x95+1x35	1,1	0.9	2.3	47.3	6232	3662	0.193/0.524	0.320/0.868
4x95+1x50	1.1	1.0	2.4	48.2	5413	3767	0.193/0.387	0.320/0.641
4x95+1x70	1.1	1.1	2.4	50.4	7153	4377	0.193/0.268	0.320/0.443
4x120+1x50	1.2	1.0	2.5	53.6	8104	4841	0.153/0.387	0.253/0.641
	1.2	1.1	2.5	54.3	8357	4965	0.153/0.268	0.253/0.443
4x120+1x70	1.1	***						
	12	1 1	26	55.5	8602	5128	0.153/0.102	0.253/0.220
4x120+1x70 4x120+1x95 4x150+1x50	1.2 1.4	1.1	2.6 2.7	55.5 58.1	8692 9523	5138 5565	0.153/0.193 0.124/0.387	0.253/0.320 0.206/0.641





CU(AL)/XLPE/PVC/SWA/PVC 0.6/1(1.2) kV Conductor: Copper/Aluminum Insulation: XLPE Bedding: PVC Armour: Galvanized Steel Wire

Section	Insulation	Thickness	Sheath Thickness	Overall Diameter	Cable	Weight	DC. Electrical Re	sistance at 20°C
No.xmm ²	mm		mm	mm	Cu	Al	Cu	Al
No.xmm	11	1111	HIRI	mm	kg	/km	Ω/km	
4x150+1x95	1.4	1.1	2.7	59.8	10094	5844	0.124/0.193	0.206/0.320
4x150+1x120	1.4	1.2	2.8	60.9	10417	6016	0.124/0.153	0.206/0.253
4x185+1x70	1.6	1.1	2.8	64.0	11631	6622	0.0991/0.268	0.164/0.443
4x185+1x95	1.6	1.1	2.9	65.0	11967	6796	0.0991/0.193	0.164/0.320
4x185+1x120	1.6	1.2	2.9	65.8	12263	6940	0.0991/0.153	0.164/0.253
4x185+1x150	1.6	1.4	2.9	66.8	12600	7106	0.0991/0.124	0.164/0.206
4x240+1x70	1.7	1.1	3.0	69.8	14237	7785	0.0754/0.268	0.125/0.443
4x240+1x95	1.7	1.1	3.0	70.7	14556	7942	0.0754/0.193	0.125/0.320
4x240+1x120	1.7	1.2	3.1	71.8	14933	8167	0.0754/0.153	0.125/0.253
4x240+1x150	1.7	1.4	3.1	72.7	15269	8331	0.0754/0.124	0.125/0.206
4x240+1x185	1.7	1.6	3.1	73.8	15697	8532	0.0601/0.193	0.100/0.320
4x300+1x120	1.8	1.2	3.2	77.1	17655	9352	0.0601/0.153	0.100/0.253
4x300+1x150	1.8	1.4	3.3	80.0	19024	10551	0.0601/0.124	0.100/0.206
4x300+1x185	1.8	1.6	3.4	81.2	19510	10809	0.0601/0.0991	0.100/0.164
4x300+1x240	1.8	1.7	3.4	82.4	20149	11093	0.0601/0.0754	0.100/0.125
4x400+1x120	2.0	1.2	3.6	87.1	22652	12240	0.0470/0.153	0.0778/0.253
4x400+1x150	2.0	1.4	3.6	87.9	23015	12431	0.0470/0.124	0.0778/0.206
4x400+1x185	2.0	1.6	3.6	88.8	23465	12654	0.0470/0.0991	0.0778/0.164
4x400+1x240	2.0	1.7	3.7	90.3	24158	12992	0.0470/0.0754	0.0778/0.125
4x500+1x150	2.2	1.4	3.8	95.9	27945	14611	0.0366/0.124	0.0605/0.206
4x500+1x185	2.2	1.6	3.8	96.9	28410	14848	0.0366/0.0991	0.0605/0.164
4x500+1x240	2.2	1.7	3.9	98.3	29107	15190	0.0366/0.0754	0.0605/0.125
4x500+1x300	2.2	1.8	3.9	99.2	29768	15473	0.0366/0.0601	0.0605/0.100





AA/XLPE/PVC 0.6/1(1.2) kV

Standards

• AS/NZS 5000.1

GB/T 31840

• IEC 60502-1

Application

The cable is of high conductivity, good creep resistant property, high flexibility, high elongation, low resilience and connective stability. The cable is used for buildings without flame, including office, airports, hospitals, hotels, shopping malls and feeder lines of lighting in factories as well as another electric appliance.

AS/NZS 5000.1

Conductor: Aluminum Alloy 8030

Insulation: XLPE

Sheath: PVC

(Optional) Flame Retardant Property

(Optional) Fire Resistant Property

• (Optional) Anti-Termite & Rodent Property

(Optional) Water Resistant Property



Section	Insulation Thickness	Sheath Thickness	Overall Diameter	Cable Weight AA 8030	DC. Electrical Resistance at 20°C AA 8030
No.xmm ²	mm	mm	mm	AA 8030 kg/km	AA 8030 Ω/km
1x10	0.7	1.4	8.3	81	3.08
1x16	0.7	1.4	9.3	106	1.91
1x25	0.9	1.4	10.9	148	1.21
1x35	0.9	1.4	11.9	185	0.868
1x50	1.0	1.4	13.4	244	0.641
1x70	1.1	1.4	15.2	315	0.443
1x95	1.1	1.5	16.8	403	0.320
1x120	1.2	1.5	18.5	495	0.253
1x150	1.4	1.6	20.4	606	0.206
1x185	1.6	1.7	22.9	746	0.164
1x240	1.7	1.8	25.6	942	0.125
1x300	1.8	1.8	27.8	1137	0.100
1x400	2.0	2.0	31.6	1492	0.0778
1x500	2.2	2.1	35.3	1844	0.0605
1x630	2.4	2.2	39.6	2292	0.0469
2x10	0.7	1.8	14.6	207	3.08
2x16	0.7	1.8	16.6	271	1.91
2x25	0.9	1.8	19.8	380	1.21
2x35	0.9	1.8	21.8	471	0.868
2x50	1.0	1.8	24.8	620	0.641
2x70	1.1	1.8	28.4	803	0.443
2x95	1.1	2.0	31.6	1014	0.320
2x120	1.2	2.1	35.2	1260	0.253
2x150	1.4	2.2	38.8	1535	0.206
2x185	1.6	2.3	43.6	1896	0.164
2x240	1.7	2.5	49.4	2440	0.125
2x300	1.8	2.7	54.1	2974	0.100
2x400	2.0	2.9	61.3	3856	0.0778
2x500	2.2	3.1	68.7	4789	0.0605
2x630	2.4	3.4	77.5	6012	0.0469
3x10	0.7	1.8	15.4	247	3.08
3x16	0.7	1.8	17.6	330	1.91
3x25	0.9	1.8	21.0	469	1.21
3x35	0.9	1.8	23.2	590	0.868
3x50	1.0	1.8	26.4	784	0.641
3x70	1.1	1.9	30.5	1036	0.443
3x95	1.1	2.0	33.7	1303	0.320
3x120	1.2	2.1	37.6	1626	0.253
3x150	1.4	2.3	41.6	2003	0.206
3x185	1.6	2.4	47.2	2505	0.164
3x240	1.7	2.6	52.9	3176	0.125
3x300	1.8	2.8	58.9	3878	0.100
3x400	2.0	3.1	65.9	5072	0.0778
3x500	2.2	3.3	73.9	6300	0.0605
	2.4	3.6		7860	0.0469
3x630	0.7		83.1	299	3.08
4x10		1.8	16.8		
4x16	0.7	1.8	19.2	402	1.91 1.21
4x25	0.9	1.8	23.1	580	
4x35	0.9	1.8	25.5	733	0.868
4x50	1.0	1.9	29.3	996	0.641
4x70	1.1	2.0	33.9	1304	0.443
4x95	1.1	2.1	37.4	1663	0.320
4x120	1.2	2.3	41.9	2091	0.253
4x150	1.4	2.4	46.6	2590	0.206
4x185	1.6	2.6	52.5	3216	0.164
4x240	1.7	2.8	58.9	4075	0.125





AA/XLPE/PVC 0.6/1(1.2) kV
Conductor: Aluminum Alloy 8030
Insulation: XLPE
Sheath: PVC

Section	Insulation Thi	ckness	Sheath Thickness	Overall Diameter	Cable Weight AA 8030	DC. Electrical Resistance at 2 AA 8030
No.xmm ²	mm		mm	mm	kg/km	Ω/km
4x300	1.8		3.0	64.6	4978	0.100
4x400	2.0		3.3	73.4	6514	0.0778
4x500	2.2		3.5	82.3	8088	0.0605
4x630	2.4		3.9	92.7	10133	0.0469
5x10	0.7		1.8	18.3	355	3.08
5x16	0.7		1.8	21.0	482	1.91
	0.9				698	1.21
5x25			1.8	25.3		
5x35	0.9		1.8	28.0	887	0.868
5x50	1.0		2.0	32.5	1212	0.641
5x70	1.1		2.1	37.5	1604	0.443
5x95	1.1		2.3	41.7	2069	0.320
5x120	1.2		2.4	46.9	2613	0.253
5x150	1.4		2.6	51.8	3216	0.206
5x185	1.6		2.8	58.4	3986	0.164
5x240	1.7		3.0	65.6	5054	0.125
5x300	1.8		3.2	71.9	6171	0.100
5x400	2.0		3.6	81.8	8106	0.0778
	2.2				10052	0.0605
5x500			3.8	91.6		
5x630	2.4		4.2	103.5	12634	0.0469
3x10+1x6	0.7	0.7	1.8	16.2	279	3.08/4.61
3x16+1x10	0.7	0.7	1.8	18.6	376	1.91/3.08
3x25+1x16	0.9	0.7	1.8	22.2	537	1.21/1.91
3x35+1x16	0.9	0.7	1.8	24.0	649	0.868/1.91
3x50+1x25	1.0	0.9	1.8	27.7	882	0.641/1.21
3x70+1x35	1.1	0.9	1.9	31.7	1159	0.443/0.868
3x95+1x50	1.1	1.0	2,1	35.6	1499	0.32/0.641
3x120+1x70	1.2	1.1	2.2	40.0	1889	0.253/0.443
3x150+1x70	1.4	1.1	2.3	43.2	2233	0.206/0.443
					2827	0.164/0.320
3x185+1x95	1.6	1.1	2.5	49.1		
3x240+1x120	1.7	1.2	2.7	54.9	3574	0.125/0.253
3x300+1x150	1.8	1.4	2.9	60.3	4372	0.100/0.206
3x400+1x185	2.0	1.6	3.1	68.3	5652	0.0778/0.164
3x500+1x240	2.2	1.7	3.4	76.6	7041	0.0605/0.125
3x600+1x300	2.4	1.8	3.7	85.8	8783	0.0469/0.100
3x10+2x6	0.7	0.7	1.8	17.3	316	3.08/3.08
3x16+2x10	0.7	0.7	1.8	20.1	434	1.91/1.91
3x25+2x16	0.9	0.7	1.8	23.8	616	1.21/1.91
3x35+2x16	0.9	0.7	1.8	25.5	728	0.868/1.91
3x50+2x25	1,0	0.9	1.9	29.9	1016	0.641/1.21
3x70+2x35	1.1	0.9	2.0	34.1	1317	0.443/0.868
		1.0	2.2	38.4	1732	0.320/0.641
3x95+2x50	1.1					0.253/0.443
3x120+2x70	1.2	1.1	2.3	43.4	2203	
3x150+2x70	1.4	1.1	2.4	46.8	2581	0.206/0.443
3x185+2x95	1.6	1.1	2.6	52.4	3227	0.164/0.320
3x240+2x120	1.7	1.2	2.8	58.7	4076	0.125/0.253
3x300+2x150	1.8	1.4	3.0	64.6	4993	0.100/0.206
3x400+2x185	2.0	1.6	3.3	73.3	6452	0.0778/0.164
3x500+2x240	2.2	1.7	3.5	82.1	8043	0.0605/0.125
3x630+2x300	2.4	1.8	3.8	91.5	9969	0.0469/0.100
4x10+1x6	0.7	0.7	1.8	17.9	337	3.08/3.08
4x16+1x10	0.7	0.7	1.8	20.7	461	1.91/1.91
4x25+1x16	0.9	0.7	1.8	24.7	661	1.21/1.91
				26.9	811	0.868/1.91
4x35+1x16	0.9	0.7	1.8		1117	
4x50+1x25	1.0	0.9	1.9	31.2		0.641/1.21
4x70+1x35	1.1	0.9	2.1	36.1	1474	0.443/0.868
4x95+1x50	1.1	1.0	2.2	40.2	1900	0.320/0.641
4x120+1x70	1.2	1.1	2.4	45.7	2443	0.253/0.443
4x150+1x70	1.4	1.1	2.5	49.6	2908	0.206/0.443
4x185+1x95	1.6	1.1	2.7	55.7	3620	0.164/0.320
4x240+1x120	1.7	1.2	2.9	62.5	4582	0.125/0.253
4x300+1x150	1.8	1.4	3.1	68.6	5600	0.100/0.206
4x400+1x185	2.0	1.6	3.4	77.9	7283	0.0778/0.164
	2.5					
4x500+1x240	2.2	1.7	3.7	87.2	9059	0.0605/0.125





AA/XLPE/PVC/SSTA/PVC 0.6/1(1.2) kV

Standards

- AS/NZS 5000.1
- GB/T 31840
- IEC 60502-1

Application

The cable is of high conductivity, good creep resistant property, high flexibility, high elongation, low resilience and connective stability. The cable is used for buildings without flame, including office, airports, hospitals, hotels, shopping malls and feeder lines of lighting in factories as well as another electric appliance.

AS/NZS 5000.1

• Conductor: Aluminum Alloy 8030

Insulation: XLPEBedding: PVC

Armour: Double Layer Stainless Steel Tape

Sheath: PVC/PE(Optional)

(Optional) Flame Retardant Property

(Optional) Fire Resistant Property

• (Optional) Anti-Termite & Rodent Property

(Optional) Water Resistant Property



Section	Insulation Thickness	Sheath Thickness	Overall Diameter	Cable Weight	DC. Electrical Resistance at 20°C
No.xmm ²	mm	mm	mm	AA 8030 kg/km	AA 8030 Ω/km
1x10	0.7	1.8	11.7	192	3.08
1x16	0.7	1.8	12.7	228	1.91
1x25	0.9	1.8	14.4	292	1.21
1x35	0.9	1.8	15.0	330	0.868
1x50	1.0	1.8	16.5	397	0.641
1x70	1.1	1.8	18.2	493	0.443
1x95	1.1	1.8	19.9	601	0.320
1x120	1.2	1.8	21.6	708	0.253
1x150	1.4	1.8	23.5	833	0.206
1x185	1.6	1.8	25.5	987	0.164
1x240	1.7	1.8	28.0	1206	0.125
1x300	1.8	1.9	30.6	1447	0.100
1x400	2.0	2.0	34.1	1782	0.0778
1x500	2.2	2.1	38.9	2564	0.0605
1x630	2.4	2.3	43.2	3154	0.0469





AA/XLPE/PVC/STA/PVC 0.6/1(1.2) kV

Standards

• AS/NZS 5000.1

GB/T 31840

• IEC 60502-1

Application

The cable is of high conductivity, good creep resistant property, high flexibility, high elongation, low resilience and connective stability. The cable is used for buildings without flame, including office, airports, hospitals, hotels, shopping malls and feeder lines of lighting in factories as well as other electric appliance.

AS/NZS 5000.1

Conductor: Aluminum Alloy 8030

Insulation: XLPEBedding: PVC

Armour: Double Layer Galvanized Steel Tape

■ Sheath: PVC/PE(Optional)

(Optional) Flame Retardant Property

(Optional) Fire Resistant Property

(Optional) Anti-Termite & Rodent Property

(Optional) Water Resistant Property



Section	Insulation Thickness	Sheath Thickness	Overall Diameter	Cable Weight AA 8030	DC. Electrical Resistance at 20°C AA 8030
No.xmm ²	mm	mm	mm	kg/km	Ω/km
2x10	0.7	1.8	17.5	333	3.08
2x16	0.7	1.8	19.5	410	1.91
2x25	0.9	1.8	22.7	539	1.21
2x35	0.9	1.8	24.7	642	0.868
2x50	1.0	1.8	27.7	807	0.641
2x70	1.1	1.9	31.5	1021	0.443
2x95	1.1	2.0	34.5	1247	0.320
2x120	1.2	2.1	39.5	1888	0.253
2x150	1.4	2.3	43.1	2216	0.206
2x185	1.6	2.4	47.9	2641	0.164
2x240	1.7	2.6	53.3	3218	0.125
2x300	1.8	2.7	58.1	3808	0.100
2x400	2.0	3.0	65.3	4768	0.0778
2x500	2.2	3.2	72.7	5773	0.0605
2x630	2.4	3.6	81.5	7077	0.0469
3x10	0.7	1.8	18.3	381	3.08
3x16	0.7	1.8	20.5	480	1.91
	0.9	1.8		642	1.21
3x25	0.9		23.9	776	0.868
3x35	1.0	1.8	26.1	991	0.641
3x50		1.8	29.3	1280	0.443
3x70	1.1	1.9	33.6	1947	0.320
3x95	1.1	2.1	38.2		0.320
3x120	1.2	2.2	42.1	2332	
3x150	1.4	2.4	45.9	2751	0.206
3x185	1.6	2.5	51.3	3319	0.164
3x240	1.7	2.7	56.9	4050	0.125
3x300	1.8	2.9	52.0	4819	0.100
3x400	2.0	3.1	59.9	6110	0.0778
3x500	2.2	3.3	77.9	7433	0.0605
3x630	2.4	3.8	87.3	9136	0.0469
4x10	0.7	1.8	19.7	444	3.08
4x16	0.7	1.8	22.1	565	1.91
4x25	0.9	1.8	26.0	769	1.21
4x35	0.9	1.8	28.4	937	0.868
4x50	1.0	1.9	32.2	1224	0.641
4x70	1.1	2.0	38.2	1940	0.443
4x95	1.1	2.2	41.9	2373	0.320
4x120	1.2	2.4	46.2	2853	0.253
4x150	1.4	2.5	50.7	3407	0.206
4x185	1.6	2.7	56.5	4097	0.164
4x240	1.7	2.9	62.9	5045	0.125
4x300	1.8	3.1	68.6	6025	0.100
4x400	2.0	3.4	77.4	7670	0.0778
4x500	2.2	3.7	86.5	9390	0.0605
4x630	2.4	4.2	97.0	11557	0.0469
5x10	0.7	1.8	21.2	511	3.08
5x16	0.7	1.8	23.9	656	1.91
5x25	0.9	1.8	28.2	901	1.21
5x35	0.9	1.8	31.1	1121	0.868
5x50	1.0	2.0	35.4	1471	0.641
5x70	1.1	2.2	41.8	2297	0.443
5x95	1.1	2.3	46.0	2827	0.320
5,05	350	7.000 miles	,0.0	18868841	(1970) TO 1970





AA/XLPE/PVC/STA/PVC 0.6/1(1.2) kV
Conductor: Aluminum Alloy 8030
Insulation: XLPE
Bedding: PVC
Armour: Double Layer Galvanized Steel Tape
Sheath: PVC 0000

Section	Insulation		Sheath Thickness	Overall Diameter	Cable Weight AA 8030	DC. Electrical Resistance at 20° AA 8030
No.xmm ²	m	m	mm	mm	kg/km	Ω/km
5x120	1.	2	2.5	51.0	3434	0.253
5x150	1.		2.7	55.8	4087	0.206
5x185	1.		2.9	62.4	4948	0.164
5x240	1.		3.1	69.6	6113	0.125
5x300	1.		3.3	76.1	7341	0.100
5x400	2.		3.7	85.9	9367	0.0778
5x500	2.		4.0	95.9	11464	0.0605
5x630	2.		4.5	107.6	14132	0.0469
3x10+1x6	0.7	0.7	1.8	19.1	419	3.08/4.61
3x16+1x10	0.7	0.7	1.8	21.5	534	1.91/3.08
3x25+1x16	0.9	0.7	1.8	25.1	719	1.21/1.91
3x35+1x16	0.9		1.8	26.9	844	0.868/1.91
		0.7			1114	0.641/1.21
3x50+1x25	1.0	0.9	1.8	30.8	1416	0.443/0.868
3x70+1x35	1.1	0.9	1.9	34.8		
3x95+1x50	1.1	1.0	2.0	39.9	2162	0.32/0.641
3x120+1x70	1.2	1.1	2.1	44.3	2623	0.253/0.443
3x150+1x70	1.4	1.1	2.2	47.7	3038	0.206/0.443
3x185+1x95	1.6	1.1	2.4	53.0	3659	0.164/0.320
3x240+1x120	1.7	1.2	2.5	58.9	4490	0.125/0.253
3x300+1x150	1.8	1.4	2.7	64.3	5362	0.100/0.206
3x400+1x185	2.0	1.6	2.9	72.5	6782	0.0778/0.164
3x500+1x240	2.2	1.7	3.1	80.8	8279	0.0605/0.125
3x600+1x300	2.4	1.8	3.9	90.1	10139	0.0469/0.100
3x10+2x6	0.7	0.7	1.8	20.2	465	3.08/3.08
3x16+2x10	0.7	0.7	1.8	23.0	602	1.91/1.91
3x25+2x16	0.9	0.7	1.8	26.7	808	1.21/1.91
3x35+2x16	0.9	0.7	1.8	28.4	932	0.868/1.91
3x50+2x25	1.0	0.9	1.9	32.8	1247	0.641/1.21
3x70+2x35	1.1	0.9	2.0	38.4	1956	0.443/0.868
3x95+2x50	1.1	1.0	2.2	42.7	2439	0.320/0.641
3x120+2x70	1.2	1.1	2.4	47.7	2986	0.253/0.443
3x150+2x70	1.4	1.1	2.5	50.7	3380	0.206/0.443
3x185+2x95	1.6	1.1	2.7	56.4	4108	0.164/0.320
3x240+2x120	1.7	1.2	2.9	62.7	5045	0.125/0.253
3x300+2x150	1.8	1.4	3.1	68.6	6040	0.100/0.206
3x400+2x185	2.0	1.6	3.3	77.3	7607	0.0778/0.164
3x500+2x240	2.2	1.7	3.6	86.3	9344	0.0605/0.125
3x630+2x300	2.4	1.8	4.1	95.8	11386	0.0469/0.100
4x10+1x6	0.7	0.7	1.8	20.8	490	3.08/3.08
4x16+1x10	0.7	0.7	1.8	23.6	633	1.91/1.91
4x25+1x16	0.9	0.7	1.8	27.6	859	1.21/1.91
4x35+1x16	0.9	0.7	1.8	29.8	1024	0.868/1.91
4x50+1x25	1.0	0.9	2.0	34.3	1368	0.641/1.21
4x70+1x35	1.1	0.9	2.1	40.4	2143	0.443/0.868
4x95+1x50	1.1	1.0	2.3	44.5	2636	0.320/0.641
4x120+1x70	1.2	1.1	2.4	49.6	3223	0.253/0.443
4x150+1x70	1.4	1.1	2.6	53.5	3743	0.206/0.443
4x185+1x95	1.6	1.1	2.8	59.7	4541	0.164/0.320
4x240+1x120	1.7	1.1	3.0	66.5	5595	0.125/0.253
			3.2	72.6	6693	0.100/0.206
4x300+1x150	1.8	1.4			8525	
4x400+1x185	2.0	1.6	3.5	82.1	10415	0.0778/0.164 0.0605/0.125
4x500+1x240	2.2	1.7	3.8	91.5		
4x630+1x300	2.2	1.8	4.3	102.2	12789	0.0469/0.100





CU(AL)/XLPE/CTS/PVC 1.8/3(3.6) kV

Standards

- AS/NZS 5000.1
- IEC 60502-1

Application

This canle is used for power transmission and distribution lines with AC rated voltage of 1.8/3(3.6) V, especially for solar plants.

AS/NZS 5000.1

- Conductor: Copper/Aluminum
- Insulation: PVC
- Metallic Screen: Copper Tape
- Sheath: PVC/PE(Optional)
- (Optional) Flame Retardant Property
- (Optional) Fire Resistant Property
- (Optional) Anti-Termite & Rodent Property
- (Optional) Water Resistant Property



Section	Insulation Thickness	Sheath Thickness	Overall Diameter		Weight	DC. Electrical Re	
No.xmm ²	mm	mm	mm	Cu kg	Al /km	Cu Ω/	Al km
1x10	2.0	1.4	12.9	252	189	1.83	3.08
1x16	2.0	1.4	14.0	326	226	1.15	1.91
1x25	2.0	1.4	15.0	426	269	0.727	1.20
1x35	2.0	1.4	16.2	538	319	0.524	0.868
1x50	2.0	1.5	17.6	702	390	0.387	0.641
1x70	2.0	1.5	19.2	914	475	0.268	0.443
1x95	2.0	1.6	21.1	1181	586	0.193	0.320
1x120	2.0	1.6	22.5	1433	681	0.153	0.253
1x150	2.0	1.7	24.2	1743	803	0.124	0.206
1x185	2.0	1.7	25.9	2091	933	0.0991	0.164
1x240	2.0	1.8	28.3	2643	1140	0.0754	0.125
1x300	2.0	1.9	30.7	3244	1364	0.0601	0.123
1x400	2.0	2.0	34.0	4225	1718	0.0470	0.0778
1x500	2.2	2.1	37.4	5227	2093	0.0366	0.0605
1x630	2.4	2.2	41.5	6253	2574	0.0283	0.0469
1x800	2.6	2.3	47.0	8221	3207	0.0221	0.0367
1x1000	2.8	2.5	52.3	10371	4104	0.0176	0.0291
2x10	2.0	1.8	20.4	519	391	1.83	3.08
2x16	2.0	1.8	22.3	671	472	1.15	1.91
2x25	2.0	1.8	24.7	898	584	0.727	1.20
2x35	2.0	1.8	26.9	1131	695	0.524	0.868
2x50	2.0	1.8	29.1	1419	827	0.387	0.641
2x70	2.0	1.9	32.4	1901	1049	0.268	0.443
2x95	2.0	2.0	35.8	2487	1302	0.193	0.320
2x120	2.0	2.1	39.0	3046	1549	0.153	0.253
2x150	2.0	2.2	42.0	3668	1816	0.124	0.206
2x185	2.0	2.3	45.4	4450	2153	0.0991	0.164
2x240	2.0	2.5	50.6	5694	2684	0.0754	0.125
2x300	2.0	2.6	55.0	6963	3200	0.0601	0.100
2x400	2.0	2.8	61.4	8868	3978	0.0470	0.0778
2x500	2.2	3.0	68.5	11270	4972	0.0366	0.0605
3x10	2.0	1.8	22.8	700	511	1.83	3.08
3x16	2.0	1.8	25.2	964	662	1.15	1.91
3x25	2.0	1.8	27.3	1255	783	0.727	1.20
3x35	2.0	1.9	30.1	1623	962	0.524	0.868
3x50	2.0	2.0	32.9	2016	1072	0.387	0.641
3x70	2.0	2.1	36.6	2660	1336	0.268	0.443
3x95	2.0	2.2	40.4	3444	1647	0.193	0.320
3x120	2.0	2.3	43.6	4216	1946	0.153	0.253
3x150	2.0	2.4	47.1	5141	2304	0.124	0.206
3x185	2.0	2.5	50.9	6207	2707	0.0991	0.164
3x240	2.0	2.7	56.1	7874	3335	0.0754	0.125
3x300	2.0	2.8	61.0	9666	3986	0.0601	0.100
3x400	2.0	3.1	68.3	12659	5086	0.0470	0.0778
3x500	2.2	3.3	75.6	15695	6228	0.0366	0.0605





CU(AL)/XLPE/CTS/PVC/SSTA/PVC 1.8/3(3.6) kV

Standards

- AS/NZS 5000.1
- IEC 60502-1

Application

This canle is used for power transmission and distribution lines with AC rated voltage of 1.8/3(3.6)V, especially for solar plants.

AS/NZS 5000.1

• Conductor: Copper/Aluminum

Insulation: PVC

Metallic Screen: Copper Tape

Bedding: PVC

Armour: Double Layer Stainless Steel Tape

• Sheath: PVC/PE(Optional)

(Optional) Flame Retardant Property

• (Optional) Fire Resistant Property

(Optional) Anti-Termite & Rodent Property

• (Optional) Water Resistant Property



Section	Insulation Thickness	Sheath Thickness	Overall Diameter	Cable	Weight	DC. Electrical Re	sistance at 20°C
No.xmm ²	mm	mm	mm	Cu	Al	Cu	Al
IVOLKIIIII				kg	/km	Ω/km	
1x10	2.0	1.8	15.0	418	355	1.83	3.08
1x16	2.0	1.8	16.0	503	403	1.15	1.91
1x25	2.0	1.8	17.3	626	469	0.727	1.20
1x35	2.0	1.8	18.4	749	531	0.524	0.868
1x50	2.0	1.8	19.3	892	596	0.387	0.641
1x70	2.0	1.8	21.0	1133	707	0.268	0.443
1x95	2.0	1.8	22.6	1419	826	0.193	0.320
1x120	2.0	1.8	24.2	1691	943	0.153	0.253
1x150	2.0	1.8	25.6	1989	1063	0.124	0.206
1x185	2.0	1.8	27.3	2365	1217	0.0991	0.164
1x240	2.0	1.8	29.9	2955	1450	0.0754	0.125
1x300	2.0	1.9	32.3	3575	1694	0.0601	0.100
1x400	2.0	2.0	35.8	4512	2067	0.0470	0.0778
1x500	2.2	2.2	41.1	6218	3069	0.0366	0.0605
1x630	2.4	2.3	45.3	7616	3682	0.0283	0.0469





CU(AL)/XLPE/CTS/PVC/STA/PVC 1.8/3(3.6) kV

Standards

- AS/NZS 5000.1
- IEC 60502-1

Application

This canle is used for power transmission and distribution lines with AC rated voltage of 1.8/3(3.6)V, especially for solar plants.

AS/NZS 5000.1

• Conductor: Copper/Aluminum

Insulation: PVC

Metallic Screen: Copper Tape

Bedding: PVC

Armour: Double Layer Galvanized Steel Tape

Sheath: PVC/PE(Optional)

(Optional) Flame Retardant Property

(Optional) Fire Resistant Property

(Optional) Anti-Termite & Rodent Property

(Optional) Water Resistant Property



Section	Insulation Thickness	Sheath Thickness	Overall Diameter	Cable Weight		DC. Electrical Re	esistance at 20°C
No.xmm ²	mm	mm	mm	Cu	Al	Cu	Al
NO.XIIIII	1100	11001	111111	kg,	/km	Ω/	km
2x10	2.0	1.8	22.6	807	680	1.83	3.08
2x16	2.0	1.8	24.4	986	786	1.15	1.91
2x25	2.0	1.8	26.6	1245	931	0.727	1.20
2x35	2.0	1.8	28.8	1510	1074	0.524	0.868
2x50	2.0	1.9	31.6	1852	1259	0.387	0.641
2x70	2.0	2.0	35.4	2421	1569	0.268	0.443
2x95	2.0	2.2	40.2	3599	2414	0.193	0.320
2x120	2.0	2.3	43.2	4247	2751	0.153	0.253
2x150	2.0	2.4	46.6	5013	3160	0.124	0.206
2x185	2.0	2.5	49.8	5894	3597	0.0991	0.164
2x240	2.0	2.6	54.4	7258	4248	0.0754	0.125
2x300	2.0	2.8	59.2	8750	4988	0.0601	0.100
2x400	2.0	3.0	65.8	10866	5977	0.0470	0.0778
2x500	2.2	3.2	72.2	13474	7176	0.0366	0.0605
3x10	2.0	1.8	26.0	988	799	1.83	3.08
3x16	2.0	1.8	28.4	1281	979	1.15	1.91
3x25	2.0	1.9	30.7	1613	1141	0.727	1.20
3x35	2.0	2.0	33.5	2015	1354	0.524	0.868
3x50	2.0	2.1	36.3	2443	1499	0.387	0.641
3x70	2.0	2.2	41.2	3520	2196	0.268	0.443
3x95	2.0	2.3	45.2	4412	2615	0.193	0.320
3x120	2.0	2.4	48.4	5257	2987	0.153	0.253
3x150	2.0	2.6	52.3	6312	3475	0.124	0.206
3x185	2.0	2.7	56.3	7496	3997	0.0991	0.164
3x240	2.0	2.9	61.7	9319	4780	0.0754	0.125
3x300	2.0	3.0	66.8	11265	5585	0.0601	0.100
3x400	2.0	3.3	74.3	14476	6903	0.0470	0.0778
3x500	2.2	3.5	81.8	17738	8271	0.0366	0.0605





CU(AL)/XLPE/CTS/PVC/AWA/PVC 1.8/3(3.6) kV

Standards

- AS/NZS 5000.1
- IEC 60502-1

Application

This canle is used for power transmission and distribution lines with AC rated voltage of 1.8/3(3.6)V, especially for solar plants.

AS/NZS 5000.1

• Conductor: Copper/Aluminum

Insulation: PVC

Metallic Screen: Copper Tape

Bedding: PVC

Armour: Aluminum WireSheath: PVC/PE(Optional)

• (Optional) Flame Retardant Property

(Optional) Fire Resistant Property

(Optional) Anti-Termite & Rodent Property

(Optional) Water Resistant Property



Section	Insulation Thickness	Sheath Thickness	Overall Diameter	Cable	Weight	DC. Electrical Resistance at 20°C	
No.xmm²		mm	Company Company	Cu	Al	Cu	Al
NO.XIIII	mm	11011	mm	kg	/km	Ω/km	
1x10	2.0	1.8	15.8	383	320	1.83	3.08
1x16	2.0	1.8	17.7	511	411	1.15	1.91
1x25	2.0	1.8	19.0	634	477	0.727	1.20
1x35	2.0	1.8	20.1	755	537	0.524	0.868
1x50	2.0	1.8	21.0	893	597	0.387	0.641
1x70	2.0	1.8	23.4	1181	755	0.268	0.443
1x95	2.0	1.8	25.0	1468	876	0.193	0.320
1x120	2.0	1.8	26.6	1742	994	0.153	0.253
1x150	2.0	1.8	28.0	2043	1117	0.124	0.206
1x185	2.0	1.9	29.9	2441	1292	0.0991	0.164
1x240	2.0	2.0	32.7	3052	1547	0.0754	0.125
1x300	2.0	2.1	35.9	3765	1883	0.0601	0.100
1x400	2.0	2.2	39.4	4716	2271	0.0470	0.0778
1x500	2.2	2.3	43.3	5899	2750	0.0366	0.0605
1x630	2.4	2.5	48.7	7432	3498	0.0283	0.0469





CU(AL)/XLPE/CTS/PVC/SWA/PVC 1.8/3(3.6) kV

Standards

- AS/NZS 5000.1
- IEC 60502-1

Application

This cable is used for power transmission and distribution lines with AC rated voltage of 1.8/3(3.6)V, especially for solar plants.

AS/NZS 5000.1

Conductor: Copper/Aluminum

Insulation: PVC

Metallic Screen: Copper Tape

Bedding: PVC

Armour: Galvanized Steel Wire

Sheath: PVC/PE(Optional)

(Optional) Flame Retardant Property

(Optional) Fire Resistant Property

• (Optional) Anti-Termite & Rodent Property



Section	Insulation Thickness	Sheath Thickness	Overall Diameter	Cable	Weight	DC. Electrical Re	esistance at 20°C
S2	200.000	mm	mm	Cu	Al	Cu	Al
No.xmm ²	mm	1401	11111	kg	/km	Ω,	'km
2x10	2.0	1.8	25.0	1228	1101	1.83	3.08
2x16	2.0	1.8	26.8	1436	1237	1.15	1.91
2x25	2.0	1.8	29.0	1736	1422	0.727	1.20
2x35	2.0	1.9	31.4	2074	1637	0.524	0.868
2x50	2.0	2.0	35.0	2685	2092	0.387	0.641
2x70	2.0	2.1	38.8	3345	2493	0.268	0.443
2x95	2.0	2.2	42.2	4078	2893	0.193	0.320
2x120	2.0	2.4	46.4	5194	3697	0.153	0.253
2x150	2.0	2.5	49.8	6037	4185	0.124	0.206
2x185	2.0	2.6	53.0	6963	4665	0.0991	0.164
2x240	2.0	2.7	57.6	8452	5442	0.0754	0.125
2x300	2.0	2.9	62.4	10033	6271	0.0601	0.100
2x400	2.0	3.1	69.0	12310	7420	0.0470	0.0778
2x500	2.2	3.4	76.9	15930	9632	0.0366	0.0605
3x10	2.0	1.8	29.0	1640	1451	1.83	3.08
3x16	2.0	1.9	31.6	2010	1708	1.15	1.91
3x25	2.0	2.0	33.9	2407	1935	0.727	1.20
3x35	2.0	2.1	37.5	3123	2462	0.524	0.868
3x50	2.0	2.2	40.3	3652	2709	0.387	0.641
3x70	2.0	2.3	44.0	4469	3145	0.268	0.443
3x95	2.0	2.5	49.6	6012	4215	0.193	0.320
3x120	2.0	2.6	52.8	6995	4725	0.153	0.253
3x150	2.0	2.7	56.5	8160	5323	0.124	0.206
3x185	2.0	2.8	60.5	9747	5974	0.0991	0.164
3x240	2.0	3.0	65.9	11498	6958	0.0754	0.125
3x300	2.0	3.2	71.2	13636	7956	0.0601	0.100
3x400	2.0	3.5	80.0	18022	10448	0.0470	0.0778
	2.2					0.0000	





Part II Medium Voltage Power Cable



CU(AL,AA)/SCR/XLPE/SCR/(CWS)/CTS/PVC 1.9/3.3(3.6)kV ~ 26/35(40.5)kV

© CU(AL,AA)/SCR/XLPE/SCR/(CWS)/CTS/PVC/SSTA/PVC 3.6/6(7.2)kV ~ 26/35(40.5)kV

CU(AL,AA)/SCR/XLPE/SCR/(CWS)/CTS/PVC/STA/PVC 3.6/6(7.2)kV ~ 26/35(40.5)kV

CU(AL)/SCR/XLPE/SCR/(CWS)/CTS/PVC/AWA/PVC 3.6/6(7.2)kV ~ 26/35(40.5)kV

© CU(AL)/SCR/XLPE/SCR/(CWS)/CTS/PVC/SWA/PVC 1.9/3.3(3.6)kV ~ 26/35(40.5)kV





CU(AL)/SCR/XLPE/SCR/(CWS)/CTS/PVC 3.6/6(7.2) ~ 26/35(40.5) kV


Standards

- AS/NZS 1429.1
- HD 620
- IEC 60502-2
- DIN VDE 0276-620

Application

The cable is designed for distribution of electrical power with nominal voltage Uo/U(Um) ranging from 3.6/6(7.2) kV to 26/35(40.5) kV and frequency 50Hz. It is suitable for installation mostly in power supply stations, in doors and in cable ducts, outdoors, underground and in water as well as for installation on cable trays for industries, switchboards and power stations.

AS/NZS 1429.1



- Conductor Screen: Semi-Conductive Compound
- Insulation: XLPE
- Insulation Screen: Semi-Conductive Compound
- Metallic Screen: Copper Wire(Optional)/Copper Tape
- Sheath: PVC/PE(Optional)
- (Optional) Flame Retardant Property
- (Optional) Fire Resistant Property
- (Optional) Anti-Termite & Rodent Property
- (Optional) Water Resistant Property



Section	Insulation Thickness	Sheath Thickness	Overall Diameter		Weight		Resistance at 20°0
No.xmm ²	mm	mm	mm	Cu	Al	Cu	Al
			3.6/6(7.2)kV, 3.8/6.6(7.2)kV	1000	/km	7	2/km
1x25	2.5	1.5	17.9	560	390	0.727	1.20
1x35	2.5	1.6	18.9	680	480	0.524	0.868
1x50	2.5	1.6	20.3	860	550	0.324	0.641
1x70	2.5	1.7	21.9	1080	650	0.268	0.443
1x95	2.5	1.7	23.7	1350	760	0.193	0.320
1x120	2.5	1.8	25.2	1610	840	0.153	0.253
1x150	2.5	1.8	27.0	1920	990	0.124	0.206
1x185	2.5	1.9	28.6	2290	1140	0.0991	0.200
1x240	2.6	2.0	31.2	2860	1370	0.0754	0.164
	2.8	2.1	34.0	3500		0.0601	0.123
1x300	3.0				1640		
1x400		2.2	37.6	4610	2140	0.0470	0.0778
1x500	3.2	2.3	41.3	5700	2610	0.0366	0.0609
1x630	3.2	2.4	44.9	6990	3090	0.0283	0.0469
3x25	2.5	2.1	35.8	1750	1280	0.727	1.20
3x35	2.5	2.2	38.1	2130	1470	0.524	0.868
3x50	2.5	2.3	41.1	2670	1740	0.387	0.641
3x70	2.5	2.4	44.5	3390	2090	0.268	0.443
3x95	2.5	2.5	48.5	4250	2470	0.193	0.320
3x120	2.5	2.6	51.7	5090	2850	0.153	0.253
3x150	2.5	2.8	55.4	6120	3310	0.124	0.206
3x185	2.5	2.9	58.8	7270	3800	0.0991	0.164
3x240	2.6	3.0	64.6	9090	4600	0.0754	0.125
3x300	2.8	3.2	70.6	11120	5510	0.0601	0.100
3x400	3.0	3.5	78.4	15190	7750	0.0470	0.0778
3x500	3.2	3.7	86.2	17131	8045	0.0366	0.0609
3x630	3.2	4.0	94.0	21037	9749	0.0283	0.0469
			6/10(12)kV, 6.35/11(12)kV				
1x25	3.4	1.6	19.8	609	458	0.727	1.20
1x35	3,4	1.6	20.8	729	514	0.524	0.868
1x50	3.4	1.7	22.3	876	585	0.387	0.641
1x70	3.4	1.7	23.8	1092	681	0.268	0.443
1x95	3.4	1.8	25.7	1380	805	0.193	0.320
1x120	3.4	1.8	27.1	1651	913	0.153	0.253
1x150	3.4	1.9	28.7	1970	1043	0.124	0.206
1x185	3.4	1.9	30.4	2271	1165	0.0991	0.164
1x240	3.4	2.0	32.9	2830	1382	0.0754	0.125
1x300	3.4	2.1	35.3	3502	1642	0.0601	0.100
1x400	3.4	2.2	38.5	4406	1991	0.0470	0.077
1x500	3.4	2.3	42.0	5515	2418	0.0366	0.060
1x630	3.4	2.4	45.6	6754	2883	0.0283	0.0469
3x25	3.4	2.2	39.8	1927	1451	0.727	1.20
3x35	3.4	2.3	42.2	2316	1639	0.524	0.868
3x50	3.4	2.4	45.2	2805	1874	0.387	0.641
3x70	3.4	2.5	48.6	3497	2193	0.268	0.443
3x95	3.4	2.7	52.7	4483	2653	0.193	0.320





Conductor: Copper/Aluminum

• Conductor Screen: Semi-Conductive Compound

Insulation: XLPE

• Insulation Screen: Semi-Conductive Compound

Metallic Screen: Copper Wire(Optional)/Copper Tape

Section	Insulation Thickness	Sheath Thickness	Overall Diameter		Weight	DC. Electrical Re	
No.xmm²	mm	mm	mm	Cu kg,	/km	Cu Ω/	'km
			6/10(12)kV, 6.35/11(12)kV		-		
3x120	3.4	2.8	55.9	5340	3040	0.153	0.253
3x150	3.4	2.9	59.6	6398	3503	0.124	0.206
3x185	3.4	3.0	63.0	7241	3946	0.0991	0.164
3x240	3.4	3.2	68.3	9234	4729	0.0754	0.125
3x300	3.4	3.3	73.3	11337	5586	0.0601	0.100
3x400	3.4	3.6	80.3	14174	6822	0.0470	0.0778
3x500	3.4	3.8	87.9	17320	8299	0.0366	0.060
3x630	3.4	4.1	95.8 8.7/15(17.5)kV	21736	9949	0.0283	0.0469
1x25	4.5	1.6	22.0	696	544	0.727	1.20
1x35	4.5	1.6	23.0	819	604	0.524	0.868
1x50	4.5	1.7	24.5	970	679	0.387	0.641
1x70	4.5	1.8	26.2	1191	780	0.268	0.443
1x95	4.5	1.8	27.9	1493	910	0.193	0.320
1x120	4.5	1.9	29.5	1760	1023	0.153	0.253
1x150	4.5	1.9	31.1	2085	1158	0.124	0.206
1x185	4.5	2.0	32.8	2391	1285	0.0991	0.164
1x240	4.5	2.1	35.3	2873	1525	0.0754	0.125
1x300	4.5	2.2	37.7	3657	1798	0.0601	0.100
1x400	4.5	2.3	40.9	4571	2156	0.0470	0.077
1x500	4.5	2.4	44.4	5692	2595	0.0366	0.060
1x630	4.5	2.5	48.0	6954	3074	0.0283	0.0469
3x25	4.5	2.4	45.0	2217	1747	0.727	1.20
3x35	4.5	2.5	47.3	2616	1947	0.524	0.868
3x50	4.5	2.6	50.3	3144	2223	0.387	0.641
3x70	4.5	2.7	53.8	3879	2586	0.268	0.443
3x95	4.5	2.8	57.6	4872	3051	0.193	0.320
3x120	4.5	2.9	60.9	5753	3458	0.153	0.253
3x150	4.5	3.0	64.5	6837	3945	0.124	0.206
3x185	4.5	3.2	68.1	7900	4429	0.0991	0.164
3x240	4.5	3.3	73.3	9719	5230	0.0754	0.125
3x300	4.5	3.5	78.4	11862	6154	0.0601	0.100
3x400	4.5	3.7	85.3	14795	7402	0.0470	0.077
3x500	4.5	4.0	93.0 12/20(24)kV, 12.7/22(24)kV	18381	8950	0.0366	0.060
1x35	5.5	1.8	25.4	930	720	0.524	0.868
1x50	5.5	1.8	26.8	1160	850	0.387	0.641
1x70	5.5	1.9	28.4	1410	980	0.268	0.443
1x95	5.5	1.9	30.2	1690	1110	0.193	0.320
1x120	5.5	2.0	31.7	1980	1240	0.153	0.253
1x150	5.5	2.0	33.4	2310	1380	0.124	0.206
1x185	5.5	2.1	35.0	2770	1550	0.0991	0.164
1x240	5.5	2.2	37.4	3290	1800	0.0754	0.125
1x300	5.5	2.2	39.8	3910	2050	0.0601	0.100
1x400	5.5	2.3	43.0	5030	2550	0.0470	0.0778
1x500	5.5	2.5	46.2	6120	3030	0.0366	0.060
1x630	5.5	2.6	49.8	7440	3540	0.0283	0.0469
3x35	5.5	2.7	52.0	3230	2570	0.524	0.868
3x50	5.5	2.8	55.0	3840	2900	0.387	0.641
3x70	5.5	2.9	58.4	4640	3330	0.268	0.443
3x95	5.5	3.0	62.3	5570	3800	0.193	0.320
3x120	5.5	3.1	65.6	6480	4240	0.153	0.253
3x150	5.5	3.2	69.2	7560	4750	0.124	0.206
3x185	5.5	3.3	72.7	8780	5320	0.0991	0.164
3x240	5.5	3.5	78.0	10680	6180	0.0754	0.125
3x300	5.5	3.7	83.0	12720	7100	0.0601	0.100
3x400	5.5	3.9	90.0	16280	8790	0.0470	0.0778
3x500	5.5	4.1	96.8	18820	9580	0.0366	0.060
1x50	8.0	2.0	18/30(36)kV, 19/33(36)kV 33.3	1560	1250	0.387	0.641
1x70	8.0	2.1	33.3 34.9	1840	1400	0.268	0.443
1x70 1x95	8.0	2.1	36.7	2140	1550	0.193	0.320
1x120	8.0	2.2	38.2	2450	1700	0.153	0.253
1x120 1x150	8.0	2.2	39.9	2790	1860	0.124	0.206
1x185	8.0	2.3	41.5	3200	2050	0.0991	0.206
1x185	8.0	2.3	44.0	3800	2310	0.0991	0.164
1x240 1x300	8.0	2.4	46.3	4460	2600	0.0754	0.123
1x400	8.0	2.5	49.6	5530	3060	0.0470	0.100
1x500	8.0	2.6	52.8	6160	3560	0.0470	0.060
1x630	8.0	2.7	56.4	8020	4120	0.0388	0.0469
3x50	8.0	3.1	68.4	5290	4350	0.387	0.641
3x70	8.0	3.2	72.5	6240	4930	0.268	0.443





• Conductor: Copper/Aluminum

• Conductor Screen: Semi-Conductive Compound

Insulation: XLPE

Insulation Screen: Semi-Conductive Compound

Metallic Screen: Copper Wire(Optional)/Copper Tape

Section	Insulation Thickness	Sheath Thickness	Overall Diameter	Cable	Weight	DC. Electrical Re	sistance at 20°C
No.xmm ²	mm	mm	mm	Cu	Al	Cu	Al
NO.XIIIII	1000		3,000	kg,	/km	Ω/	km
			18/30(36)kV, 19/33(36)kV				
3x120	8.0	3.5	79.4	8350	6120	0.153	0.253
3x150	8.0	3.6	82.6	9520	6410	0.124	0.206
3x185	8.0	3.7	86.4	10830	7370	0.0991	0.164
3x240	8.0	3.9	91.4	12810	8300	0.0754	0.125
3x300	8.0	4.0	96.7	14920	9300	0.0601	0.100
3x400	8.0	4.3	103.8	18110	10620	0.0470	0.0778
			26/35(40.5)kV				
1x50	10.5	2.2	38.7	1727	1437	0.387	0.641
1x70	10.5	2.2	40.2	1980	1570	0.268	0.443
1x95	10.5	2.3	42.1	2335	1750	0.193	0.320
1x120	10.5	2.4	43.7	2650	1910	0.153	0.253
1x150	10.5	2.4	45.3	3016	2090	0.124	0.206
1x185	10.5	2.5	47.0	3377	2270	0.0991	0.164
1x240	10.5	2.5	49.3	3996	2550	0.0754	0.125
1x300	10.5	2.6	51.7	4733	2870	0.0601	0.100
1x400	10.5	2.7	54.9	5723	3308	0.0470	0.0778
1x500	10.5	2.8	59.8	7068	3970	0.0366	0.0605
1x630	10.5	3.0	63.6	8418	4550	0.0283	0.0469
3x50	10.5	3.6	80.8	6030	5150	0.387	0.641
3x70	10.5	3.7	54.2	6900	5650	0.268	0.443
3x95	10.5	3.8	88.1	8060	6282	0.193	0.320
3x120	10.5	3.9	91.3	9070	6830	0.153	0.253
3x150	10.5	4.0	94.9	10290	7470	0.124	0.206
3x185	10.5	4.1	98.4	11490	8120	0.0991	0.164
3x240	10.5	4.2	103.5	13550	9140	0.0754	0.125
3x300	10.5	4.4	108.7	15950	10290	0.0601	0.100
3x400	10.5	4.6	115.5	19180	11830	0.0470	0.0778





CU(AL)/SCR/XLPE/SCR/CWS/PVC 1.9/3.3(3.6) ~ 19/33(36) kV


Standards

AS/NZS 1429.1

Application

The cables is designed to be used for the supply of electrical energy in fixed installations up to the indicated rated voltage at a nominal power frequency in the range 49Hz to 61Hz, intended for use either installed in air, directly buried in the ground or in ducts.

AS/NZS 1429.1



• Conductor Screen: Semi-Conductive Compound

Insulation: XLPE

Insulation Screen: Semi-Conductive Compound

• Metallic Screen: Copper Wire


• Sheath: PVC/PE(Optional)

(Optional) Flame Retardant Property

• (Optional) Fire Resistant Property

(Optional) Anti-Termite & Rodent Property

(Optional) Water Resistant Property



Section	Insulation Thickness	Sheath Thickness	Overall Diameter		Weight		cal Resistance at 20°0
No.xmm ²	mm	mm	mm	Cu	Al /km	Cu	Al Ω/km
			1.9/3.3(3.6)kV	Α9	/801		*4/ KIII
			Light Duty Screened				
1x25	2.0	1.8	18.6	650	450	0.727	1.20
1x35	2.0	1.8	19.6	750	550	0.524	0.868
1x50	2.0	1.8	20.7	900	600	0.387	0.641
1x70	2.0	1.8	22.3	1100	700	0.268	0.443
1x95	2.0	1.8	24.0	1350	800	0.193	0.320
1x120	2.0	1.8	25.4	1600	900	0.153	0.253
1x150	2.0	1.8	26.8	1900	1000	0.124	0.206
1x185	2.0	1.8	28.6	2250	1100	0.0991	0.164
1x240	2.0	1.8	31.0	2800	1350	0.0754	0.125
1x300	2.0	1.9	33.5	3400	1550	0.0601	0.100
1x400	2.0	2.0	37.2	4300	1900	0.0470	0.077
1x500	2.2	2.1	40.9	5350	2250	0.0366	0.060
1x630	2.4	2.3	45.2	6750	2800	0.0283	0.046
3x25	2.0	2.0	36.0	1600	1100	0.727	1.20
3x35	2.0	2.0	38.2	1950	1300	0.524	0.868
3x50	2.0	2.1	40.8	2350	1500	0.387	0.641
3x70	2.0	2.3	44.6	3050	1800	0.268	0.443
3x95	2.0	2.4	48.6	3900	2150	0.193	0.320
3x120	2.0	2.5	51.9	4750	2500	0.153	0.253
3x150	2.0	2.6	55.1	5600	2900	0.124	0.206
3x185	2.0	2.7	59.1	6750	3350	0.0991	0.164
3x240	2.0	2.9	64.2	8550	4100	0.0754	0.125
3x300	2.0	3.0	69.5	10500	4900	0.0601	0.100
3x300	2.0	5.0	Heavy Duty Screened	10500	4300	0.0001	0.700
1x25	2.0	1.8	18.6	700	450	0.727	1.20
1x35	2.0	1.8	20.9	900	550	0.524	0.868
1x50	2.0	1.8	22.0	1150	700	0.387	0.641
1x70	2.0	1.8	24.3	1550	950	0.268	0.443
1x95	2.0	1.8	26.0	1850	1200	0.193	0.320
1x120	2.0	1.8	26.7	2050	1350	0.153	0.253
1x150	2.0	1.8	28.1	2350	1450	0.124	0.206
1x185	2.0	1.8	30.1	2700	1600	0.0991	0.164
1x240	2.0	1.9	32.3	3250	1800	0.0754	0.125
1x300	2.0	1.9	34.8	3850	2000	0.0601	0.100
1x400	2.0	2.1	38.5	4750	2350	0.0470	0.077
1x500	2.2	2.2	42.2	5800	2700	0.0366	0.060
1x630	2.4	2.3	46.5	7200	3250	0.0283	0.046
3x25	2.0	2.0	36.0	1650	1100	0.727	1.20
3x35	2.0	2.1	38.2	2100	1300	0.524	0.868
3x50	2.0	2.2	40.8	2600	1600	0.387	0.641
3x70	2.0	2.3	44.8	3500	2050	0.268	0.443
3x95	2.0	2.4	48.6	4350	2550	0.193	0.320
3x120	2.0	2.5	51.9	5150	2900	0.153	0.253
3x150	2.0	2.6	55.1	6000	3300	0.124	0.206
3x185	2.0	2.8	59.1	7150	3750	0.0991	0.164
3x240	2.0	2.9	64.2	8900	4450	0.0754	0.125
3x300	2.0	3.0	69.5	10800	5200	0.0601	0.100





Conductor: Copper/Aluminum Conductor Screen: Semi-Conductive Compound

Insulation: XLPE

00000 Insulation Screen: Semi-Conductive Compound Metallic Screen: Copper Wire Sheath: PVC

mm 3.8/6.6(7.2)kV tht Duty Screened 19.6 20.6 21.7 23.3 25.0 26.4 27.8 29.8 32.2 35.1 39.2 43.1 47.0 38.3 40.5 43.2 46.9 50.8 54.0 57.4 61.4 66.8 73.3 avy Duty Screened 19.6 21.9 23.0 25.3 27.0 27.7 29.1 31.1 33.7 36.6 40.7	700 800 900 1150 1400 1650 1900 2300 2850 3500 4400 5500 6850 1700 2100 2500 3200 4050 4850 5750 6950 8800 10800 750 950 1200 1600 1850 2100 2400 2750 3350	Meight Al /km 500 600 650 700 850 900 1000 1200 1400 1650 2000 2400 2900 1200 1400 1660 1950 2300 2650 3050 3550 4300 5250 500 600 650 700 850 900 1000 1200 1400	DC. Electrical Re Cu Ω/ 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991 0.0754 0.0601 0.0470 0.0366 0.0283 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991 0.0754 0.0601 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991 0.0754 0.387 0.268 0.193 0.153 0.124 0.0991 0.0754	1.20 0.868 0.641 0.443 0.320 0.253 0.206 0.164 0.125 0.100 0.0778 0.0605 0.469 1.20 0.868 0.641 0.443 0.3200 0.253 0.206 0.164 0.125 0.100 1.20 0.868 0.641 0.443 0.320 0.253 0.206 0.164 0.125 0.100
3.8/6.6(7.2)kV Int Duty Screened 19.6 20.6 21.7 23.3 25.0 26.4 27.8 29.8 32.2 35.1 39.2 43.1 47.0 38.3 40.5 43.2 46.9 50.8 54.0 57.4 61.4 66.8 73.3 avy Duty Screened 19.6 21.9 23.0 25.3 27.0 27.7 29.1 31.1 33.7 36.6 40.7	700 800 900 1150 1400 1650 1900 2300 2850 3500 4400 5500 6850 1700 2100 2500 3200 4050 4850 5750 6950 8800 10800 750 950 1200 1600 1850 2100 2400 2400 2750 3350	500 600 650 700 850 900 1000 1200 1400 2900 2400 2900 1200 1400 1600 1950 2300 2650 3050 3550 4300 5250 500 600 650 700 850 900 1000	0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991 0.0754 0.0601 0.0470 0.0366 0.0283 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991 0.0754 0.0601	1.20 0.868 0.641 0.443 0.320 0.253 0.206 0.164 0.125 0.100 0.0778 0.0605 0.469 1.20 0.868 0.641 0.443 0.320 0.253 0.206 0.164 0.125 0.100 1.20 0.868 0.641 0.443 0.320 0.253 0.206 0.164 0.125 0.100
ht Duty Screened 19.6 20.6 21.7 23.3 25.0 26.4 27.8 29.8 32.2 35.1 39.2 43.1 47.0 38.3 40.5 43.2 46.9 50.8 54.0 57.4 61.4 66.8 73.3 avy Duty Screened 19.6 21.9 23.0 25.3 27.0 27.7 29.1 31.1 33.7 36.6 40.7	800 900 1150 1400 1650 1900 2300 2850 3500 4400 5500 6850 1700 2100 2500 3200 4050 4850 5750 6950 8800 10800 750 950 1200 1600 1850 2100 2400 2400 2750 3350	600 650 700 850 900 1000 1200 1400 1650 2000 2400 2900 1200 1400 1600 1950 2300 2650 3050 3550 4300 5250 500 600 650 700 850 900 1000 1200	0.524 0.387 0.268 0.193 0.153 0.154 0.0991 0.0754 0.0601 0.0470 0.0366 0.0283 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991 0.0754 0.0601 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991	0.868 0.641 0.443 0.320 0.253 0.206 0.164 0.125 0.100 0.0778 0.0605 0.0469 1.20 0.868 0.641 0.443 0.320 0.125 0.100 1.20 0.868 0.641 0.443 0.320 0.253 0.206 0.164 0.125 0.100
19.6 20.6 21.7 23.3 25.0 26.4 27.8 29.8 32.2 35.1 39.2 43.1 47.0 38.3 40.5 43.2 46.9 50.8 54.0 57.4 61.4 66.8 73.3 avy Duty Screened 19.6 21.9 23.0 25.3 27.0 27.7 29.1 31.1 33.7 36.6 40.7	800 900 1150 1400 1650 1900 2300 2850 3500 4400 5500 6850 1700 2100 2500 3200 4050 4850 5750 6950 8800 10800 750 950 1200 1600 1850 2100 2400 2400 2750 3350	600 650 700 850 900 1000 1200 1400 1650 2000 2400 2900 1200 1400 1600 1950 2300 2650 3050 3550 4300 5250 500 600 650 700 850 900 1000 1200	0.524 0.387 0.268 0.193 0.153 0.154 0.0991 0.0754 0.0601 0.0470 0.0366 0.0283 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991 0.0754 0.0601 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991	0.868 0.641 0.443 0.320 0.253 0.206 0.164 0.125 0.100 0.0778 0.0605 0.0469 1.20 0.868 0.641 0.443 0.320 0.125 0.100 1.20 0.868 0.641 0.443 0.320 0.253 0.206 0.164 0.125 0.100
20.6 21.7 23.3 25.0 26.4 27.8 29.8 32.2 35.1 39.2 43.1 47.0 38.3 40.5 43.2 46.9 50.8 54.0 57.4 61.4 66.8 73.3 avy Duty Screened 19.6 21.9 23.0 25.3 27.0 27.7 29.1 31.1 33.7 36.6 40.7	800 900 1150 1400 1650 1900 2300 2850 3500 4400 5500 6850 1700 2100 2500 3200 4050 4850 5750 6950 8800 10800 750 950 1200 1600 1850 2100 2400 2400 2750 3350	600 650 700 850 900 1000 1200 1400 1650 2000 2400 2900 1200 1400 1600 1950 2300 2650 3050 3550 4300 5250 500 600 650 700 850 900 1000 1200	0.524 0.387 0.268 0.193 0.153 0.154 0.0991 0.0754 0.0601 0.0470 0.0366 0.0283 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991 0.0754 0.0601 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991	0.868 0.641 0.443 0.320 0.253 0.206 0.164 0.125 0.100 0.0778 0.0605 0.0469 1.20 0.868 0.641 0.443 0.320 0.125 0.100 1.20 0.868 0.641 0.443 0.320 0.253 0.206 0.164 0.125 0.100
21.7 23.3 25.0 26.4 27.8 29.8 32.2 35.1 39.2 43.1 47.0 38.3 40.5 43.2 46.9 50.8 54.0 57.4 61.4 66.8 73.3 avy Duty Screened 19.6 21.9 23.0 25.3 27.0 27.7 29.1 31.1 33.7 36.6 40.7	900 1150 1400 1650 1900 2300 2850 3500 4400 5500 6850 1700 2100 2500 3200 4050 4850 5750 6950 8800 10800 750 950 1200 1600 1850 2100 2400 2750 3350	650 700 850 900 1000 1200 1400 1650 2000 2400 2900 1200 1400 1600 1950 2300 2650 3050 3550 4300 5250 500 600 650 700 850 900 1000 1200	0.387 0.268 0.193 0.153 0.124 0.0991 0.0754 0.0601 0.0470 0.0366 0.0283 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991 0.0754 0.0601 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991	0.641 0.443 0.320 0.253 0.206 0.164 0.125 0.100 0.0778 0.0605 0.0469 1.20 0.868 0.641 0.443 0.320 0.253 0.206 0.164 0.125 0.100 1.20 0.868 0.641 0.443 0.320 0.253 0.206 0.164 0.125 0.100
23.3 25.0 26.4 27.8 29.8 32.2 35.1 39.2 43.1 47.0 38.3 40.5 43.2 46.9 50.8 54.0 57.4 61.4 66.8 73.3 any Duty Screened 19.6 21.9 23.0 25.3 27.0 27.7 29.1 31.1 33.7 36.6 40.7	1150 1400 1650 1900 2300 2850 3500 4400 5500 6850 1700 2100 2500 3200 4050 4850 5750 6950 8800 10800 750 950 1200 1600 1850 2100 2400 2750 3350	700 850 900 1000 1200 1400 1650 2000 2400 2900 1200 1400 1600 1950 2300 2650 3050 3550 4300 5250 500 600 650 700 850 900 1000 1200	0.268 0.193 0.153 0.124 0.0991 0.0754 0.0601 0.0470 0.0366 0.0283 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991 0.0754 0.0601 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991	0.443 0.320 0.253 0.206 0.164 0.125 0.100 0.0778 0.0605 0.0469 1.20 0.868 0.641 0.443 0.320 0.253 0.206 0.164 0.125 0.100 1.20 0.868 0.641 0.443 0.320 0.253 0.206 0.164 0.125 0.100
25.0 26.4 27.8 29.8 32.2 35.1 39.2 43.1 47.0 38.3 40.5 43.2 46.9 50.8 54.0 57.4 61.4 66.8 73.3 avy Duty Screened 19.6 21.9 23.0 25.3 27.0 27.7 29.1 31.1 33.7 36.6 40.7	1400 1650 1900 2300 2850 3500 4400 5500 6850 1700 2100 2500 3200 4050 4850 5750 6950 8800 10800 750 950 1200 1600 1850 2100 2400 2750 3350	850 900 1000 1200 1400 1650 2000 2400 2900 1200 1400 1600 1950 2300 2650 3050 3550 4300 5250 500 600 650 700 850 900 1000 1200	0.193 0.153 0.124 0.0991 0.0754 0.0601 0.0470 0.0366 0.0283 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991 0.0754 0.0601	0.320 0.253 0.206 0.164 0.125 0.100 0.0778 0.0605 0.0469 1.20 0.868 0.641 0.443 0.320 0.253 0.100 1.20 0.868 0.641 0.443 0.320 0.253 0.206
26.4 27.8 29.8 32.2 35.1 39.2 43.1 47.0 38.3 40.5 43.2 46.9 50.8 54.0 57.4 61.4 66.8 73.3 avy Duty Screened 19.6 21.9 23.0 25.3 27.0 27.7 29.1 31.1 33.7 36.6 40.7	1650 1900 2300 2850 3500 4400 5500 6850 1700 2100 2500 3200 4050 4850 5750 6950 8800 10800 750 950 1200 1600 1850 2100 2400 2400 2750 3350	900 1000 1200 1400 1400 2900 2400 2900 1200 1400 1650 2300 2650 3050 3550 4300 5250 500 600 650 700 850 900 1000 1200	0.153 0.124 0.0991 0.0754 0.0601 0.0470 0.0366 0.0283 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991 0.0754 0.0601	0.253 0.206 0.164 0.125 0.100 0.0778 0.0605 0.0469 1.20 0.868 0.641 0.443 0.320 0.164 0.125 0.100 1.20 0.868 0.641 0.443 0.320 0.253 0.266 0.164 0.125 0.100
27.8 29.8 32.2 35.1 39.2 43.1 47.0 38.3 40.5 43.2 46.9 50.8 54.0 57.4 61.4 66.8 73.3 avy Duty Screened 19.6 21.9 23.0 25.3 27.0 27.7 29.1 31.1 33.7 36.6 40.7	1900 2300 2850 3500 4400 5500 6850 1700 2100 2500 3200 4050 4850 5750 6950 8800 10800 750 950 1200 1600 1850 2100 2400 2750 3350	1000 1200 1400 1650 2000 2400 2900 1200 1400 1600 1950 2300 2650 3050 3550 4300 5250 500 600 650 700 850 900 1000 1200	0.124 0.0991 0.0754 0.0601 0.0470 0.0366 0.0283 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991 0.0754 0.0601 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991 0.754 0.0601	0.206 0.164 0.125 0.100 0.0778 0.0605 0.0469 1.20 0.868 0.641 0.443 0.320 0.253 0.206 0.164 0.125 0.100 1.20 0.868 0.641 0.443 0.320 0.253 0.206 0.100
29.8 32.2 35.1 39.2 43.1 47.0 38.3 40.5 43.2 46.9 50.8 54.0 57.4 61.4 66.8 73.3 avy Duty Screened 19.6 21.9 23.0 25.3 27.0 27.7 29.1 31.1 33.7 36.6 40.7	2300 2850 3500 4400 5500 6850 1700 2100 2500 3200 4050 4850 5750 6950 8800 10800 750 950 1200 1600 1850 2100 2400 2750 3350	1200 1400 1650 2000 2400 2900 1200 1400 1600 1950 2300 2650 3050 3550 4300 5250 500 600 650 700 850 900 1000 1200	0.0991 0.0754 0.0601 0.0470 0.0366 0.0283 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991 0.0754 0.0601 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991	0.164 0.125 0.100 0.0778 0.0605 0.0469 1.20 0.868 0.641 0.443 0.320 0.253 0.206 0.164 0.125 0.100 1.20 0.868 0.641 0.443
32.2 35.1 39.2 43.1 47.0 38.3 40.5 43.2 46.9 50.8 54.0 57.4 61.4 66.8 73.3 avy Duty Screened 19.6 21.9 23.0 25.3 27.0 27.7 29.1 31.1 33.7 36.6 40.7	2850 3500 4400 5500 6850 1700 2100 2500 3200 4050 4850 5750 6950 8800 10800 750 950 1200 1600 1850 2100 2400 2750 3350	1400 1650 2000 2400 2900 1200 1400 1600 1950 2300 2650 3050 3550 4300 5250 500 600 650 700 850 900 1000 1200	0.0754 0.0601 0.0470 0.0366 0.0283 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991 0.0754 0.0601 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991	0.125 0.100 0.0778 0.0605 0.0469 1.20 0.868 0.641 0.443 0.320 0.253 0.206 0.164 0.125 0.100 1.20 0.868 0.641 0.443 0.320 0.253
35.1 39.2 43.1 47.0 38.3 40.5 43.2 46.9 50.8 54.0 57.4 61.4 66.8 73.3 avy Duty Screened 19.6 21.9 23.0 25.3 27.0 27.7 29.1 31.1 33.7 36.6 40.7	3500 4400 5500 6850 1700 2100 2500 3200 4050 4850 5750 6950 8800 10800 750 950 1200 1600 1850 2100 2400 2400 2750 3350	1650 2000 2400 2900 1200 1400 1600 1950 2300 2650 3050 3550 4300 5250 500 600 650 700 850 900 1000 1200	0.0601 0.0470 0.0366 0.0283 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991 0.0754 0.0601 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991	0.100 0.0778 0.0605 0.0469 1.20 0.868 0.641 0.443 0.320 0.253 0.206 0.164 0.125 0.100 1.20 0.868 0.641 0.443 0.320 0.253
39.2 43.1 47.0 38.3 40.5 43.2 46.9 50.8 54.0 57.4 61.4 66.8 73.3 avy Duty Screened 19.6 21.9 23.0 25.3 27.0 27.7 29.1 31.1 33.7 36.6 40.7	4400 5500 6850 1700 2100 2500 3200 4050 4850 5750 6950 8800 10800 750 950 1200 1600 1850 2100 2400 2750 3350	2000 2400 2900 1200 1400 1600 1950 2300 2650 3050 3550 4300 5250 500 600 650 700 850 900 1000 1200	0.0470 0.0366 0.0283 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991 0.0754 0.0601 0.727 0.524 0.387 0.268 0.193 0.153 0.153 0.124 0.0991	0.0778 0.0605 0.0469 1.20 0.868 0.641 0.443 0.320 0.253 0.206 0.164 0.125 0.100 1.20 0.868 0.641 0.443 0.320
43.1 47.0 38.3 40.5 43.2 46.9 50.8 54.0 57.4 61.4 66.8 73.3 avy Duty Screened 19.6 21.9 23.0 25.3 27.0 27.7 29.1 31.1 33.7 36.6 40.7	5500 6850 1700 2100 2500 3200 4050 4850 5750 6950 8800 10800 750 950 1200 1600 1850 2100 2400 2750 3350	2400 2900 1200 1400 1600 1950 2300 2650 3050 3550 4300 5250 500 600 650 700 850 900 1000 1200	0.0366 0.0283 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991 0.0754 0.0601 0.727 0.524 0.387 0.268 0.193 0.153 0.194 0.0991	0.0605 0.0469 1.20 0.868 0.641 0.443 0.320 0.253 0.206 0.164 0.125 0.100 1.20 0.868 0.641 0.443 0.320 0.253
47.0 38.3 40.5 43.2 46.9 50.8 54.0 57.4 61.4 66.8 73.3 avy Duty Screened 19.6 21.9 23.0 25.3 27.0 27.7 29.1 31.1 33.7 36.6 40.7	6850 1700 2100 2500 3200 4050 4850 5750 6950 8800 10800 750 950 1200 1600 1850 2100 2400 2750 3350	2900 1200 1400 1400 1600 1950 2300 2650 3050 3550 4300 5250 500 600 650 700 850 900 1000 1200	0.0283 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991 0.0754 0.0601 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991	0.0469 1.20 0.868 0.641 0.443 0.320 0.253 0.206 0.164 0.125 0.100 1.20 0.868 0.641 0.443 0.320 0.253
38.3 40.5 43.2 46.9 50.8 54.0 57.4 61.4 66.8 73.3 avy Duty Screened 19.6 21.9 23.0 25.3 27.0 27.7 29.1 31.1 33.7 36.6 40.7	1700 2100 2500 3200 4050 4850 5750 6950 8800 10800 750 950 1200 1600 1850 2100 2400 2750 3350	1200 1400 1600 1950 2300 2650 3050 3550 4300 5250 500 600 650 700 850 900 1000 1200	0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991 0.0754 0.0601 0.727 0.524 0.387 0.268 0.193 0.153 0.153 0.124 0.0991	1.20 0.868 0.641 0.443 0.320 0.253 0.206 0.164 0.125 0.100 1.20 0.868 0.641 0.443 0.320 0.253
40.5 43.2 46.9 50.8 54.0 57.4 61.4 66.8 73.3 avy Duty Screened 19.6 21.9 23.0 25.3 27.0 27.7 29.1 31.1 33.7 36.6 40.7	2100 2500 3200 4050 4850 5750 6950 8800 10800 750 950 1200 1600 1850 2100 2400 2750 3350	1400 1600 1950 2300 2650 3050 3550 4300 5250 500 600 650 700 850 900 1000 1200	0.524 0.387 0.268 0.193 0.153 0.124 0.0991 0.0754 0.0601 0.727 0.524 0.387 0.268 0.193 0.153 0.154 0.0991	0.868 0.641 0.443 0.320 0.253 0.206 0.164 0.125 0.100 1.20 0.868 0.641 0.443 0.320 0.253
43.2 46.9 50.8 54.0 57.4 61.4 66.8 73.3 avy Duty Screened 19.6 21.9 23.0 25.3 27.0 27.7 29.1 31.1 33.7 36.6 40.7	2500 3200 4050 4850 5750 6950 8800 10800 750 950 1200 1600 1850 2100 2400 2750 3350	1600 1950 2300 2650 3050 3550 4300 5250 500 600 650 700 850 900 1000 1200	0.387 0.268 0.193 0.153 0.124 0.0991 0.0754 0.0601 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991	0.641 0.443 0.320 0.253 0.206 0.164 0.125 0.100 1.20 0.868 0.641 0.443 0.320 0.253
46.9 50.8 54.0 57.4 61.4 66.8 73.3 avy Duty Screened 19.6 21.9 23.0 25.3 27.0 27.7 29.1 31.1 33.7 36.6 40.7	3200 4050 4850 5750 6950 8800 10800 750 950 1200 1600 1850 2100 2400 2750 3350	1950 2300 2650 3050 3550 4300 5250 500 600 650 700 850 900 1000 1200	0.268 0.193 0.153 0.124 0.0991 0.0754 0.0601 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991	0.443 0.320 0.253 0.206 0.164 0.125 0.100 1.20 0.868 0.641 0.443 0.320 0.253
50.8 54.0 57.4 61.4 66.8 73.3 avy Duty Screened 19.6 21.9 23.0 25.3 27.0 27.7 29.1 31.1 33.7 36.6 40.7	4050 4850 5750 6950 8800 10800 750 950 1200 1600 1850 2100 2400 2750 3350	2300 2650 3050 3550 4300 5250 500 600 650 700 850 900 1000 1200	0.193 0.153 0.124 0.0991 0.0754 0.0601 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991	0.320 0.253 0.266 0.164 0.125 0.100 1.20 0.868 0.641 0.443 0.320 0.253
54.0 57.4 61.4 66.8 73.3 avy Duty Screened 19.6 21.9 23.0 25.3 27.0 27.7 29.1 31.1 33.7 36.6 40.7	4850 5750 6950 8800 10800 750 950 1200 1600 1850 2100 2400 2750 3350	2650 3050 3550 4300 5250 500 600 650 700 850 900 1000 1200	0.153 0.124 0.0991 0.0754 0.0601 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991	0.253 0.206 0.164 0.125 0.100 1.20 0.868 0.641 0.443 0.320 0.253
57.4 61.4 66.8 73.3 avy Duty Screened 19.6 21.9 23.0 25.3 27.0 27.7 29.1 31.1 33.7 36.6 40.7	5750 6950 8800 10800 750 950 1200 1600 1850 2100 2400 2750 3350	3050 3550 4300 5250 500 600 650 700 850 900 1000 1200	0.124 0.0991 0.0754 0.0601 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991	0.206 0.164 0.125 0.100 1.20 0.868 0.641 0.443 0.320 0.253
61.4 66.8 73.3 avy Duty Screened 19.6 21.9 23.0 25.3 27.0 27.7 29.1 31.1 33.7 36.6 40.7	6950 8800 10800 750 950 1200 1600 1850 2100 2400 2750 3350	3550 4300 5250 500 600 650 700 850 900 1000 1200	0.0991 0.0754 0.0601 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991	0.164 0.125 0.100 1.20 0.868 0.641 0.443 0.320 0.253
66.8 73.3 avy Duty Screened 19.6 21.9 23.0 25.3 27.0 27.7 29.1 31.1 33.7 36.6 40.7	8800 10800 750 950 1200 1600 1850 2100 2400 2750 3350	4300 5250 500 600 650 700 850 900 1000 1200	0.0754 0.0601 0.727 0.524 0.387 0.268 0.193 0.153 0.124	0.125 0.100 1.20 0.868 0.641 0.443 0.320 0.253
73.3 avy Duty Screened 19.6 21.9 23.0 25.3 27.0 27.7 29.1 31.1 33.7 36.6 40.7	750 950 1200 1600 1850 2100 2400 2750 3350	5250 500 600 650 700 850 900 1000 1200	0.0601 0.727 0.524 0.387 0.268 0.193 0.153 0.124 0.0991	0.100 1.20 0.868 0.641 0.443 0.320 0.253
19.6 21.9 23.0 25.3 27.0 27.7 29.1 31.1 33.7 36.6 40.7	750 950 1200 1600 1850 2100 2400 2750 3350	500 600 650 700 850 900 1000 1200	0.727 0.524 0.387 0.268 0.193 0.153 0.124	1.20 0.868 0.641 0.443 0.320 0.253
19.6 21.9 23.0 25.3 27.0 27.7 29.1 31.1 33.7 36.6 40.7	950 1200 1600 1850 2100 2400 2750 3350	600 650 700 850 900 1000	0.524 0.387 0.268 0.193 0.153 0.124 0.0991	0.868 0.641 0.443 0.320 0.253 0.206
21.9 23.0 25.3 27.0 27.7 29.1 31.1 33.7 36.6 40.7	950 1200 1600 1850 2100 2400 2750 3350	600 650 700 850 900 1000	0.524 0.387 0.268 0.193 0.153 0.124 0.0991	0.868 0.641 0.443 0.320 0.253 0.206
23.0 25.3 27.0 27.7 29.1 31.1 33.7 36.6 40.7	1200 1600 1850 2100 2400 2750 3350	650 700 850 900 1000	0.387 0.268 0.193 0.153 0.124 0.0991	0.641 0.443 0.320 0.253 0.206
25.3 27.0 27.7 29.1 31.1 33.7 36.6 40.7	1600 1850 2100 2400 2750 3350	700 850 900 1000 1200	0.268 0.193 0.153 0.124 0.0991	0.443 0.320 0.253 0.206
27.0 27.7 29.1 31.1 33.7 36.6 40.7	1850 2100 2400 2750 3350	850 900 1000 1200	0.193 0.153 0.124 0.0991	0.320 0.253 0.206
27.7 29.1 31.1 33.7 36.6 40.7	2100 2400 2750 3350	900 1000 1200	0.153 0.124 0.0991	0.253 0.206
29.1 31.1 33.7 36.6 40.7	2400 2750 3350	1000 1200	0.124 0.0991	0.206
31.1 33.7 36.6 40.7	2750 3350	1200	0.0991	
33.7 36.6 40.7	3350			0.164
36.6 40.7				0 405
40.7				0.125
	3950	1650	0.0601	0.100
44.4	4850	2000	0.0470	0.0778
44.4	5950	2400	0.0366	0.0605
48.3 38.3	7300 1750	2900 1200	0.0283 0.727	0.0469 1.20
40.5	2200	1450	0.524	0.868
				0.641
				0.443 0.320
				0.320
				0.206
				0.206
				0.164
				0.123
	1120	3000	0.0001	0.100
	750	EEO	0.727	1.20
				0.868
				0.641
				0.641
				0.320
				0.253
				0.206
				0.164
				0.125
				0.100
				0.0778
				0.0605
				0.0469
				1.20
				0.868
				0.641
51.2	3450			0.443
			0.102	0.320
55.1 58.3	4400 5200	2650	0.153	0.253
	43.2 46.9 51.0 54.2 57.4 61.4 67.0 73.3 6.35/11(12)kV ht Duty Screened 21.4 22.4 23.5 25.1 26.8 28.2 29.8 31.6 34.0 36.7 40.4 43.7 47.6 42.6 44.6 47.3 51.2	43.2 2750 46.9 3600 51.0 4500 51.0 4500 54.2 5300 67.4 6150 61.4 7350 67.0 9200 73.3 1120 6.35/11(12)kV htt Duty Screened 21.4 750 22.4 850 23.5 1000 25.1 1200 26.8 1500 28.2 1750 29.8 2000 31.6 2400 34.0 2950 36.7 3600 40.4 4450 43.7 5550 47.6 6900 42.6 1950 44.6 2300 47.3 2700 51.2 3450	43.2 2750 1700 46.9 3600 2150 51.0 4500 2700 54.2 5300 3050 57.4 6150 3450 61.4 7350 3950 67.0 9200 4700 73.3 1120 5600 6.35/11(12)kV htt Duty Screened 21.4 750 550 22.4 850 650 23.5 1000 700 25.1 1200 800 26.8 1500 900 28.2 1750 1000 29.8 2000 1100 31.6 2400 1250 34.0 2950 1500 36.7 3600 1750 40.4 4450 2100 43.7 5550 2450 47.6 6900 2950 42.6 1950 1400 44.6 2300 1600 47.3 2700 1850 51.2 3450 2200	43.2 2750 1700 0.387 46.9 3600 2150 0.268 51.0 4500 2700 0.193 54.2 5300 3050 0.153 57.4 6150 3450 0.124 61.4 7350 3950 0.0991 67.0 9200 4700 0.0754 73.3 1120 5600 0.0601 6.35/11(12)kV htt Duty Screened 21.4 750 550 0.727 22.4 850 650 0.524 23.5 1000 700 0.387 25.1 1200 800 0.268 26.8 1500 900 0.193 28.2 1750 1000 0.153 29.8 2000 1100 0.153 29.8 2000 1100 0.124 31.6 2400 1250 0.0991 34.0 2950 1500 0.0754 36.7 3600 1750 0.0601 40.4 4450 2100 0.0727 43.6 2950 1500 0.0727 44.6 6900 2950 0.0283 42.6 1950 1400 0.727 44.6 6900 2950 0.0283 42.6 1950 1400 0.727 44.6 2300 1600 0.524 47.3 2700 1850 0.387 51.2 3450 2200 0.268





AS NZS 1429.1 Conductor: Copper/Aluminum Conductor Screen: Semi-Conductive Compound

Insulation: XLPE

00000 Insulation Screen: Semi-Conductive Compound

Metallic Screen: Copper Wire Sheath: PVC

Section	Insulation Thickness	Sheath Thickness	Overall Diameter	Cable 1	A CONTRACTOR OF THE PARTY OF TH	DC. Electrical Re	
No.xmm ²	mm	mm	mm	Cu ka	'km	Cu O/	km Al
			6.35/11(12)kV	N9/	NII	**/	KIII
			Light Duty Screened				
3x185	3.4	2.9	65.5	7300	3900	0.0991	0.164
3x240	3.4	3.1	70.6	9150	4650	0.0754	0.125
3x300	3.4	3.2	76.3	11100	5500	0.0601	0.100
			Heavy Duty Screened				
1x25	3.4	1.8	21.4	800	550	0.727	1.20
1x35	3.4	1.8	23.7	1000	650	0.524	0.868
1×50	3.4	1.8	24.8	1250	800	0.387	0.641
1x70	3.4	1.8	27.1	1650	1000	0.268	0.443
1x95	3.4	1.8	28.1	1950	1300	0.193	0.320
1x120	3.4	1.8	29.5	2200	1450	0.153	0.253
1x150	3.4	1.8	31.1	2450	1550	0.124	0.206
1x185	3.4	1.9	32.9	2850	1700	0.0991	0.164
1x240	3.4	2.0	35.3	3400	1950	0.0754	0.125
1x300	3.4	2.0	38.0	4050	2200	0.0601	0.100
1x400	3.4	2.2	41.7	4950	2550	0.0470	0.0778
1x500	3.4	2.2	45.0	6000	2900	0.0366	0.060
1x630	3.4	2.4	48.9	7350	3400	0.0283	0.0469
3x25	3.4	2.2	42.6	1950	1450	0.727	1.20
3x35	3.4	2.3	44.8	2450	1650	0.524	0.868
3x50	3.4	2.4	47.5	3000	1950	0.387	0.641
3x70	3.4	2.5	51.2	3900	2400	0.268	0.443
3x95	3.4	2.6	55.1	4800	3000	0.193	0.320
3x120	3.4	2.7	58.3	5600	3350	0.153	0.253
3x150	3.4	2.8	61.5	6450	3750	0.124	0.206
3x185	3.4	3.0	65.5	7650	4250	0.0991	0.164
3x240	3.4	3.1	70.6	9450	5000	0.0754	0.125
3x300	3.4	3.3	76.3	11400	5850	0.0601	0.100
			12.7/22(14)kV				
			Light Duty Screened				
1x35	5.5	1.8	26.6	1000	800	0.524	0.868
1×50	5.5	1.8	27.7	1150	850	0.387	0.641
1x70	5.5	1.8	29.5	1400	950	0.268	0.443
1x95	5.5	1.9	31.2	1650	1100	0.193	0.320
1x120	5.5	1.9	32.8	1950	1200	0.153	0.253
1x150	5.5	2.0	34.2	2250	1300	0.124	0.206
1x185	5.5	2.0	36.2	2650	1500	0.0991	0.164
1x240	5.5	2.1	38.4	3200	1700	0.0754	0.125
1x300	5.5	2.2	41.1	3850	2000	0.0601	0.100
1x400	5.5	2.3	44.8	4750	2350	0.0470	0.0778
1x500	5.5	2.4	48.1	5850	2750	0.0366	0.060
1x630	5.5	2.5	52.0	7250	3300	0.0283	0.0469
3x35	5.5	2.6	54.5	3000	2300	0.524	0.868
3×50	5.5	2.7	57.1	3400	2550	0.387	0.641
3x70	5.5	2.8	60.9	4200	2950	0.268	0.443
3x95	5.5	2.9	64.7	5150	3400	0.193	0.320
3x120	5.5	3.0	68.0	6050	3800	0.153	0.253
3x150	5.5	3.1	71.2	6900	4200	0.124	0.206
3x185	5.5	3.3	75.1	8200	4800	0.0991	0.164
3x240	5.5	3.4	80.3	10100	5650	0.0754	0.125
3x300	5.5	3.5	86.2	12200	6600	0.0601	0.100
		11500000	Heavy Duty Screened				
1x35	5.5	1.8	27.9	1150	800	0.524	0.868
1x50	5.5	1.8	29.0	1400	950	0.387	0.641
1x70	5.5	1.8	30.8	1850	1200	0.268	0.443
1x95	5.5	1.9	32.5	2150	1500	0.193	0.320
1x120	5.5	1.9		2400	1650	0.153	
			34.1				0.253
1x150	5.5	2.0	35.5	2700	1800	0.124	0.206
1x185	5.5	2.1	37.5	3100	1950	0.0991	0.164
1x240	5.5	2.1	39.9	3700	2200	0.0754	0.125
1x300	5.5	2.2	42.4	4300	2450	0.0601	0.100
1x400	5.5	2.3	46.3	5250	2850	0.0470	0.0778
1x500	5.5	2.4	49.4	6300	3200	0.0366	0.060
1x630	5.5	2.5	53.5	7700	3750	0.0283	0.0469
3x35	5.5	2.6	54.5	3100	2300	0.524	0.868
3x50	5.5	2.7	57.1	3600	2600	0.387	0.641
3x70	5.5	2.8	60.9	4550	3100	0.268	0.443
3x95	5.5	2.9	64.7	5500	3700	0.193	0.320
3x120	5.5	3.0	68.0	6400	4150	0.153	0.253
3x150	5.5	3.1	71.2	7250	4550	0.124	0.206
3x185	5.5	3.3	75.1	8500	5100	0.0991	0.200
	J.J	3.3	r J. I	0300	3100	0.0331	0.104
3x240	5.5	3.4	80.3	10400	5900	0.0754	0.125





AS NZS 1429.1
Conductor: Copper/Aluminum
Conductor Screen: Semi-Conductive Compound

Insulation: XLPE

00000 Insulation Screen: Semi-Conductive Compound

Metallic Screen: Copper Wire Sheath: PVC

Section	Insulation Thickness	Sheath Thickness	Overall Diameter		Weight	DC. Electrical Re	
No.xmm²	mm	mm	mm	Cu	Al	Cu	Al
nnessonnist.	10000000	100000	40.02050114	kg,	/km	Ω	'km
			19/33(36)kV				
	722		Light Duty Screened	1122		72.2.2.2.2	
1x50	8.0	1.9	33.1	1400	1100	0.387	0.641
1x70	8.0	2.0	34.7	1650	1200	0.268	0.443
1x95	8.0	2.0	36.6	1950	1350	0.193	0.320
1x120	8.0	2.1	38.0	2250	1500	0.153	0.253
1x150	8.0	2.1	39.6	2550	1650	0.124	0.206
1x185	8.0	2.2	41.4	2950	1800	0.0991	0.164
1x240	8.0	2.3	43.8	3550	2050	0.0754	0.125
1x300	8.0	2.3	46.5	4200	2350	0.0601	0.100
1x400	8.0	2.4	50.2	5150	2750	0.0470	0.0778
1x500	8.0	2.5	53.5	6250	3200	0.0366	0.0605
1x630	8.0	2.6	57.4	7700	3750	0.0283	0.0469
3x50	8.0	3.1	68.5	4350	3500	0.387	0.641
3x70	8.0	3.2	72.4	5250	4000	0.268	0.443
3x95	8.0	3.3	76.3	6200	4450	0.193	0.320
3x120	8.0	3.4	79.5	7150	4900	0.153	0.253
3x150	8.0	3.5	82.7	8100	5350	0.124	0.206
3x185	8.0	3.6	86.7	9400	6000	0.0991	0.164
3x240	8.0	3.8	91.8	11400	6900	0.0754	0.125
3x300	8.0	3.9	97.6	13500	7950	0.0601	0.100
			Heavy Duty Screened				
1x50	8.0	2.0	34.4	1650	1250	0.387	0.641
1x70	8.0	2.0	36.2	2100	1500	0.268	0.443
1x95	8.0	2.1	37.9	2400	1750	0.193	0.320
1x120	8.0	2.1	39.5	2700	1950	0.153	0.253
1x150	8.0	2.2	40.9	3000	2100	0.124	0.206
1x185	8.0	2.2	42.9	3400	2300	0.0991	0.164
1x240	8.0	2.3	45.1	4000	2500	0.0754	0.125
1x300	8.0	2.4	47.8	4650	2800	0.0601	0.100
1x400	8.0	2.5	51.5	5600	3200	0.0470	0.0778
1x500	8.0	2.6	54.8	6750	3650	0.0366	0.0605
1x630	8.0	2.7	58.7	8150	4200	0.0283	0.0469
3x50	8.0	3.1	68.7	4550	3550	0.387	0.641
3x70	8.0	3.2	72.4	5600	4100	0.268	0.443
3x95	8.0	3.3	76.3	6550	4700	0.193	0.320
3x120	8.0	3.4	79.5	7450	5200	0.153	0.253
3x150	8.0	3.5	82.7	8400	5650	0.124	0.233
3x185	8.0	3.7	86.7	9700	6300	0.0991	0.206
3x240	8.0	3.8	91.8	11600	7150	0.0754	0.164
3x300	8.0	4.0	97.6	13800	8200	0.0754	0.125





CU(AL)/SCR/XLPE/SCR/(CWS)/CTS/PVC/SSTA/PVC 3.6/6(7.2) ~ 26/35(40.5) kV

Standards

- AS/NZS 1429.1
- HD 620
- IEC 60502-2
- DIN VDE 0276-620

Application

The cable is designed for distribution of electrical power with nominal voltage Uo/U(Um) ranging from 3.6/6(7.2)kV to 26/35(40.5)kV and frequency 50Hz. It is suitable for installation mostly in power supply stations, in doors and in cable ducts, outdoors, underground and in water as well as for installation on cable trays for industries, switchboards and power stations.

AS/NZS 1429.1

- Conductor: Copper/Aluminum
- Conductor Screen: Semi-Conductive Compound
- Insulation: XLPE
- Insulation Screen: Semi-Conductive Compound
- Metallic Screen: Copper Wire(Optional)/Copper Tape
- Bedding: PVC
- Armour: Double Layer Stainless Steel Tape
- Sheath: PVC/PE(Optional)
- o (Optional) Flame Retardant Property
- (Optional) Fire Resistant Property
- (Optional) Anti-Termite & Rodent Property
- o (Optional) Water Resistant Property

No.xmm	insu	insulatio	n Thickne	ess	Sheath	Thickness	Ove	rall Diameter			le Weight	D		rical Resistar	
1425		1	mm			mm		mm	C		Al ra/km		Cu	O/km	Al
1225							3.6/6(7.2)kV, 3.8/6.6(7.2)k\	/	, and	у, ки			22/ Kill	
135			2.5			1.8				00	550	(0.727		1.20
1850															0.868
17/0															0.641
1855 2.5															0.443
Table 19															0.320
1x150															0.253
1x185															0.206
1x240															0.164
1x300 2.8 2.2 38.7 3810 1990 0.0601 1x400 3.0 2.3 4.25 4840 2420 0.0470 1x500 3.2 2.4 46.3 5860 2830 0.0366 1x630 3.2 2.6 50.0 7200 3380 0.0283 (F/10(12)KV, 6.35/11(12)kV (F/10(12)KV, 6.35/11(112)kV (F/10(12)KV, 6.35/11(12)kV (F/10(12)KV, 1.25/11(12)kV (F/10(12)KV, 1.25/11(12)kV <td></td> <td>0.125</td>															0.125
1x400 3.0 2.3 42.5 4840 2420 0.0470 1x500 3.2 2.4 46.3 5860 2830 0.0366 1x630 3.2 2.6 50.0 7200 3380 0.0283 6/10(1z)kV, 6.35/11(1z)kV 1x25 3.4 1.8 23.2 1011 860 0.727 1x55 3.4 1.8 24.1 1150 .955 0.524 1x50 3.4 1.8 25.2 1332 1031 0.387 1x70 3.4 1.8 26.8 1566 1155 0.268 1x95 3.4 1.9 28.5 1911 1328 0.193 1x120 3.4 2.0 30.1 2482 1745 0.153 1x150 3.4 2.0 30.1 2482 1745 0.153 1x185 3.4 2.1 33.4 3207 2101 0.0991 1x240 3.4															0.100
1x500 3.2 2.6 50.0 720 330 0.0366 1x630 3.2 2.6 50.0 7200 3380 0.0283 (F/10(12)kV, 6.35/11(12)kV 1x25 3.4 1.8 23.2 1011 860 0.727 1x35 3.4 1.8 23.2 1011 860 0.727 1x50 3.4 1.8 25.2 1322 1031 0.387 1x70 3.4 1.8 26.8 1566 1155 0.268 1x95 3.4 1.9 2.85 1911 1328 0.193 1x120 3.4 2.0 30.1 2482 1745 0.153 1x150 3.4 2.0 31.7 2848 1921 0.124 1x185 3.4 2.1 33.4 32.7 2101 0.0991 1x240 3.4 2.2 37.1 3813 2265 0.0754 1x300 3.4 2.2 <td></td> <td>0.077</td>															0.077
1x690 3.2 2.6 5.00 7200 3380 0.0283 1x25 3.4 1.8 23.2 1011 860 0.727 1x35 3.4 1.8 24.1 1150 935 0.524 1x50 3.4 1.8 26.8 1566 1155 0.268 1x95 3.4 1.9 28.5 1911 1328 0.193 1x120 3.4 2.0 30.1 2482 1745 0.153 1x150 3.4 2.0 30.1 2482 1745 0.153 1x150 3.4 2.0 30.1 2482 1745 0.153 1x150 3.4 2.0 31.7 2848 1921 0.124 1x185 3.4 2.1 33.4 3207 2101 0.0991 1x240 3.4 2.2 39.5 4573 2715 0.0601 1x400 3.4 2.2 39.5 4573 2715															0.060
f6/10(12)kV, 6.35/11(12)kV 1x25 3.4 1.8 23.2 1011 860 0.727 1x35 3.4 1.8 24.1 1150 935 0.524 1x50 3.4 1.8 25.2 1322 1031 0.387 1x70 3.4 1.8 26.8 1566 1155 0.268 1x95 3.4 1.9 28.5 1911 1328 0.193 1x120 3.4 2.0 30.1 2482 1745 0.153 1x150 3.4 2.0 31.7 2848 1921 0.124 1x185 3.4 2.1 33.4 3207 2101 0.0991 1x240 3.4 2.2 37.1 3813 2365 0.0754 1x300 3.4 2.2 39.5 4573 2715 0.0601 1x400 3.4 2.5 46.3 6812 3715 0.0601 1x500 3.4 2.6<															0.046
1x25 3.4 1.8 23.2 1011 860 0.727 1x55 3.4 1.8 24.1 1150 935 0.524 1x50 3.4 1.8 25.2 1322 1031 0.387 1x70 3.4 1.8 26.8 1566 1155 0.268 1x95 3.4 1.9 28.5 1911 1328 0.193 1x120 3.4 2.0 30.1 2482 1745 0.153 1x150 3.4 2.0 31.7 2848 1921 0.124 1x185 3.4 2.1 33.4 3207 2101 0.0991 1x240 3.4 2.2 37.1 3813 2365 0.0754 1x200 3.4 2.2 39.5 4573 2715 0.0601 1x400 3.4 2.2 39.5 4573 2715 0.0601 1x630 3.4 2.5 46.3 6812 3715			A. 1785				6/10(12)						d deduction of		7.17.0.7
1x35 3.4 1.8 24.1 1150 935 0.524 1x50 3.4 1.8 25.2 1322 1031 0.387 1x70 3.4 1.8 26.8 1566 1155 0.268 1x95 3.4 1.9 28.5 1911 1328 0.193 1x120 3.4 2.0 30.1 2482 1745 0.153 1x150 3.4 2.0 31.7 2848 1921 0.124 1x185 3.4 2.1 33.4 3207 2101 0.0991 1x240 3.4 2.2 37.1 3813 2365 0.0754 1x300 3.4 2.2 39.5 4573 2715 0.0601 1x600 3.4 2.2 39.5 4573 2715 0.0601 1x630 3.4 2.5 46.3 6812 3715 0.0366 1x630 3.4 2.6 50.2 8159 4288			3.4			1.8				11	860	(0.727		1.20
1x50 3.4 1.8 25.2 1322 1031 0.387 1x70 3.4 1.8 26.8 1566 1155 0.268 1x95 3.4 1.9 28.5 1911 1328 0.193 1x120 3.4 2.0 30.1 2482 1745 0.153 1x150 3.4 2.0 31.7 2848 1921 0.124 1x185 3.4 2.1 33.4 3207 2101 0.0991 1x240 3.4 2.2 37.1 3813 2365 0.0754 1x200 3.4 2.2 39.5 4573 2715 0.0601 1x400 3.4 2.2 39.5 4573 2715 0.0601 1x400 3.4 2.5 46.3 6812 3715 0.0566 1x500 3.4 2.6 50.2 8159 4288 0.0283 1x630 3.4 2.6 50.2 8159 4288 <td></td> <td>0.868</td>															0.868
1x70 3.4 1.8 26.8 1566 1155 0.268 1x95 3.4 1.9 28.5 1911 1328 0.193 1x120 3.4 2.0 30.1 2482 1745 0.153 1x150 3.4 2.0 31.7 2848 1921 0.124 1x185 3.4 2.1 33.4 3207 2101 0.0991 1x240 3.4 2.2 37.1 3813 2365 0.0754 1x300 3.4 2.2 39.5 4573 2715 0.0601 1x400 3.4 2.2 39.5 4573 2715 0.0601 1x400 3.4 2.5 46.3 6812 3715 0.0366 1x500 3.4 2.6 50.2 8159 4288 0.0283 1x25 4.5 1.8 25.6 919 769 0.727 1x35 4.5 1.8 27.9 1219 929															0.641
1x95 3.4 1.9 28.5 1911 1328 0.193 1x120 3.4 2.0 30.1 2482 1745 0.153 1x150 3.4 2.0 31.7 2848 1921 0.124 1x185 3.4 2.1 33.4 3207 2101 0.0991 1x240 3.4 2.2 37.1 3813 2365 0.0754 1x300 3.4 2.2 39.5 4573 2715 0.0601 1x400 3.4 2.3 42.7 5573 3159 0.0470 1x500 3.4 2.5 46.3 6812 3715 0.0366 1x630 3.4 2.6 50.2 8159 4288 0.0283 1x25 4.5 1.8 25.6 919 769 0.727 1x35 4.5 1.8 25.6 1919 769 0.727 1x35 4.5 1.8 25.6 1919 929															0.443
1x120 3.4 2.0 30.1 2482 1745 0.153 1x150 3.4 2.0 31.7 2848 1921 0.124 1x185 3.4 2.1 33.4 3207 2101 0.0991 1x240 3.4 2.2 37.1 3813 2365 0.0754 1x300 3.4 2.2 39.5 4573 2715 0.0601 1x400 3.4 2.3 42.7 5573 3159 0.0470 1x500 3.4 2.5 46.3 6812 3715 0.0366 1x630 3.4 2.5 46.3 6812 3715 0.0366 1x630 3.4 2.6 50.2 8159 4288 0.0283 1x620 3.4 2.6 50.2 8159 4288 0.0283 1x25 4.5 1.8 25.6 919 769 0.727 1x25 4.5 1.8 27.9 1219 929 <td></td> <td>0.320</td>															0.320
1x150 3.4 2.0 31.7 2848 1921 0.124 1x185 3.4 2.1 33.4 3207 2101 0.0991 1x240 3.4 2.2 37.1 3813 2365 0.0754 1x300 3.4 2.2 39.5 4573 2715 0.0601 1x400 3.4 2.3 42.7 5573 3159 0.0470 1x500 3.4 2.5 46.3 6812 3715 0.0366 1x630 3.4 2.6 50.2 8159 4288 0.0283 1x630 3.4 2.6 50.2 8159 4288 0.0283 1x630 3.4 2.6 50.2 8159 4288 0.0283 1x55 4.5 1.8 2.56 919 769 0.727 1x35 4.5 1.8 2.66 1055 840 0.524 1x50 4.5 1.8 2.79 1219 929															0.253
1x185 3.4 2.1 33.4 3207 2101 0.0991 1x240 3.4 2.2 37.1 3813 2365 0.0754 1x300 3.4 2.2 39.5 4573 2715 0.0601 1x400 3.4 2.3 42.7 5573 3159 0.0470 1x500 3.4 2.5 46.3 6812 3715 0.0366 1x630 3.4 2.6 50.2 8159 4288 0.0283 ***Excess of the colspan="6">***Excess of the colspan="6">**Excess of t															0.206
1x240 3.4 2.2 37.1 3813 2365 0.0754 1x300 3.4 2.2 39.5 4573 2715 0.0601 1x400 3.4 2.3 42.7 5573 3159 0.0470 1x500 3.4 2.5 46.3 6812 3715 0.0366 1x630 3.4 2.6 50.2 8159 4288 0.0283 1x630 4.5 1.8 25.6 919 769 0.727 1x35 4.5 1.8 25.6 199 769 0.727 1x35 4.5 1.8 27.9 1219 929 0.387 1x70 4.5 1.8 27.9 1219 929															0.164
1x300 3.4 2.2 39.5 4573 2715 0.0601 1x400 3.4 2.3 42.7 5573 3159 0.0470 1x500 3.4 2.5 46.3 6812 3715 0.0366 1x630 3.4 2.6 50.2 8159 428 0.0283 8.7/15(17.5)kV 1x25 4.5 1.8 25.6 919 769 0.727 1x35 4.5 1.8 26.6 1055 840 0.524 1x50 4.5 1.8 27.9 1219 929 0.387 1x70 4.5 1.9 30.8 1458 1047 0.268 1x95 4.5 2.0 32.7 1780 1197 0.193 1x120 4.5 2.0 34.1 2312 1575 0.153 1x150 4.5 2.1 35.9 2670 1743 0.124 1x240 4.5 2.2 <t< td=""><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td>0.125</td></t<>															0.125
1x400 3.4 2.3 42.7 5573 3159 0.0470 1x500 3.4 2.5 46.3 6812 3715 0.0366 1x630 3.4 2.6 50.2 8159 4288 0.0283 8.7/15(17.5)kV 1x25 4.5 1.8 27.6 919 769 0.727 1x35 4.5 1.8 26.6 1055 840 0.524 1x50 4.5 1.8 27.9 1219 929 0.387 1x70 4.5 1.9 30.8 1458 1047 0.268 1x95 4.5 2.0 32.7 1780 1197 0.193 1x120 4.5 2.0 34.1 2312 1575 0.153 1x150 4.5 2.1 35.9 2670 1743 0.124 1x85 4.5 2.2 37.6 3007 1901 0.0991 1x240 4.5 2.3 <td></td> <td>0.100</td>															0.100
1x500 3.4 2.5 46.3 6812 3715 0.0366 1x630 3.4 2.6 50.2 8159 4288 0.0283 8.7/15(17.5)kV 1x25 4.5 1.8 25.6 919 769 0.727 1x35 4.5 1.8 26.6 1055 840 0.524 1x50 4.5 1.8 27.9 1219 929 0.387 1x70 4.5 1.9 30.8 1458 1047 0.268 1x95 4.5 2.0 32.7 1780 1197 0.193 1x120 4.5 2.0 34.1 2312 1575 0.153 1x150 4.5 2.1 35.9 2670 1743 0.124 1x85 4.5 2.2 37.6 3007 1901 0.0991 1x240 4.5 2.2 39.9 3621 2173 0.0754 1x300 4.5 2.3 <td></td> <td>0.077</td>															0.077
1x630 3.4 2.6 50.2 8159 4288 0.0283 8.7/15(17.5)kV 1x25 4.5 1.8 25.6 919 769 0.727 1x35 4.5 1.8 26.6 1055 840 0.524 1x50 4.5 1.8 27.9 1219 929 0.387 1x70 4.5 1.9 30.8 1458 1047 0.268 1x95 4.5 2.0 32.7 1780 1197 0.193 1x120 4.5 2.0 34.1 2312 1575 0.153 1x150 4.5 2.1 35.9 2670 1743 0.124 1x185 4.5 2.2 37.6 3007 1901 0.0991 1x240 4.5 2.2 39.9 3621 2173 0.0754 1x300 4.5 2.3 42.5 4330 2470 0.0601 1x400 4.5 2.4 <															0.060
1x25 4.5 1.8 25.6 919 769 0.727 1x35 4.5 1.8 26.6 1055 840 0.524 1x50 4.5 1.8 27.9 1219 929 0.387 1x70 4.5 1.9 30.8 1458 1047 0.268 1x95 4.5 2.0 32.7 1780 1197 0.193 1x120 4.5 2.0 34.1 2312 1575 0.153 1x150 4.5 2.1 35.9 2670 1743 0.124 1x185 4.5 2.2 37.6 3007 1901 0.0991 1x240 4.5 2.2 39.9 3621 2173 0.0754 1x300 4.5 2.3 42.5 4330 2470 0.0601 1x400 4.5 2.4 45.7 5281 2866 0.0470 1x500 4.5 2.5 49.4 6442 334															0.046
1x25 4.5 1.8 25.6 919 769 0.727 1x35 4.5 1.8 26.6 1055 840 0.524 1x50 4.5 1.8 27.9 1219 929 0.387 1x70 4.5 1.9 30.8 1458 1047 0.268 1x95 4.5 2.0 32.7 1780 1197 0.193 1x120 4.5 2.0 34.1 2312 1575 0.153 1x150 4.5 2.1 35.9 2670 1743 0.124 1x185 4.5 2.2 37.6 3007 1901 0.0991 1x240 4.5 2.2 37.6 3007 1901 0.0991 1x240 4.5 2.2 39.9 3621 2173 0.0754 1x300 4.5 2.3 42.5 4330 2470 0.0601 1x400 4.5 2.4 45.7 5281 2866						2.0	8.7		0,	-	1200				0.040
1x35 4.5 1.8 26.6 1055 840 0.524 1x50 4.5 1.8 27.9 1219 929 0.387 1x70 4.5 1.9 30.8 1458 1047 0.268 1x95 4.5 2.0 32.7 1780 1197 0.193 1x120 4.5 2.0 34.1 2312 1575 0.153 1x150 4.5 2.1 35.9 2670 1743 0.124 1x85 4.5 2.2 37.6 3007 1901 0.0991 1x240 4.5 2.2 39.9 3621 2173 0.0754 1x300 4.5 2.3 42.5 4330 2470 0.0601 1x400 4.5 2.4 45.7 5281 2866 0.0470 1x630 4.5 2.5 49.4 6442 3345 0.0366 1x630 4.5 2.7 53.4 7766 3895			4.5			1.8			91	19	769	(0.727		1.20
1x50 4.5 1.8 27.9 1219 929 0.387 1x70 4.5 1.9 30.8 1458 1047 0.268 1x95 4.5 2.0 32.7 1780 1197 0.193 1x120 4.5 2.0 34.1 2312 1575 0.153 1x150 4.5 2.1 35.9 2670 1743 0.124 1x185 4.5 2.2 37.6 3007 1901 0.0991 1x240 4.5 2.2 39.9 3621 2173 0.0754 1x300 4.5 2.3 42.5 4330 2470 0.0601 1x400 4.5 2.4 45.7 5281 2866 0.0470 1x500 4.5 2.5 49.4 6442 3345 0.0366 1x630 4.5 2.7 53.4 7766 3895 0.0283 1x630 4.5 2.7 53.4 7766 3895															0.868
1x70 4.5 1.9 30.8 1458 1047 0.268 1x95 4.5 2.0 32.7 1780 1197 0.193 1x120 4.5 2.0 34.1 2312 1575 0.153 1x150 4.5 2.1 35.9 2670 1743 0.124 1x185 4.5 2.2 37.6 3007 1901 0.0991 1x240 4.5 2.2 39.9 3621 2173 0.0754 1x300 4.5 2.3 42.5 4330 2470 0.0601 1x400 4.5 2.4 45.7 5281 2866 0.0470 1x500 4.5 2.5 49.4 6442 3345 0.0366 1x630 4.5 2.7 53.4 7766 3895 0.0283 1x630 4.5 2.7 53.4 7766 3895 0.0283 1x35 5.5 1.9 30.1 1410 1200 <td></td> <td>0.641</td>															0.641
1x95 4.5 2.0 32.7 1780 1197 0.193 1x120 4.5 2.0 34.1 2312 1575 0.153 1x150 4.5 2.1 35.9 2670 1743 0.124 1x185 4.5 2.2 37.6 3007 1901 0.0991 1x240 4.5 2.2 39.9 3621 2173 0.0754 1x300 4.5 2.3 42.5 4330 2470 0.0601 1x400 4.5 2.4 45.7 5281 2866 0.0470 1x500 4.5 2.5 49.4 6442 3345 0.0366 1x630 4.5 2.7 53.4 7766 385 0.0283 1x35 5.5 1.9 30.1 1410 1200 0.524															0.443
1x120 4.5 2.0 34.1 2312 1575 0.153 1x150 4.5 2.1 35.9 2670 1743 0.124 1x185 4.5 2.2 37.6 3007 1901 0.0991 1x240 4.5 2.2 39.9 3621 2173 0.0754 1x300 4.5 2.3 42.5 4330 2470 0.0601 1x400 4.5 2.4 45.7 5281 2866 0.0470 1x500 4.5 2.5 49.4 6442 3345 0.0366 1x630 4.5 2.7 53.4 7766 3895 0.0283 12/20(24)kV, 12.7/22(24)kV 1x35 5.5 1.9 30.1 1410 1200 0.524															0.320
1x150 4.5 2.1 35.9 2670 1743 0.124 1x185 4.5 2.2 37.6 3007 1901 0.0991 1x240 4.5 2.2 39.9 3621 2173 0.0754 1x300 4.5 2.3 42.5 4330 2470 0.0601 1x400 4.5 2.4 45.7 5281 2866 0.0470 1x500 4.5 2.5 49.4 6442 3345 0.0366 1x630 4.5 2.7 53.4 7766 3895 0.0283 12/20(24)kV, 12.7/22(24)kV 1x35 5.5 1.9 30.1 1410 1200 0.524															0.253
1x185 4.5 2.2 37.6 3007 1901 0.0991 1x240 4.5 2.2 39.9 3621 2173 0.0754 1x300 4.5 2.3 42.5 4330 2470 0.0601 1x400 4.5 2.4 45.7 5281 2866 0.0470 1x500 4.5 2.5 49.4 6442 3345 0.0366 1x630 4.5 2.7 53.4 7766 3895 0.0283 1x35 5.5 1.9 30.1 1410 1200 0.524															0.206
1x240 4.5 2.2 39.9 3621 2173 0.0754 1x300 4.5 2.3 42.5 4330 2470 0.0601 1x400 4.5 2.4 45.7 5281 2866 0.0470 1x500 4.5 2.5 49.4 6442 3345 0.0366 1x630 4.5 2.7 53.4 7766 3895 0.0283 1x2/20(24)kV, 12:7/22(24)kV 12/20(24)kV, 12:7/22(24)kV 1410 1200 0.524															0.164
1x300 4.5 2.3 42.5 4330 2470 0.0601 1x400 4.5 2.4 45.7 5281 2866 0.0470 1x500 4.5 2.5 49.4 6442 3345 0.0366 1x630 4.5 2.7 53.4 7766 3895 0.0283 12/20(24)kV, 12.7/22(24)kV 1x35 5.5 1.9 30.1 1410 1200 0.524															0.125
1x400 4.5 2.4 45.7 5281 2866 0.0470 1x500 4.5 2.5 49.4 6442 3345 0.0366 1x630 4.5 2.7 53.4 7766 3895 0.0283 12/20(24)kV, 12.7/22(24)kV 1x35 5.5 1.9 30.1 1410 1200 0.524															0.123
1x500 4.5 2.5 49.4 6442 3345 0.0366 1x630 4.5 2.7 53.4 7766 3895 0.0283 12/20(24)kV, 12.7/22(24)kV 1x35 5.5 1.9 30.1 1410 1200 0.524															0.077
1x630 4.5 2.7 53.4 7766 3895 0.0283 12/20(24)kV, 12.7/22(24)kV 1x35 5.5 1.9 30.1 1410 1200 0.524															0.060
12/20(24)kV, 12.7/22(24)kV 1x35 5.5 1.9 30.1 1410 1200 0.524															0.046
1x35 5.5 1.9 30.1 1410 1200 0.524							12/20(24			55	3033	0	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,		0.040
			5.5			19				10	1200		0 524		0.868
1,50 5.5 1.5 1.50 0.507															0.641
1x70 5.5 2.0 33.1 1890 1460 0.268															0.443







• Conductor: Copper/Aluminum

• Conductor Screen: Semi-Conductive Compound

Insulation: XLPE

Insulation Screen: Semi-Conductive CompoundMetallic Screen: Copper Wire(Optional)/Copper Tape

Bedding: PVC

• Armour: Double Layer Stainless Steel Tape

Section	Insulation Thickness	Sheath Thickness	Overall Diameter	Cable	Weight	DC. Electrical Re	esistance at 20°C
No.xmm ²	mm	mm	mm	Cu	Al	Cu	Al
NO.XIIIII	tinit.	3000	All III	kg	/km	Ω/	km
			12/20(24)kV, 12.7/22(24)kV				
1x95	5.5	2.1	34.9	2210	1640	0.193	0.320
1x120	5.5	2.1	36.4	2510	1780	0.153	0.253
1x150	5.5	2.2	38.1	2880	1970	0.124	0.206
1x185	5.5	2.2	39.7	3270	2150	0.0991	0.164
1x240	5.5	2.3	42.1	3900	2440	0.0754	0.125
1x300	5.5	2.4	44.7	4590	2770	0.0601	0.100
1x400	5.5	2.5	48.1	5670	3250	0.0470	0.0778
1x500	5.5	2.6	51.4	6760	3730	0.0366	0.0605
1x630	5.5	2.7	55.2	8150	4320	0.0283	0.0469
			18/30(36)kV, 19/33(36)kV				
1x50	8.0	2.2	38.7	2060	1760	0.387	0.641
1x70	8.0	2.2	40.2	2340	1910	0.268	0.443
1x95	8.0	2.3	42.1	2680	2100	0.193	0.320
1x120	8.0	2.3	43.7	3020	2290	0.153	0.253
1x150	8.0	2.4	45.5	3400	2490	0.124	0.206
1x185	8.0	2.4	47.0	3810	2690	0.0991	0.164
1x240	8.0	2.5	49.7	4490	3030	0.0754	0.125
1x300	8.0	2.6	52.1	5180	3300	0.0601	0.100
1x400	8.0	2.7	55.5	6310	3880	0.0470	0.0778
1x500	8.0	2.8	59.2	7430	4390	0.0366	0.0605
1x630	8.0	2.8	60.4	9280	5380	0.0283	0.0469
			26/35(40.5)kV				
1x50	10.5	2.4	43.7	2600	2320	0.387	0.641
1x70	10.5	2.4	45.2	2890	2480	0.268	0.443
1x95	10.5	2.5	47.1	3270	2690	0.193	0.320
1x120	10.5	2.5	48.7	3600	2860	0.153	0.253
1x150	10.5	2.6	50.5	4020	3090	0.124	0.206
1x185	10.5	2.6	52.0	4410	3305	0.0991	0.164
1x240	10.5	2.7	54.7	5110	3660	0.0754	0.125
1x300	10.5	2.8	57.1	5900	4040	0.0601	0.100
1x400	10.5	2.9	60.5	6340	4520	0.0470	0.0778
1x500	10.5	3.0	65.5	8380	5290	0.0366	0.0605
1x630	10.5	3.0	65.8	9950	6050	0.0283	0.0469





CU(AL)/SCR/XLPE/SCR/(CWS)/CTS/PVC/STA/PVC 3.6/6(7.2) ~ 26/35(40.5) kV

Standards

• AS/NZS 1429.1

• HD 620

• IEC 60502-2

DIN VDE 0276-620

Application

The cable is designed for distribution of electrical power with nominal voltage Uo/U(Um) ranging from 3.6/6(7.2) kV to 26/35(40.5) kV and frequency 50Hz. It is suitable for installation mostly in power supply stations, in doors and in cable ducts, outdoors, underground and in water as well as for installation on cable trays for industries, switchboards and power stations.

AS/NZS 1429.1

Conductor: Copper/Aluminum

• Conductor Screen: Semi-Conductive Compound

Insulation: XLPE

Insulation Screen: Semi-Conductive Compound

• Metallic Screen: Copper Wire(Optional)/Copper Tape

Bedding: PVC

Armour: Double Layer Galvanized Steel Tape

Sheath: PVC/PE(Optional)

• (Optional) Flame Retardant Property

(Optional) Fire Resistant Property

(Optional) Anti-Termite & Rodent Property

(Optional) Water Resistant Property

Section	Insulation Thickness	Sheath Thickness	Overall Diameter		Weight	DC. Electrical Re	
No.xmm ²	mm	mm	mm	Cu	Al	Cu	Al
\$1000000000000000000000000000000000000			2 6 /6/7 20/4/ 2 9 /6 6/7 20/4/		/km	Ω/	km
3x25	2.5	2.3	3.6/6(7.2)kV, 3.8/6.6(7.2)kV 40.5	2760	2300	0.727	1.20
3x25 3x35	2.5	2.3	40.5	3210	2550	0.727	0.868
	2.5						
3x50		2.4	46.1	3830	2890	0.387	0.641
3x70	2.5	2.6	49.7	4650	3340	0.268	0.443
3x95	2.5	2.7	53.8	5630	3850	0.193	0.320
3x120	2.5	2.8	57.2	6550	4310	0.153	0.253
3x150	2.5	2.9	60.9	7650	4840	0.124	0.206
3x185	2.5	3.1	64.5	8890	5430	0.0991	0.164
3x240	2.6	3.2	70.5	10860	6370	0.0754	0.125
3x300	2.8	3.4	76.7	13230	7610	0.0601	0.100
3x400	3.0	3.8	86.2	17830	10440	0.0470	0.0778
3x500	3.2	4.0	94.3	20087	11256	0.0366	0.0605
3x630	3.2	4.2	102.4	23952	13166	0.0283	0.0469
			6/10(12)kV, 6.35/11(12)kV				
3x25	3.4	2.4	44.8	2785	2322	0.727	1.20
3x35	3.4	2.5	47.4	3224	2569	0.524	0.868
3x50	3.4	2.6	50.4	3795	2909	0.387	0.641
3×70	3.4	2.7	54.0	4586	3335	0.268	0.443
3x95	3.4	2.8	57.9	5631	3857	0.193	0.320
3x120	3.4	2.9	61.3	6561	4317	0.153	0.253
3x150	3.4	3.1	65.4	7732	4911	0.124	0.206
3x185	3.4	3.2	68.8	8828	5460	0.0991	0.164
3x240	3.4	3.4	74.3	10769	6360	0.0754	0.125
3x300	3.4	3.6	80.9	13069	7406	0.0601	0.100
3x400	3.4	3.8	88.1	16832	9480	0.0470	0.0778
3x500	3.4	4.1	95.2	20687	11256	0.0366	0.0605
3x630	3.4	4.3	104.0	24952	13165	0.0283	0.0469
			8.7/15(17.5)kV				
3x25	4.5	2.6	50.2	3201	2739	0.727	1.20
3x35	4.5	2.6	52.3	3646	2991	0.524	0.868
3x50	4.5	2.8	55.7	4269	3383	0.387	0.641
3x70	4.5	2.9	59.4	5082	3831	0.268	0.443
3x95	4.5	3.0	63.2	6159	4285	0.193	0.320
3x120	4.5	3.1	66.7	7115	4870	0.153	0.253
3x150	4.5	3.2	70.5	8296	5475	0.124	0.206
3x185	4.5	3.4	74.1	9429	6061	0.0991	0.164
3x240	4.5	3.5	79.5	11450	7041	0.0754	0.125
3x300	4.5	3.8	86.2	14508	8845	0.0601	0.100
3x400	4.5	4.0	93.5	17695	10343	0.0470	0.0778
3x500	4.5	4.2	101.2	21503	12072	0.0366	0.0605
			12/20(24)kV, 12.7/22(24)kV				
3x35	5.5	2.8	57.4	4270	3620	0.524	0.868
	5.5	2.9	60.6	4930	4010	0.387	0.641
3x50	3,3						







Conductor: Copper/Aluminum

• Conductor Screen: Semi-Conductive Compound

Insulation: XLPE

• Insulation Screen: Semi-Conductive Compound

Metallic Screen: Copper Wire(Optional)/Copper Tape

Bedding: PVC

Armour: Double Layer Galvanized Steel Tape

Section	Insulation Thickness	Sheath Thickness	Overall Diameter	Cable	Weight	DC. Electrical Re	esistance at 20°C
2				Cu	Al	Cu	Al
No.xmm ²	mm	mm	mm	kg	/km	Ω/	km
			12/20(24)kV, 12.7/22(24)kV	/			
3x95	5.5	3.2	68.2	6850	5090	0.193	0.320
3x120	5.5	3.3	71.5	7850	5640	0.153	0.253
3x150	5.5	3.4	75.3	9040	6260	0.124	0.206
3x185	5.5	3.5	78.9	10300	6890	0.0991	0.164
3x240	5.5	3.7	85.7	13120	8690	0.0754	0.125
3x300	5.5	3.9	91.0	15350	9810	0.0601	0.100
3x400	5.5	4.2	98.2	18940	11560	0.0470	0.0778
3x500	5.5	4.4	105.3	22530	13300	0.0366	0.0605
			18/30(36)kV, 19/33(36)kV				
3x50	8.0	3.3	75.1	7200	6250	0.387	0.641
3x70	8.0	3.5	78.7	8230	6910	0.268	0.443
3x95	8.0	3.6	84.0	9430	7620	0.193	0.320
3x120	8.0	3.8	87.5	11120	8870	0.153	0.253
3x150	8.0	3.9	91.3	12400	9580	0.124	0.206
3x185	8.0	4.0	94.9	13910	10450	0.0991	0.164
3x240	8.0	4.2	100.3	16080	11590	0.0754	0.125
3x300	8.0	4.3	105.6	18500	12850	0.0601	0.100
			26/35(40.5)kV				
3x50	10.5	38.0	88.6	8700	7820	0.387	0.641
3x70	10.5	39.0	92.0	9690	8430	0.268	0.443
3x95	10.5	41.0	86.3	11050	9270	0.193	0.320
3x120	10.5	42.0	99.7	12210	9970	0.153	0.253
3x150	10.5	43.0	103.3	13560	10730	0.124	0.206
3x185	10.5	44.0	107.0	14880	11500	0.0991	0.164
3x240	10.5	46.0	112.5	17210	12800	0.0754	0.125
3x300	10.5	47.0	117.7	19760	14100	0.0601	0.100





CU(AL)/SCR/XLPE/SCR/(CWS)/CTS/PVC/AWA/PVC 3.6/6(7.2) ~ 26/35(40.5) kV

Standards


- AS/NZS 1429.1
- HD 620
- IEC 60502-2
- DIN VDE 0276-620

Application

The cable is designed for distribution of electrical power with nominal voltage Uo/U(Um) ranging from 3.6/6(7.2)kV to 26/35(40.5)kV and frequency 50Hz. It is suitable for installation mostly in power supply stations, in doors and in cable ducts, outdoors, underground and in water as well as for installation on cable trays for industries, switchboards and power stations.

AS/NZS 1429.1

- Conductor: Copper/Aluminum
- Conductor Screen: Semi-Conductive Compound
- Insulation: XLPE
- Insulation Screen: Semi-Conductive Compound
- Metallic Screen: Copper Wire(Optional)/Copper Tape
- Bedding: PVC
- Armour: Aluminum Wire
- Sheath: PVC/PE(Optional)
- (Optional) Flame Retardant Property
- (Optional) Fire Resistant Property
- (Optional) Anti-Termite & Rodent Property
- (Optional) Water Resistant Property



Section	Insulation Thickness	Sheath Thickness	Overall Diameter		Weight		lesistance at 20°C
No.xmm ²	mm	mm	mm	Cu	/km	Cu	Al 2/km
			3.6/6(7.2)kV, 3.8/6.6(7.2)kV		KRIII	*	укш
1x25	2.5	1.8	23.9	856	701	0.727	1.20
1x35	2.5	1.8	25.0	991	774	0.524	0.868
1x50	2.5	1.8	25.9	1156	847	0.387	0.641
1x70	2.5	1.8	27.7	1407	974	0.268	0.443
1x95	2.5	1.9	29.5	1711	1123	0.193	0.320
1x120	2.5	2.0	31.3	2008	1266	0.153	0.253
1x150	2.5	2.0	32.6	2327	1399	0.124	0.206
1x185	2.5	2.1	34.4	2724	1580	0.0991	0.164
1x240	2.6	2.2	37.6	3369	1884	0.0754	0.125
1x300	2.8	2.3	40.4	4038	2182	0.0601	0.100
1x400	3.0	2.4	43.6	5069	2594	0.0470	0.0778
1x500	3.2	2.5	49.1	6352	3258	0.0366	0.0605
1x630	3.2	2.7	52.8	7716	3818	0.0283	0.0469
12050	J.12		6/10(12)kV, 6.35/11(12)kV	7710	3010	0.0203	0.0403
1x25	3.4	1.8	25.7	918	763	0.727	1.20
1x35	3.4	1.8	26.8	1052	836	0.524	0.868
1x50	3.4	1.8	27.7	1218	909	0.324	0.641
1x70	3.4	1.9	29.7	1483	1050	0.268	0.443
1x70	3.4	2.0	31.5	1780	1193	0.193	0.320
1x120	3.4	2.0	33.1	2072	1329	0.153	0.320
1x120 1x150	3.4	2.1	34.6	2408	1480	0.124	0.253
	3.4						
1x185 1x240	3.4	2.1 2.2	36.6 39.2	2820	1676 1946	0.0991 0.0754	0.164 0.125
				3431			
1x300	3.4 3.4	2.3 2.4	41.6	4075	2218	0.0601	0.100
1x400			45.4	5234	2759	0.0470	0.0778
1x500	3.4	2.6	49.7	6386	3293	0.0366	0.0605
1x630	3.4	2.7	53.2	7727	3829	0.0283	0.0469
4 05			8.7/15(17.5)kV				100
1x25	4.5	1.8	27.9	987	833	0.727	1.20
1x35	4.5	1.9	29.2	1136	920	0.524	0.868
1x50	4.5	1.9	30.1	1311	1001	0.387	0.641
1x70	4.5	2.0	32.1	1569	1136	0.268	0.443
1x95	4.5	2.0	33.7	1861	1273	0.193	0.320
1x120	4.5	2.1	35.9	2200	1458	0.153	0.253
1x150	4.5	2.2	37.4	2539	1611	0.124	0.206
1x185	4.5	2.2	39.0	2923	1778	0.0991	0.164
1x240	4.5	2.3	41.6	3528	2043	0.0754	0.125
1x300	4.5	2.4	45.0	4320	2463	0.0601	0.100
1x400	4.5	2.5	48.2	5405	2930	0.0470	0.0778
1x500	4.5	2.6	51.9	6483	3390	0.0366	0.0605
1x630	4.5	2.7	55.4	7825	3927	0.0283	0.0469
			12/20(24)kV, 12.7/22(24)kV				
1x35	5.5	2.0	31.4	1218	1002	0.524	0.868
1x50	5.5	2.0	32.3	1393	1084	0.387	0.641
1x70	5.5	2.1	34.3	1662	1229	0.268	0.443





• Conductor: Copper/Aluminum

• Conductor Screen: Semi-Conductive Compound

Insulation: XLPE

Insulation Screen: Semi-Conductive CompoundMetallic Screen: Copper Wire(Optional)/Copper Tape

Bedding: PVC

• Armour: Aluminum Wire

Section	Insulation Thickness	Sheath Thickness	Overall Diameter	Cable	Weight	DC. Electrical Re	esistance at 20°0
No.xmm²	mm	mm	mm	Cu	Al	Cu	Al
NO.XIIII	1000				/km	Ω/	km
		J.	12/20(24)kV, 12.7/22(24)kV				
1x95	5.5	2.1	36.3	1986	1398	0.193	0.320
1x120	5.5	2.2	38.1	2289	1547	0.153	0.253
1x150	5.5	2.2	39.4	2611	1683	0.124	0.206
1x185	5.5	2.3	41.2	3014	1870	0.0991	0.164
1x240	5.5	2.4	43.8	3630	2145	0.0754	0.125
1x300	5.5	2.5	47.2	4417	2561	0.0601	0.100
1x400	5.5	2.6	50.4	5507	3032	0.0470	0.0778
1x500	5.5	2.7	54.1	6601	3508	0.0366	0.060
1x630	5.5	2.8	57.6	7945	4048	0.0283	0.0469
			18/30(36)kV, 19/33(36)kV				
1x50	8.0	2.2	38.1	1636	1327	0.387	0.641
1x70	8.0	2.2	39.9	1892	1459	0.268	0.443
1x95	8.0	2.3	41.7	2207	1619	0.193	0.320
1x120	8.0	2.4	43.5	2515	1772	0.153	0.253
1x150	8.0	2.4	45.8	2980	2052	0.124	0.206
1x185	8.0	2.5	48.0	3431	2286	0.0991	0.164
1x240	8.0	2.6	50.6	4060	2575	0.0754	0.125
1x300	8.0	2.7	53.0	4730	2874	0.0601	0.100
1x400	8.0	2.8	55.8	5770	3296	0.0470	0.0778
1x500	8.0	2.9	59.9	6924	3830	0.0366	0.060
1x630	8.0	3.0	63.4	8277	4379	0.0283	0.0469
			26/35(40.5)kV				
1x50	10.5	2.4	43.7	1871	1562	0.387	0.641
1x70	10.5	2.5	46.7	2300	1866	0.268	0.443
1x95	10.5	2.5	48.7	2640	2053	0.193	0.320
1x120	10.5	2.6	50.5	2965	2222	0.153	0.253
1x150	10.5	2.6	51.8	3301	2372	0.124	0.206
1x185	10.5	2.7	53.6	3716	2572	0.0991	0.164
1x240	10.5	2.8	56.2	4352	2867	0.0754	0.125
1x300	10.5	2.8	58.4	4999	3143	0.0601	0.100
1x400	10.5	3.0	61.8	6129	3654	0.0470	0.0778
1x500	10.5	3.1	65.5	7240	4147	0.0366	0.0605
1x630	10.5	3.2	69.0	8601	4703	0.0283	0.0469





CU(AL)/SCR/XLPE/SCR/(CWS)/CTS/PVC/SWA/PVC 3.6/6(7.2) ~ 26/35(40.5) kV

Standards

- AS/NZS 1429.1
- HD 620
- IEC 60502-2
- DIN VDE 0276-620

Application

The cable is designed for distribution of electrical power with nominal voltage o/U(Um) ranging from 3.6/6(7.2)kV to 26/35(40.5)kV and frequency 50Hz. It is suitable for installation mostly in power supply stations, in doors and in cable ducts, outdoors, underground and in water as well as for installation on cable trays for industries, switchboards and power stations.

AS/NZS 1429.1

- Conductor: Copper/Aluminum
- Conductor Screen: Semi-Conductive Compound
- Insulation: XLPE
- Insulation Screen: Semi-Conductive Compound
- Metallic Screen: Copper Wire(Optional)/Copper Tape
- Bedding: PVC
- Armour: Galvanized Steel Wire
- Sheath: PVC/PE(Optional)
- (Optional) Flame Retardant Property
- (Optional) Fire Resistant Property
- (Optional) Anti-Termite & Rodent Property
- (Optional) Water Resistant Property



**************************************	Section	Insulation Thickness	Sheath Thickness	Overall Diameter	Cable	Weight	DC. Electrical Re	esistance at 20°C
25 2.5 2.3 4.27 3.676(7.2)kV 3.8766(7.2)kV 3.20kV 3.8766(7.2)kV 3.8766(7	No.xmm²	mm	mm	mm				Al 'km
25				3.6/6(7.2)kV, 3.8/6.6(7.2)kV				
25	3x25	2.5				3160	0.727	1.20
50	3x35	2.5				3490	0.524	0.868
70	3x50	2.5						0.641
120	3x70					4480		0.443
120	3x95	2.5	2.7	57.0	6870	5120	0.193	0.320
185	3x120	2.5						0.253
185	3x150	2.5	2.9	64.2		6320	0.124	0.206
240	3x185	2.5	3.0			7050	0.0991	0.164
1900 3.0 3.7 89.5 19320 11930 0.0470 0.0500 3.2 4.0 97.6 23060 13820 0.0366 0.0065 0.006	3x240	2.6	3.2	75.1	13380	8940	0.0754	0.125
1900 3.0 3.7 89.5 19320 11930 0.0470 0.0500 3.2 4.0 97.6 23060 13820 0.0366 0.0065 0.006	3x300	2.8	3.4	81.3	15680	10130	0.0601	0.100
105.7 105.	3x400	3.0						0.0778
105.7 27690 16050 0.0283 0.0	3x500	3.2	4.0	97.6	23060	13820	0.0366	0.0605
255 3.4 2.4 48.0 4229 3766 0.727 1. 355 3.4 2.5 50.6 4771 4117 0.524 0.1 50 3.4 2.6 53.6 5456 4571 0.387 0.0 70 3.4 2.7 57.2 6352 5101 0.268 0.4 95 3.4 2.8 61.6 7539 5765 0.193 0.1 120 3.4 2.9 64.5 8578 6334 0.153 0.1 150 3.4 3.0 68.6 9901 7080 0.124 0.0 185 3.4 3.2 72.0 11095 7727 0.0991 0.0 240 3.4 3.4 3.4 77.5 13254 8844 0.0754 0.1 300 3.4 3.6 84.2 16678 11015 0.0601 0.0 400 3.4 4.0 9.9	3x630	3.2		105.7				0.0469
255 3.4 2.4 48.0 4229 3766 0.727 1. 355 3.4 2.5 50.6 4771 4117 0.524 0.1 50 3.4 2.6 53.6 5456 4571 0.387 0.0 70 3.4 2.7 57.2 6352 5101 0.268 0.4 95 3.4 2.8 61.6 7539 5765 0.193 0.1 120 3.4 2.9 64.5 8578 6334 0.153 0.1 150 3.4 3.0 68.6 9901 7080 0.124 0.0 185 3.4 3.2 72.0 11095 7727 0.0991 0.0 240 3.4 3.4 3.4 77.5 13254 8844 0.0754 0.1 300 3.4 3.6 84.2 16678 11015 0.0601 0.0 400 3.4 4.0 9.9				6/10(12)kV, 6.35/11(12)kV				
Section Sect	3x25	3.4	2.4		4229	3766	0.727	1.20
70 3.4 2.7 57.2 6352 5101 0.268 0.4 95 3.4 2.8 61.6 7539 5765 0.193 0.3 120 3.4 2.9 64.5 8578 6334 0.153 0.3 150 3.4 3.0 68.6 9901 7080 0.124 0.0 185 3.4 3.2 72.0 11095 7727 0.0991 0.2 240 3.4 3.6 84.2 16678 11015 0.0601 0.7 300 3.4 3.6 84.2 16678 11015 0.0601 0.0 400 3.4 3.8 91.4 20051 12698 0.0470 0.0 500 3.4 4.0 99.2 24211 14780 0.0366 0.0 500 3.4 4.3 107.3 2839 17052 0.0283 0.0 500 3.4 4.3 107.3 28	3x35	3.4	2.5	50.6	4771	4117	0.524	0.868
955	3x50	3.4	2.6	53.6	5456	4571	0.387	0.641
120	3x70	3.4	2.7	57.2	6352	5101	0.268	0.443
150 3.4 3.0 68.6 9901 7080 0.124 0.2 185 3.4 3.2 72.0 11095 7727 0.0991 0.7 240 3.4 3.4 77.5 13254 8844 0.0754 0.3 300 3.4 3.6 84.2 16678 11015 0.0601 0.7 400 3.4 3.8 91.4 20051 12698 0.0470 0.0 500 3.4 4.0 99.2 24211 14780 0.0366 0.0 630 3.4 4.0 99.2 24211 14780 0.0366 0.0 630 3.4 4.3 107.3 28839 17052 0.0283 0.0 630 3.4 4.3 107.3 28839 17052 0.0283 0.0 630 4.5 2.6 52.4 4841 4378 0.727 1. 25 4.5 3.5 2.7 <	3x95	3.4	2.8	61.6	7539	5765	0.193	0.320
185 3.4 3.2 72.0 11095 7727 0.0991 0.7 240 3.4 3.4 77.5 13254 8844 0.0754 0.0 300 3.4 3.6 84.2 16678 11015 0.0601 0.0 300 3.4 3.8 91.4 20051 12698 0.0470 0.0 500 3.4 4.0 99.2 24211 14780 0.0366 0.0 530 3.4 4.3 107.3 28839 17052 0.0283 0.0 550 4.5 2.6 52.4 4841 4378 0.727 1 25 4.5 2.6 52.4 4841 4378 0.727 1 35 4.5 2.6 52.4 4841 4378 0.727 1 25 4.5 2.6 52.4 4841 4378 0.727 1 35 4.5 3.0 66.4 826	3x120	3.4	2.9	64.5	8578	6334	0.153	0.253
240 3.4 3.4 77.5 13254 8844 0.0754 0.0 300 3.4 3.6 84.2 16678 11015 0.0601 0.0 400 3.4 3.8 91.4 20051 12698 0.0470 0.0 500 3.4 4.0 99.2 24211 14780 0.0366 0.0 530 3.4 4.3 107.3 28839 17052 0.0283 0.0 630 3.4 4.3 107.3 28839 17052 0.0283 0.0 850 4.5 2.6 52.4 4841 4378 0.727 1 25 4.5 2.6 52.4 4841 4378 0.727 1 25 4.5 2.7 55.7 5394 4740 0.524 0.0 35 4.5 2.7 58.9 6107 5222 0.387 0.0 70 4.5 3.0 66.26 7066 </td <td>3x150</td> <td>3.4</td> <td>3.0</td> <td>68.6</td> <td>9901</td> <td>7080</td> <td>0.124</td> <td>0.206</td>	3x150	3.4	3.0	68.6	9901	7080	0.124	0.206
300 3.4 3.6 84.2 16678 11015 0.0601 0.0601 400 3.4 3.8 91.4 20051 12698 0.0470 0.0 500 3.4 4.0 99.2 24211 14780 0.0366 0.0 530 3.4 4.3 107.3 2839 17052 0.0283 0.0 500 3.4 4.3 107.3 2839 17052 0.0283 0.0 500 4.5 2.6 52.4 4841 4378 0.727 1. 355 4.5 2.6 52.4 4841 4378 0.727 1. 355 4.5 2.7 55.7 5394 4740 0.524 0.1 550 4.5 2.7 58.9 6107 5222 0.387 0.0 45 2.9 62.6 7066 5815 0.268 0.0 450 3.0 66.4 8276 6501 0	3x185	3.4	3.2	72.0	11095	7727	0.0991	0.164
100	3x240	3.4	3.4	77.5	13254	8844	0.0754	0.125
500 3.4 4.0 99.2 24211 14780 0.0366 0.0 630 3.4 4.3 107.3 28839 17052 0.0283 0.0 8.7/15(17.5)kV 5.7 5.87/15(17.5)kV 5.7 5.87 4.841 4378 0.727 1. 35 4.5 2.6 52.4 4841 4378 0.727 1. 50 4.5 2.7 58.9 6107 5222 0.387 0.0 70 4.5 2.9 62.6 7066 5815 0.268 0.0 95 4.5 3.0 66.4 8276 6501 0.193 0.3 120 4.5 3.1 69.9 9312 7068 0.153 0.1 150 4.5 3.2 73.7 10636 7814 0.124 0.3 185 4.5 3.3 77.3 11879 8510 0.0991 0.0 240 4.5 3.6	3x300	3.4	3.6	84.2	16678	11015	0.0601	0.100
530 3.4 4.3 107.3 28839 17052 0.0283 0.0 8.7/15(17.5)kV 8.7/15(17.5)kV 8.7/15(17.5)kV 1.2 0.0283 0.0 35 4.5 2.6 52.4 4841 4378 0.727 1.2 35 4.5 2.7 55.7 5394 4740 0.524 0.3 50 4.5 2.9 62.6 7066 5815 0.268 0.0 70 4.5 3.0 66.4 8276 6501 0.193 0.3 120 4.5 3.1 69.9 9312 7068 0.153 0.3 150 4.5 3.2 73.7 10636 7814 0.124 0.0 185 4.5 3.3 77.3 11879 8510 0.0991 0.0 240 4.5 3.6 84.2 15060 10650 0.0754 0.0 360 4.5 3.7 89.5 17597	3x400	3.4	3.8	91.4	20051	12698	0.0470	0.0778
Style="block of the learnest color: block o	3x500	3.4	4.0	99.2	24211	14780	0.0366	0.0605
25 4.5 2.6 52.4 4841 4378 0.727 1. 35 4.5 2.7 55.7 5394 4740 0.524 0.4 50 4.5 2.7 58.9 6107 5222 0.387 0.1 70 4.5 2.9 62.6 7066 5815 0.268 0.4 95 4.5 3.0 66.4 8276 6501 0.193 0.2 120 4.5 3.1 69.9 9312 7068 0.153 0.2 150 4.5 3.2 73.7 10636 7814 0.124 0.2 185 4.5 3.3 77.3 11879 8510 0.0991 0.2 240 4.5 3.6 84.2 15060 10650 0.0754 0.2 340 4.5 3.7 89.5 17597 11934 0.0601 0.0 400 4.5 3.9 96.8 21109	3x630	3.4	4.3	107.3	28839	17052	0.0283	0.0469
35 4.5 2.7 55.7 5394 4740 0.524 0.1 50 4.5 2.7 58.9 6107 5222 0.387 0.4 70 4.5 2.9 62.6 7066 5815 0.268 0.4 95 4.5 3.0 66.4 8276 6501 0.193 0.3 120 4.5 3.1 69.9 9312 7068 0.153 0.2 150 4.5 3.2 73.7 10636 7814 0.124 0.2 185 4.5 3.3 77.3 11879 8510 0.0991 0.2 840 4.5 3.6 84.2 15060 10650 0.0754 0.2 800 4.5 3.7 89.5 17597 11934 0.0601 0.0 800 4.5 3.9 96.8 21109 13750 0.0470 0.0 800 4.5 4.2 140.5 25267 <td></td> <td></td> <td></td> <td>8.7/15(17.5)kV</td> <td></td> <td></td> <td></td> <td></td>				8.7/15(17.5)kV				
50 4.5 2.7 58.9 6107 5222 0.387 0.1 70 4.5 2.9 62.6 7066 5815 0.268 0.4 95 4.5 3.0 66.4 8276 6501 0.193 0.3 120 4.5 3.1 69.9 9312 7068 0.153 0.2 150 4.5 3.2 73.7 10636 7814 0.124 0.2 185 4.5 3.3 77.3 11879 8510 0.0991 0.2 240 4.5 3.6 84.2 15060 10650 0.0754 0.2 300 4.5 3.7 89.5 17597 11934 0.0601 0.5 400 4.5 3.9 96.8 21109 13750 0.0470 0.0 500 4.5 4.2 140.5 25267 15836 0.0366 0.0 530 4.5 4.5 112.6 2989	3x25	4.5	2.6	52.4	4841	4378	0.727	1.20
770 4.5 2.9 62.6 7066 5815 0.268 0.4 95 4.5 3.0 66.4 8276 6501 0.193 0.3 120 4.5 3.1 69.9 9312 7068 0.153 0.3 150 4.5 3.2 73.7 10636 7814 0.124 0.2 185 4.5 3.3 77.3 11879 8510 0.0991 0.2 240 4.5 3.6 84.2 15060 10650 0.0754 0.2 300 4.5 3.7 89.5 17597 11934 0.0601 0.3 400 4.5 3.9 96.8 21109 13750 0.0470 0.0 500 4.5 4.2 140.5 25267 15836 0.0366 0.0 500 4.5 4.5 112.6 29892 18105 0.0283 0.0 500 4.5 4.5 6.7	3x35	4.5	2.7	55.7	5394	4740	0.524	0.868
95 4.5 3.0 66.4 8276 6501 0.193 0.3 120 4.5 3.1 69.9 9312 7068 0.153 0.3 150 4.5 3.2 73.7 10636 7814 0.124 0.3 185 4.5 3.3 77.3 11879 8510 0.0991 0.3 186 4.5 3.6 84.2 15060 10650 0.0754 0.3 180 4.5 3.7 89.5 17597 11934 0.0601 0.3 180 4.5 3.9 96.8 21109 13750 0.0470 0.0 180 4.5 4.2 140.5 25267 15836 0.0366 0.0 180 4.5 4.5 12.6 2982 18105 0.0283 0.0 180 4.5 5 12/20(24)kV, 12.7/22(24)kV	3x50	4.5	2.7	58.9	6107	5222	0.387	0.641
120 4.5 3.1 69.9 9312 7068 0.153 0.1 150 4.5 3.2 73.7 10636 7814 0.124 0.1 185 4.5 3.3 77.3 11879 8510 0.0991 0.1 186 4.5 3.6 84.2 15060 10650 0.0754 0.1 187 4.5 3.6 84.2 15060 10650 0.0754 0.1 188 4.5 3.7 89.5 17597 11934 0.0601 0.1 189 4.5 3.9 96.8 21109 13750 0.0470 0.0 189 4.5 4.2 140.5 25267 15836 0.0366 0.0 189 5.5 4.5 4.2 140.5 25267 15836 0.0366 0.0 189 5.5 4.5 4.5 112.6 29892 18105 0.0283 0.0 189 5.5 5.5 2.8 60.7 5970 5330 0.524 0.3 180 5.5 5.5 2.9 63.8 6730 5810 0.387 0.1	3x70	4.5	2.9	62.6	7066	5815	0.268	0.443
150 4.5 3.2 73.7 10636 7814 0.124 0.2 185 4.5 3.3 77.3 11879 8510 0.0991 0.7 240 4.5 3.6 84.2 15060 10650 0.0754 0.7 800 4.5 3.7 89.5 17597 11934 0.0601 0.0 400 4.5 3.9 96.8 21109 13750 0.0470 0.0 500 4.5 4.2 140.5 25267 15836 0.0366 0.0 630 4.5 4.5 112.6 29892 18105 0.0283 0.0 35 5.5 2.8 60.7 5970 5330 0.524 0.1 50 5.5 2.9 63.8 6730 5810 0.387 0.1	3x95		3.0	66.4		6501	0.193	0.320
185 4.5 3.3 77.3 11879 8510 0.0991 0.091 240 4.5 3.6 84.2 15060 10650 0.0754 0.0 300 4.5 3.7 89.5 17597 11934 0.0601 0.0 400 4.5 3.9 96.8 21109 13750 0.0470 0.0 500 4.5 4.2 140.5 25267 15836 0.0366 0.0 630 4.5 4.5 112.6 29892 18105 0.0283 0.0 630 5.5 2.8 60.7 5970 5330 0.524 0.3 50 5.5 2.9 63.8 6730 5810 0.387 0.4	3x120			69.9		7068	0.153	0.253
240 4.5 3.6 84.2 15060 10650 0.0754 0.0 300 4.5 3.7 89.5 17597 11934 0.0601 0.0 400 4.5 3.9 96.8 21109 13750 0.0470 0.0 500 4.5 4.2 140.5 25267 15836 0.0366 0.0 530 4.5 4.5 112.6 29892 18105 0.0283 0.0 12/20(24)kV, 12.7/22(24)kV 35 5.5 2.8 60.7 5970 5330 0.524 0.3 50 5.5 2.9 63.8 6730 5810 0.387 0.4	3x150					7814	0.124	0.206
800 4.5 3.7 89.5 17597 11934 0.0601 0.0 400 4.5 3.9 96.8 21109 13750 0.0470 0.0 500 4.5 4.2 140.5 25267 15836 0.0366 0.0 630 4.5 4.5 11.20(24)kV, 12.7/22(24)kV 18105 0.0283 0.0 35 5.5 2.8 60.7 5970 5330 0.524 0.3 50 5.5 2.9 63.8 6730 5810 0.387 0.1	3x185				11879	8510	0.0991	0.164
400 4.5 3.9 96.8 21109 13750 0.0470 0.0 500 4.5 4.2 140.5 25267 15836 0.0366 0.0 530 4.5 4.5 112.6 29892 18105 0.0283 0.0 535 5.5 2.8 60.7 5970 5330 0.524 0.0 50 5.5 2.9 63.8 6730 5810 0.387 0.0	3x240						100000000000000000000000000000000000000	0.125
500 4.5 4.2 140.5 25267 15836 0.0366 0.0 530 4.5 4.5 112.6 29892 18105 0.0283 0.0 12/20(24)kV, 12.7/22(24)kV 355 5.5 2.8 60.7 5970 5330 0.524 0.0 50 5.5 2.9 63.8 6730 5810 0.387 0.0	3x300							0.100
530 4.5 4.5 112.6 29892 18105 0.0283 0.0 12/20(24)kV, 12.7/22(24)kV 35 5.5 2.8 60.7 5970 5330 0.524 0.1 50 5.5 2.9 63.8 6730 5810 0.387 0.1	3x400	4.5	3.9	96.8	21109	13750	0.0470	0.0778
12/20(24)kV, 12.7/22(24)kV 35 5.5 2.8 60.7 5970 5330 0.524 0.1 50 5.5 2.9 63.8 6730 5810 0.387 0.1	3x500			140.5	25267	15836	0.0366	0.0605
35 5.5 2.8 60.7 5970 5330 0.524 0.8 50 5.5 2.9 63.8 6730 5810 0.387 0.8	3x630	4.5				18105	0.0283	0.0469
50 5.5 2.9 63.8 6730 5810 0.387 0.1								
	3x35							0.868
70 5.5 3.0 67.3 7720 6430 0.268 0.	3x50		2.9	63.8		5810	0.387	0.641
	3x70							





• Conductor: Copper/Aluminum

• Conductor Screen: Semi-Conductive Compound

• Insulation: XLPE

Insulation Screen: Semi-Conductive CompoundMetallic Screen: Copper Wire(Optional)/Copper Tape

Bedding: PVC

Armour: Galvanized Steel Wire

Section	Insulation Thickness	Sheath Thickness	Overall Diameter	Cable	Weight	DC. Electrical Re	esistance at 20°C
No.xmm ²	mm	mm	mm	Cu	Al	Cu	Al
NO.XIIIII	SHIII	19111	THEF	kg	/km	Ω/	'km
			12/20(24)kV, 12.7/22(24)kV	/			
3x95	5.5	3.1	72.8	9620	7890	0.193	0.320
3x120	5.5	3.3	76.1	10800	8580	0.153	0.253
3x150	5.5	3.4	79.9	12180	9410	0.124	0.206
3x185	5.5	3.5	83.5	13600	10180	0.0991	0.164
3x240	5.5	3.7	89.0	15850	11420	0.0754	0.125
3x300	5.5	3.9	94.3	18260	12720	0.0601	0.100
3x400	5.5	4.1	101.5	22100	14710	0.0470	0.0778
3x500	5.5	4.4	108.6	25950	16710	0.0366	0.060
3x630	5.5	4.6	116.7	30690	19050	0.0283	0.0469
			18/30(36)kV, 19/33(36)kV				
3x50	8.0	3.3	79.7	9790	8870	0.387	0.641
3x70	8.0	3.4	83.3	10900	9610	0.268	0.443
3x95	8.0	3.6	87.4	12220	10470	0.193	0.320
3x120	8.0	3.7	90.8	13440	11220	0.153	0.253
3x150	8.0	3.8	94.6	14880	12100	0.124	0.206
3x185	8.0	3.9	98.2	16420	12990	0.0991	0.164
3x240	8.0	4.1	103.7	18770	14340	0.0754	0.125
3x300	8.0	4.3	108.9	21250	15710	0.0601	0.100
3x400	8.0	4.5	116.1	25260	17870	0.0470	0.0778
3x500	8.0	4.7	123.2	29260	20030	0.0366	0.060
3x630	8.0	5.0	131.3	34170	22530	0.0283	0.0469
			26/35(40.5)kV				
3x50	10.5	3.7	86.0	12620	11740	0.387	0.641
3x70	10.5	3.8	89.6	13820	12560	0.268	0.443
3x95	10.5	4.0	93.7	15360	13590	0.193	0.320
3x120	10.5	4.1	97.0	16700	14460	0.153	0.253
3x150	10.5	4.2	100.8	18280	15460	0.124	0.206
3x185	10.5	4.3	104.4	17680	14260	0.0991	0.164
3x240	10.5	4.5	109.9	20140	15710	0.0754	0.125
3x300	10.5	4.7	115.1	22610	17070	0.0601	0.100
3x400	10.5	4.9	122.3	26680	19290	0.0470	0.0778
3x500	10.5	5.1	129.4	30750	21520	0.0366	0.0609
3x630	10.5	5.4	137.5	35730	24090	0.0283	0.0469





CU(AL)/SCR/XLPE/SCR/CWS/PVC/SWA/PVC

1.9/3.3(3.6) ~ 19/33(36) kV

Standards

• AS/NZS 1429.1

Application

The cables is designed to be used for the supply of electrical energy in fixed installations up to the indicated rated voltage at a nominal power frequency in the range 49Hz to 61Hz, intended for use either installed in air, directly buried in the ground or in ducts.

AS/NZS 1429.1

• Conductor: Copper/Aluminum

• Conductor Screen: Semi-Conductive Compound

Insulation: XLPE

Insulation Screen: Semi-Conductive Compound

• Metallic Screen: Copper Wire

Bedding: PVC

• Armour: Galvanized Steel Wire

• Sheath: PVC/PE(Optional)

(Optional) Flame Retardant Property

(Optional) Fire Resistant Property

(Optional) Anti-Termite & Rodent Property

• (Optional) Water Resistant Property



Section	Insulation Thickness	Sheath Thickness	Overall Diameter		Weight	DC. Electrical Re	
No.xmm ²	mm	mm	mm	Cu	Al /km	Cu	Al km
			1.9/3.3(3.6)kV	K9,	KIII	12/	KIII
			Light Duty Screened				
3x25	2.0	2.1	43.0	3200	2700	0.727	1.20
3x35	2.0	2.2	45.2	3650	3000	0.524	0.868
3x50	2.0	2.3	49.7	4600	3750	0.387	0.641
3x70	2.0	2.5	53.4	5500	4250	0.268	0.443
3x95	2.0	2.6	57.5	6600	4850	0.193	0.320
3x120	2.0	2.6	61.0	7650	5400	0.153	0.320
	2.0						
3x150		2.8	64.2	8700	5950	0.124	0.206
3x185	2.0	2.9	68.4	10100	6650	0.0991	0.164
3x240	2.0	3.1	73.7	12200	7700	0.0754	0.125
2.25	2.0	2.2	Heavy Duty Screened	2250	2700	0.727	4.00
3x25	2.0	2.2	43.0	3250	2700	0.727	1.20
3x35	2.0	2.2	45.4	3800	3000	0.524	0.868
3x50	2.0	2.4	49.6	4900	3850	0.387	0.641
3x70	2.0	2.5	53.6	6000	4550	0.268	0.443
3x95	2.0	2.6	57.5	7000	5200	0.193	0.320
3x120	2.0	2.7	60.9	8050	5800	0.153	0.253
3x150	2.0	2.8	64.2	9150	6400	0.124	0.206
3x185	2.0	3.0	68.4	10500	7050	0.0991	0.164
3x240	2.0	3.1	73.4	12500	8100	0.0754	0.125
			3.8/6.6(7.2)kV				
			Light Duty Screened				
3x25	2.5	2.2	45.3	3400	2900	0.727	1.20
3x35	2.5	2.3	49.4	4350	3650	0.524	0.868
3x50	2.5	2.4	51.7	4900	4000	0.387	0.641
3x70	2.5	2.5	55.8	5800	4550	0.268	0.443
3x95	2.5	2.7	60.2	6950	5200	0.193	0.320
3x120	2.5	2.8	63.3	7900	5650	0.153	0.253
3x150	2.5	2.9	66.6	9000	6300	0.124	0.206
3x185	2.5	3.0	70.5	10400	7000	0.0991	0.164
3x240	2.6	3.2	77.7	13400	8950	0.0754	0.125
			3.8/6.6(7.2)kV				
			Heavy Duty Screened				
3x25	2.5	2.2	45.3	3450	2900	0.727	1.20
3x35	2.5	2.4	49.4	4500	3700	0.524	0.868
3x50	2.5	2.5	51.9	5150	4150	0.387	0.641
3x70	2.5	2.6	56.0	6250	4800	0.268	0.443
3x95	2.5	2.7	60.2	7350	5550	0.193	0.320
3x120	2.5	2.8	63.3	8300	6050	0.153	0.253
3x150	2.5	2.9	66.6	9400	6700	0.124	0.206
3x185	2.5	3.0	70.7	10800	7400	0.0991	0.164
3x240	2.6	3.2	78.1	13900	9400	0.0754	0.125





AS NZS 1429.1
Conductor: Copper/Aluminum
Conductor Screen: Semi-Conductive Compound
Insulation: XLPE

Insulation Screen: Semi-Conductive Compound
Metallic Screen: Copper Wire
Bedding: PVC
Armour: Galvanized Steel Wire
Sheath: PVC

Section	Insulation Thickness	Sheath Thickness	Overall Diameter		Weight		cal Resistance at 20°C
No.xmm ²	mm	mm	mm	Cu	Al g/km	Cu	Al Ω/km
Value and the			6.35/11(12)kV	K	J/KIII		22/8111
			Light Duty Screened				
3x25	3.4	2.4	51.3	4300	3750	0.727	1.20
3x35	3.4	2.5	53.5	4750	4150	0.524	0.868
	3.4	2.6	56.3	5350	4500	0.324	0.641
3x50 3x70	3.4	2.7	60.4	6300	5050	0.387	0.443
3x95	3.4		64.2		5700	0.200	
3x95 3x120	3.4	2.8 2.9	67.7	7450 8500	6250	0.193	0.320 0.253
3x120 3x150	3.4	3.0	71.1	9550	6850	0.133	0.206
3x185	3.4	3.2	75.2	11000	7600	0.0991	0.164
	3.4	3.3	75.2 82.1	14000		0.0991	0.164
3x240	3.4	3.3		14000	9600	0.0754	0.125
2.25	2.4	2.4	Heavy Duty Screened	1200	2000	0.707	4.00
3x25	3.4	2.4	51.3	4300	3800	0.727	1.20
3x35	3.4	2.5	53.7	4950	4150	0.524	0.868
3x50	3.4	2.6	56.3	5600	4600	0.387	0.641
3x70	3.4	2.7	60.4	6750	5250	0.268	0.443
3x95	3.4	2.8	64.4	7950	6100	0.193	0.320
3x120	3,4	2.9	67.9	8900	6650	0.153	0.253
3x150	3,4	3.0	71.3	9950	7250	0.124	0.206
3x185	3.4	3.2	76.7	12200	8800	0.0991	0.164
3x240	3.4	3.4	82.1	14400	9900	0.0754	0.125
			12.7/22(14)kV				
			Light Duty Screened				
3x35	5.5	2.8	63.6	6050	5350	0.524	0.868
3x50	5.5	2.9	66.5	6600	5700	0.387	0.641
3×70	5.5	3.0	70.2	7600	6300	0.268	0.443
3x95	5.5	3.1	74.3	8750	7000	0.193	0.320
3x120	5.5	3.2	79.4	10800	8550	0.153	0.253
3x150	5.5	3.4	82.6	11900	9200	0.124	0.206
3x185	5.5	3.5	87.0	13500	10100	0.0991	0.164
			Heavy Duty Screened				
3x35	5.5	2.8	63.6	6150	5350	0.524	0.868
3x50	5.5	2.9	66.5	6800	5800	0.387	0.641
3x70	5.5	3.0	70.6	8050	6550	0.268	0.443
3x95	5.5	3.1	74.5	9150	7350	0.193	0.320
3x120	5.5	3.3	79.4	11100	8900	0.153	0.253
3x150	5.5	3.4	82.8	12300	9550	0.124	0.206
3x185	5.5	3.5	87.0	13800	10400	0.0991	0.164
			19/33(36)kV				
			Light Duty Screened				
3x50	8.0	3.3	79.9	9200	8300	0.387	0.641
3x70	8.0	3.4	84.1	10400	9100	0.268	0.443
3x95	8.0	3.5	88.0	11600	9800	0.193	0.320
3x120	8.0	3.6	91.4	12800	10500	0.153	0.253
3x150	8.0	3.8	94.8	14000	11200	0.124	0.206
			Heavy Duty Screened				
3x50	8.0	3.3	80.1	9400	8350	0.387	0.641
3x70	8.0	3.5	84.1	10700	9200	0.268	0.443
3x95	8.0	3.6	88.0	11900	10100	0.193	0.320
3x120	8.0	3.7	91.4	13100	10800	0.153	0.253
3x150	8.0	3.8	94.8	14300	11500	0.124	0.206





AA/SCR/XLPE/SCR/(CWS)/CTS/PVC 3.6/7(7.2) ~ 26/35(40.5) kV

Standards

- AS/NZS 1429.1
- GB/T 31840
- IEC 60502-2

Application

The cable is of high conductivity, good creep resistant property, high flexibility, high elongation, low resilience and connective stability. The cable is used for buildings without flame, including office, airports, hospitals, hotels, shopping malls and feeder lines of lighting in factories as well as other electric appliance.

AS/NZS 1429.1

- Conductor: Aluminum Alloy 8030
- Conductor Screen: Semi-Conductive Compound
- Insulation: XLPE
- Insulation Screen: Semi-Conductive Compound
- Metallic Screen: Copper Wire(Optional)/Copper Tape
- Sheath: PVC/PE(Optional)
- (Optional) Flame Retardant Property
- (Optional) Fire Resistant Property
- (Optional) Anti-Termite & Rodent Property
- (Optional) Water Resistant Property



Section	Insulation Thickness	Sheath Thickness	Overall Diameter	Cable Weight	DC. Electrical Resistance at 20°0
No.xmm ²	mm	mm	mm	AA 8030 kg/km	AA 8030 Ω/km
	400000	1.00	3.6/6(7.2)kV, 3.8/6.6(7.2)kV	Kg/KIII	\$2/KIII
1x25	2.5	1.5	17.9	390	1.21
1x35	2.5	1.6	18.9	480	0.868
1x50	2.5	1.6	20.3	550	0.641
1x70	2.5	1.7	21.9	650	0.443
1x95	2.5	1.7	23.7	760	0.320
1x120	2.5	1.8	25.2	840	0.253
1x150	2.5	1.8	27.0	990	0.206
1x185	2.5	1.9	28.6	1140	0.164
1x240	2.6	2.0	31.2	1370	0.125
1x300	2.8	2.1	34.0	1640	0.100
1x400	3.0	2.2	37.6	2140	0.0778
1x500	3.2	2.3	41.3	2610	0.0605
1x630	3.2	2.4	44.9	3090	0.0469
3x25	2.5	2.1	35.8	1280	1.21
3x35	2.5	2.2	38.1	1470	0.868
3x50	2.5	2.3	41.1	1740	0.641
3x70	2.5	2.4	44.5	2090	0.443
3x95	2.5	2.5	48.5	2470	0.320
3x120	2.5	2.6	51.7	2850	0.253
3x150	2.5	2.8	55.4	3310	0.206
3x185	2.5	2.9	58.8	3800	0.164
3x240	2.6	3.0	64.6	4600	0.125
3x300	2.8	3.2	70.6	5510	0.100
3x400	3.0	3.5	78.4	7750	0.0778
3x500	3.2	3.7	86.2	8045	0.0605
3x630	3.2	4.0	94.0	9749	0.0469
			6/10(12)kV, 6.35/11(12)kV		
1x25	3.4	1.6	19.8	458	1.21
1x35	3.4	1.6	20.8	514	0.868
1x50	3.4	1.7	22.3	585	0.641
1x70	3.4	1.7	23.8	681	0.443
1x95	3.4	1.8	25.7	805	0.320
1x120	3.4	1.8	27.1	913	0.253
1x150	3.4	1.9	28.7	1043	0.206
1x185	3.4	1.9	30.4	1165	0.164
1x240	3.4	2.0	32.9	1382	0.125
1x300	3.4	2.1	35.3	1642	0.100
1x400	3.4	2.2	38.5	1991	0.0778
1x500	3.4	2.3	42.0	2418	0.0605
1x630	3.4	2.4	45.6	2883	0.0469
3x25	3.4	2.2	39.8	1451	1.21
3x35	3.4	2.3	42.2	1639	0.868
3x50	3.4	2.4	45.2	1874	0.641
3x70	3.4	2.5	48.6	2193	0.443
3x95	3.4	2.7	52.7	2653	0.320
3x120	3.4	2.8	55.9	3040	0.253
3x150	3.4	2.9	59.6	3503	0.206
3x185	3.4	3.0	63.0	3946	0.164





Conductor: Aluminum Alloy 8030

Conductor Screen: Semi-Conductive Compound

Insulation: XLPE

Insulation Screen: Semi-Conductive Compound Metallic Screen: Copper Wire(Optional)/Copper Tape

Section No.xmm ²	Insulation Thickness mm	Sheath Thickness mm	Overall Diameter mm	Cable Weight AA 8030	DC, Electrical Resistance at 20°C AA 8030
- Aminima	.,,,,,,			kg/km	Ω/km
3,240	2.4	2.2	6/10(12)kV, 6.35/11(12)kV	4720	0.125
3x240 3x300	3.4 3.4	3.2 3.3	68.3 73.3	4729 5586	0.125
3x400	3.4	3.6	80.3	6822	0.0778
3x500	3.4	3.8	87.9	8299	0.0605
3x630	3.4	4.1	95.8	9949	0.0469
3x030	9.7	.59.1	8.7/15(17.5)kV	3343	0.0403
1x25	4.5	1.6	22.0	544	1.21
1x35	4.5	1.6	23.0	604	0.868
1x50	4.5	1.7	24.5	679	0.641
1x70	4.5	1.8	26.2	780	0.443
1x95	4.5	1.8	27.9	910	0.320
1x120	4.5	1.9	29.5	1023	0.253
1x150	4.5	1.9	31,1	1158	0.206
1x185	4.5	2.0	32.8	1285	0.164
1x240	4.5	2.1	35.3	1525	0.125
1x300	4.5	2.2	37.7	1798	0.100
1x400	4.5	2.3	40.9	2156	0.0778
1x500	4.5	2.4	44.4	2595	0.0605
1x630	4.5	2.5	48.0	3074	0.0469
3x25	4.5	2.4	43.6	1702	1.21
3x35	4.5	2.5	45.9	1918	0.868
3x50	4.5	2.6	48.7	2200	0.641
3x70	4.5	2.7	52.4	2566	0.443
3x95	4.5	2.8	55.6	2966	0.320
3x120	4.5	2.9	59.0	3393	0.253
3x150	4.5	3.0	62.0	3813	0.206
3x185	4.5	3.2	66.7	4390	0.164
3x240	4.5	3.3	72.1	5217 6046	0.125 0.100
3x300	4.5 4.5	3.5 3.7	76.8	7320	0.0778
3x400 3x500	4.5	4.0	83.4 90.5	8678	0.0605
3X300	4.5	4.0	12/20(24)kV, 12.7/22(24)kV	0070	0.0003
1x35	5.5	1.8	25.4	720	0.868
1x50	5.5	1.8	26.8	850	0.641
1x70	5.5	1.9	28.4	980	0.443
1x95	5.5	1.9	30.2	1110	0.320
1x120	5.5	2.0	31.7	1240	0.253
1x150	5.5	2.0	33.4	1380	0.206
1x185	5.5	2.1	35.0	1550	0.164
1x240	5.5	2.2	37.4	1800	0.125
1x300	5.5	2.2	39.8	2050	0.100
1x400	5.5	2.3	43.0	2550	0.0778
1x500	5.5	2.5	46.2	3030	0.0605
1x630	5.5	2.6	49.8	3540	0.0469
3x35	5.5	2.7	52.0	2570	0.868
3x50	5.5	2.8	55.0	2900	0.641
3x70	5.5	2.9	58.4	3330	0.443
3x95	5.5	3.0	62.3	3800	0.320
3x120	5.5	3.1	65.6	4240	0.253
3x150	5.5	3.2	69.2	4750	0.206
3x185	5.5	3.3	72.7	5320	0.164
3x240	5.5	3.5	78.0	6180	0.125
3x300	5.5	3.7	83.0	7100	0.100
3x400	5.5	3.9	90.0	8790	0.0778
3x500	5.5	4.1	96.8	9580	0.0605
1.50	0.0	2.0	18/30(36)kV, 19/33(36)kV	1350	0.544
1x50	8.0	2.0	33.3	1250	0.641
1x70	8.0	2.1	34.9	1400	0.443
1x95	8.0	2.1	36.7	1550 1700	0.320 0.253
1x120	8.0 8.0	2.2 2.2	38.2	1860	0.206
1x150	8.0		39.9	2050	0.206
1x185	8.0	2.3	41.5 44.0	2310	0.164
1x240 1x300	8.0	2.3 2.4	44.0 46.3	2600	0.125
1x400	8.0	2.4	49.6	3060	0.0778
1x400 1x500	8.0	2.5	52.8	3560	0.0605
1x630	8.0	2.7	56.4	4120	0.0469
3x50	8.0	3.1	68.4	4350	0.641
3x70	8.0	3.2	72.5	4930	0.443
J V	8.0	3.4	75.9	5580	0.320





• Conductor: Aluminum Alloy 8030

• Conductor Screen: Semi-Conductive Compound

Insulation: XLPE

Insulation Screen: Semi-Conductive CompoundMetallic Screen: Copper Wire(Optional)/Copper Tape

Section	Insulation Thickness	Sheath Thickness	Overall Diameter	Cable Weight	DC. Electrical Resistance at 20°C
No.xmm ²	mm	mm	mm	AA 8030	AA 8030
	****	(2004)		kg/km	Ω/km
			18/30(36)kV, 19/33(36)kV		
3x120	8.0	3.5	79.4	6120	0.253
3x150	8.0	3.6	82.6	6410	0.206
3x185	8.0	3.7	86.4	7370	0.164
3x240	8.0	3.9	91.4	8300	0.125
3x300	8.0	4.0	96.7	9300	0.100
3x400	8.0	4.3	103.8	10620	0.0778
			26/35(40.5)kV		
1x50	10.5	2.2	38.7	1437	0.641
1x70	10.5	2.2	40.2	1570	0.443
1x95	10.5	2.3	42.1	1750	0.320
1x120	10.5	2.4	43.7	1910	0.253
1x150	10.5	2.4	45.3	2090	0.206
1x185	10.5	2.5	47.0	2270	0.164
1x240	10.5	2.5	49.3	2550	0.125
1x300	10.5	2.6	51.7	2870	0.100
1x400	10.5	2.7	54.9	3308	0.0778
1x500	10.5	2.8	59.8	3970	0.0605
1x630	10.5	3.0	63.6	4550	0.0469
3x50	10.5	3.6	78.1	4895	0.641
3x70	10.5	3.7	81.5	5400	0.443
3x95	10.5	3.8	84.7	5930	0.320
3x120	10.5	3.9	88.1	6494	0.253
3x150	10.5	4.0	91.1	7037	0.206
3x185	10.5	4.1	95.6	7818	0.164
3x240	10.5	4.2	100.8	8817	0.125
3x300	10.5	4.4	105.5	9840	0.100
3x400	10.5	4.6	112.2	11383	0.0778





AA/SCR/XLPE/SCR/(CWS)/CTS/PVC/SSTA/PVC 3.6/6(7.2) ~ 26/35(40.5) kV

Standards

- AS/NZS 1429.1
- GB/T 31840
- IEC 60502-2

Application

The cable is of high conductivity, good creep resistant property, high flexibility, high elongation, low resilience and connective stability. The cable is used for buildings without flame, including office, airports, hospitals, hotels, shopping malls and feeder lines of lighting in factories as well as another electric appliance.

AS/NZS 1429.1

- Conductor: Aluminum Alloy 8030
- Conductor Screen: Semi-Conductive Compound
- Insulation: XLPE
- Insulation Screen: Semi-Conductive Compound
- Metallic Screen: Copper Wire(Optional)/Copper Tape
- Bedding: PVC
- Armour: Double Layer Stainless Steel Tape
- Sheath: PVC/PE(Optional)
- (Optional) Flame Retardant Property
- (Optional) Fire Resistant Property
- (Optional) Anti-Termite & Rodent Property
- (Optional) Water Resistant Property



Section	Insulation Thickness	Sheath Thickness	Overall Diameter	Cable	Weight	DC. Electrical Re	esistance at 20°C
No.xmm ²	mm	mm	mm	Cu	Al	Cu	Al
	534/2555		2 6 (6/7 2) 2 0 (6 6/7 2) 1	AV.	/km	Ω/	'km
1.05	2.5		3.6/6(7.2)kV, 3.8/6.6(7.2)kV		550	0.727	1 20
1x25	2.5	1.8	21.7	700	550	0.727	1.20
1x35	2.5	1.8	22.6	820	610	0.524	0.868
1x50	2.5	1.8	24.0	990	690	0.387	0.641
1x70	2.5	1.8	25.4	1220	790	0.268	0.443
1x95	2.5	1.8	27.2	1490	920	0.193	0.320
1x120	2.5	1.9	28.7	1770	1040	0.153	0.253
1x150	2.5	2.0	31.7	2240	1330	0.124	0.206
1x185	2.5	2.0	33.3	2600	1480	0.0991	0.164
1x240	2.6	2.1	35.9	3180	1730	0.0754	0.125
1x300	2.8	2.2	38.7	3810	1990	0.0601	0.100
1x400	3.0	2.3	42.5	4840	2420	0.0470	0.0778
1x500	3.2	2.4	46.3	5860	2830	0.0366	0.0609
1x630	3.2	2.6	50.0	7200	3380	0.0283	0.0469
			6/10(12)kV, 6.35/11(12)kV				
1x25	3.4	1.8	23.2	1011	860	0,727	1.20
1x35	3.4	1.8	24.1	1150	935	0.524	0.868
1x50	3.4	1.8	25.2	1322	1031	0.387	0.641
1x70	3.4	1.8	26.8	1566	1155	0.268	0.443
1x95	3.4	1.9	28.5	1911	1328	0.193	0.320
1x120	3.4	2.0	30.1	2482	1745	0.153	0.253
1x150	3.4	2.0	31.7	2848	1921	0.124	0.206
1x185	3.4	2.1	33.4	3207	2101	0.0991	0.164
1x240	3.4	2.2	37.1	3813	2365	0.0754	0.125
1x300	3.4	2.2	39.5	4573	2715	0.0601	0.100
1x400	3.4	2.3	42.7	5573	3159	0.0470	0.0778
1x500	3.4	2.5	46.3	6812	3715	0.0366	0.0605
1x630	3.4	2.6	50.2	8159	4288	0.0283	0.0469
			8.7/15(17.5)kV				
1x25	4.5	1.8	25.6	919	769	0.727	1.20
1x35	4.5	1.8	26.6	1055	840	0.524	0.868
1x50	4.5	1.8	27.9	1219	929	0.387	0.641
1x70	4.5	1.9	30.8	1458	1047	0.268	0.443
1x95	4.5	2.0	32.7	1780	1197	0.193	0.320
1x120	4.5	2.0	34.1	2312	1575	0.153	0.253
1x150	4.5	2.1	35.9	2670	1743	0.124	0.206
1x185	4.5	2.2	37.6	3007	1901	0.0991	0.164
1x240	4.5	2.2	39.9	3621	2173	0.0754	0.125
1x300	4.5	2.3	42.5	4330	2470	0.0601	0.100
1x400	4.5	2.4	45.7	5281	2866	0.0470	0.0778
1x500	4.5	2.5	49.4	6442	3345	0.0366	0.0605
1x630	4.5	2.7	53.4	7766	3895	0.0283	0.0469
			12/20(24)kV, 12.7/22(24)kV	,			
1x35	5.5	1.9	30.1	1410	1200	0.524	0.868
1x50	5.5	2.0	31.5	1630	1320	0.387	0,641





• Conductor: Aluminum Alloy 8030

• Conductor Screen: Semi-Conductive Compound

Insulation: XLPE

Insulation Screen: Semi-Conductive CompoundMetallic Screen: Copper Wire(Optional)/Copper Tape

Bedding: PVC

Armour: Double Layer Stainless Steel Tape

Section	Insulation Thickness	Sheath Thickness	Overall Diameter	Cable	Weight	DC. Electrical Re	esistance at 20°0
No.xmm²	mm	mm	mm	Cu	Al	Cu	Al
NO.XIIIII	111111	711111	11111	kg	/km	Ω	'km
			12/20(24)kV, 12.7/22(24)kV	1			
1x70	5.5	2.0	33.1	1890	1460	0.268	0.443
1x95	5.5	2.1	34.9	2210	1640	0.193	0.320
1x120	5.5	2.1	36.4	2510	1780	0.153	0.253
1x150	5.5	2.2	38.1	2880	1970	0.124	0.206
1x185	5.5	2.2	39.7	3270	2150	0.0991	0.164
1x240	5.5	2.3	42.1	3900	2440	0.0754	0.125
1x300	5.5	2.4	44.7	4590	2770	0.0601	0.100
1x400	5.5	2.5	48.1	5670	3250	0.0470	0.077
1x500	5.5	2.6	51.4	6760	3730	0.0366	0.060
1x630	5.5	2.7	55.2	8150	4320	0.0283	0.0469
			18/30(36)kV, 19/33(36)kV				
1x50	8.0	2.2	38.7	2060	1760	0.387	0.641
1x70	8.0	2.2	40.2	2340	1910	0.268	0.443
1x95	8.0	2.3	42.1	2680	2100	0.193	0.320
1x120	8.0	2.3	43.7	3020	2290	0.153	0.253
1x150	8.0	2.4	45.5	3400	2490	0.124	0.206
1x185	8.0	2.4	47.0	3810	2690	0.0991	0.164
1x240	8.0	2.5	49.7	4490	3030	0.0754	0.125
1x300	8.0	2.6	52.1	5180	3300	0.0601	0.100
1x400	8.0	2.7	55.5	6310	3880	0.0470	0.077
1x500	8.0	2.8	59.2	7430	4390	0.0366	0.060
1x630	8.0	2.8	60.4	9280	5380	0.0283	0.046
			26/35(40.5)kV				
1x50	10.5	2.4	43.7	2600	2320	0.387	0.641
1x70	10.5	2.4	45.2	2890	2480	0,268	0.443
1x95	10.5	2.5	47.1	3270	2690	0.193	0.320
1x120	10.5	2.5	48.7	3600	2860	0.153	0.253
1x150	10.5	2.6	50.5	4020	3090	0.124	0.206
1x185	10.5	2.6	52.0	4410	3305	0.0991	0.164
1x240	10.5	2.7	54.7	5110	3660	0.0754	0.125
1x300	10.5	2.8	57.1	5900	4040	0.0601	0.100
1x400	10.5	2.9	60.5	6340	4520	0.0470	0.0778
1x500	10.5	3.0	65.5	8380	5290	0.0366	0.060
1x630	10.5	3.0	65.8	9950	6050	0.0283	0.0469





AA/SCR/XLPE/SCR/(CWS)/CTS/PVC/STA/PVC 3.6/6(7.2) ~ 26/35(40.5) kV

Standards

- AS/NZS 1429.1
- GB/T 31840
- IEC 60502-2

Application

The cable is of high conductivity, good creep resistant property, high flexibility, high elongation, low resilience and connective stability. The cable is used for buildings without flame, including office, airports, hospitals, hotels, shopping malls and feeder lines of lighting in factories as well as other electric appliance.

AS/NZS 1429.1

- Conductor: Aluminum Alloy 8030
- Conductor Screen: Semi-Conductive Compound
- Insulation: XLPE
- Insulation Screen: Semi-Conductive Compound
- Metallic Screen: Copper Wire(Optional)/Copper Tape
- Bedding: PVC
- Armour: Double Layer Galvanized Steel Tape
- Sheath: PVC/PE(Optional)
- (Optional) Flame Retardant Property
- (Optional) Fire Resistant Property
- (Optional) Anti-Termite & Rodent Property
- (Optional) Water Resistant Property

(0)	(®)

Section	Insulation Thickness	Sheath Thickness	Overall Diameter	Cable Weight	DC. Electrical Resistance at 20°0
No.xmm ²	mm	mm	mm	AA 8030 kg/km	AA 8030 Ω/km
		300.000	3.6/6(7.2)kV, 3.8/6.6(7.2)kV	kg/km	12/Km
3x25	2.5	2.3	40.5	2300	1.21
3x35	2.5	2.3	43.0	2550	0.868
3x50	2.5	2.4	46.1	2890	0.641
3x70	2.5	2.6	49.7	3340	0.443
3x95	2.5	2.7	53.8	3850	0.320
3x120	2.5	2.8	57.2	4310	0.253
3x150	2.5	2.9	60.9	4840	0.206
3x185	2.5	3.1	64.5	5430	0.164
3x240	2.6	3.2	70.5	6370	0.125
3x300	2.8	3.4	76.7	7610	0.100
3x400	3.0	3.8	86.2	10440	0.0778
3x500	3.2	4.0	94.3	11256	0.0605
3x630	3.2	4.2	102.4	13166	0.0469
3,030	5.2		6/10(12)kV, 6.35/11(12)kV	13100	0.0403
3x25	3.4	2.4	44.8	2322	1.21
3x35	3.4	2.5	47.4	2569	0.868
3x50	3.4	2.6	50.4	2909	0.641
3x70	3.4	2.7	54.0	3335	0.443
3x95	3.4	2.8	57.9	3857	0.320
3x120	3.4	2.9	61.3	4317	0.253
3x150	3.4	3.1	65.4	4911	0.206
3x185	3.4	3.2	68.8	5460	0.164
3x240	3.4	3.4	74.3	6360	0.125
3x300	3.4	3.6	80.9	7406	0.100
3x400	3.4	3.8	88.1	9480	0.0778
3x500	3.4	4.1	95.2	11256	0.0605
3x630	3.4	4.3	104.0	13165	0.0469
3,030	J.T	4.3	8.7/15(17.5)kV	13103	0.0103
3x25	4.5	2.6	48.4	2773	1,21
3x35	4.5	2.6	50.7	3047	0.868
3x50	4.5	2.8	53.7	3423	0.641
3x70	4.5	2.9	57.6	3911	0.443
3x95	4.5	3.0	60.8	4389	0.320
3x120	4.5	3.1	64.4	4935	0.253
3x150	4.5	3.2	67.6	5468	0.206
3x185	4.5	3.4	72.3	6166	0.164
3x240	4.5	3.5	77.7	7135	0.125
3x300	4.5	3.8	83.8	8922	0.100
3x400	4.5	4.0	91.0	10577	0.0778
3x500	4.5	4.0	98.5	12310	0.0605
3,300	4.5		12/20(24)kV, 12.7/22(24)kV	12310	0.0003
3x35	5.5	2.8	57.4	3620	0.868
3x50	5.5	2.9	60.6	4010	0.641
3x70	5.5	3.1	64.1	4540	0.443





• Conductor: Aluminum Alloy 8030

• Conductor Screen: Semi-Conductive Compound

Insulation: XLPE

Insulation Screen: Semi-Conductive CompoundMetallic Screen: Copper Wire(Optional)/Copper Tape

Bedding: PVC

Armour: Double Layer Galvanized Steel Tape

Section	Insulation Thickness	Sheath Thickness	Overall Diameter	Cable Weight	DC. Electrical Resistance at 20°C	
No.xmm ²	mm	mm	mm	AA 8030	AA 8030	
NO.XIIIII	:10111:	11011		kg/km	Ω/km	
			12/20(24)kV, 12.7/22(24)kV			
3x95	5.5	3.2	68.2	5090	0.320	
3x120	5.5	3.3	71.5	5640	0.253	
3x150	5.5	3.4	75.3	6260	0.206	
3x185	5.5	3.5	78.9	6890	0.164	
3x240	5.5	3.7	85.7	8690	0.125	
3x300	5.5	3.9	91.0	9810	0.100	
3x400	5.5	4.2	98.2	11560	0.0778	
3x500	5.5	4.4	105.3	13300	0.0605	
			18/30(36)kV, 19/33(36)kV			
3x50	8.0	3.3	75.1	6250	0.320	
3x70	8.0	3.5	78.7	6910	0.253	
3x95	8.0	3.6	84.0	7620	0.206	
3x120	8.0	3.8	87.5	8870	0.164	
3x150	8.0	3.9	91.3	9580	0.125	
3x185	8.0	4.0	94.9	10450	0.100	
3x240	8.0	4.2	100.3	11590	0.0778	
3x300	8.0	4.3	105.6	12850	0.0605	
			26/35(40.5)kV			
3x50	10.5	3.8	85.3	7898	0.320	
3x70	10.5	3.9	89.1	8589	0.253	
3x95	10.5	4.1	92.5	9290	0.206	
3x120	10.5	4.2	95.9	9984	0.164	
3x150	10.5	4.3	99.1	10694	0.125	
3x185	10.5	4.4	103.2	11545	0.100	
3x240	10.5	4.6	108,8	12854	0.0778	
3x300	10.5	4.7	113.7	14118	0.0605	





Part III High and Extra High Voltage Power Cable









CU(AL)/SCR/XLPE/SCR/CAS/PVC 36/66(72.5) ~ 127/230(245) kV

Standards

- AS/NZS 60840
- IEC 60840

Application

The cables is suitable for use in power transmission and distribution with rated power frequency voltage $36/66(72.5)kV^{2127/230(245)kV$.

AS/NZS 60840

- Conductor: Copper/Aluminum
- Conductor Screen: Semi-Conductive Compound
- Insulation: XLPE
- Insulation Screen: Semi-Conductive Compound
- Metallic Sheath: Corrugated Aluminum Sheath
- Sheath: PVC/PE(Optional)
- (Optional) Flame Retardant Property
- (Optional) Anti-Termite & Rodent Property
- (Optional) Special Water Resistant Property



Section	Insulation Thickness	CAS Thickness	Sheath Thickness	Overall Diameter		Weight	DC. Electrical Resistance at 20°C	
No.xmm ²	mm	mm	mm	mm	Cu	Al	Cu	Al
The later of the l			1,313341		kg/km		Ω/km	
			22	36/66(72.5)kV				
1x185	11.0	1.6	3.5	68.3	5250	4105	0.0991	0.164
1x240	11.0	1.6	3.5	69.0	5500	4015	0.0754	0.125
1x300	11.0	1.6	3.5	72.0	6300	4444	0.0601	0.100
1x400	11.0	1.7	3.5	75.0	7200	4725	0.0470	0.0778
1x500	11.0	1.8	4.0	79.0	8600	5507	0.0366	0.0605
1x630	11.0	1.8	4.0	83.0	10100	6202	0.0283	0.0469
1x800	11.0	1.9	4.0	87.0	12000	7050	0.0221	0.0369
1x1000	11.0	2.0	4.0	92.0	14400	8213	0.0176	0.0291
1x1200	11.0	2.1	4.5	98.0	16700	9276	0.0151	0.0247
1x1400	11.0	2.1	4.5	110.0	20110	11448	0.0129	0.0212
1x1600	11.0	2.2	4.5	105.0	20900	11001	0.0113	0.0186
1x2000	11.0	2.4	4.5	112.0	25400	13026	0.0009	0.0149
				64/110(123)kV				
1x240	14.0	1.7	3.5	76.0	6300	4815	0.0754	0.125
1x300	14.0	1.8	3.5	78.0	7000	5144	0.0601	0.100
1x400	14.0	1.8	3.5	81.0	8000	5525	0.0470	0.0778
1x500	14.0	1.9	4.0	86.0	9300	6207	0.0366	0.0605
1x630	14.0	2.0	4.0	90.0	11000	7102	0.0283	0.0469
1x800	14.0	2.0	4.0	84.0	12900	7950	0.0221	0.0369
1x1000	14.0	2.1	4.0	99.0	15400	9213	0.0176	0.0291
1x1200	14.0	2.2	4.5	104.0	17700	10276	0.0151	0.0247
1x1400	14.0	2.3	4.5	108.0	21530	12868	0.0129	0.0212
1x1600	14.0	2.4	4.5	111.0	22100	12201	0.0113	0.0186
1x2000	14.0	2.5	4.5	118.0	26500	14126	0.0009	0.0149
1x2500	14.0	2.6	4.5	128.0	33000	17533	0.0072	0.0127
				76/132(145)kV				
1x240	16.0	1.8	4.5	83.0	7100	5615	0.0754	0.125
1x300	16.0	1.8	4.5	86.0	7900	6044	0.0601	0.100
1x400	16.0	1.9	4.5	89.0	8900	6425	0.0470	0.0778
1x500	16.0	2.0	4.5	92.0	10200	7107	0.0366	0.0605
1x630	16.0	2.1	4.5	97.0	11900	8002	0.0283	0.0469
1x800	16.0	2.2	4.5	101.0	14000	9050	0.0221	0.0369
1x1000	16.0	2.2	4.5	106.0	16600	10413	0.0176	0.0291
1x1200	16.0	2.3	4.5	110.0	18600	11176	0.0151	0.0247
1x1600	16.0	2.4	4.5	116.0	22900	13001	0.0131	0.0186
1x2000	16.0	2.6	4.5	124.0	27400	15026	0.0009	0.0149
1x2500	16.0	2.8	4.5	131.0	34300	18833	0.0072	0.0127
IXESOO	10.0	2.0	4.5	87/161(170)kV	34300	10055	0.0072	0.0127
1x300	17.0	1.9	4.5	87.0	8400	6544	0.0601	0.100
1x400	17.0	1.9	4.5	91.0	9400	6925	0.0470	0.0778
1x500	17.0	2.0	4.5	94.0	10700	7607	0.0366	0.0605
1x630	17.0	2.1	4.5	98.0	12300	8402	0.0283	0.0469
1x800	17.0	2.2	4.5	102.0	14400	9450	0.0221	0.0469
1x1000	17.0	2.3	4.5	102.0	17000	10813	0.0221	0.0309
		2.3	4.5				0.0151	0.0291
1x1200	17.0			111.0	19000	11576		
1x1600	17.0	2.5	4.5	119.0	23500	13601	0.0113	0.0186
1x2000	17.0	2.6	4.5	125.0	28000	15626	0.0009	0.0149
1x2500	17.0	2.8	4.5	134.0	34500	19033	0.0072	0.0127





AS/NZS 60840

• Conductor: Copper/Aluminum

• Conductor Screen: Semi-Conductive Compound

Insulation: XLPE

Insulation Screen: Semi-Conductive CompoundMetallic Sheath: Corrugated Aluminum Sheath

Section	Insulation Thickness	CAS Thickness	Sheath Thickness	Overall Diameter	Cable Weight		Weight DC. Electrical Resistance	
No.xmm²	mm	mm	mm	mm	Cu kg	Al /km	Cu Ω/	Al km
				127/230(245)kV	-			
1x400	23.0	2.2	4.5	104.0	11000	8525	0.0470	0.0778
1x500	23.0	2.3	4.5	108.0	12100	9007	0.0366	0.0605
1x630	23.0	2.4	4.5	112.0	14200	10302	0.0283	0.0469
1x800	23.0	2.4	4.5	116.0	15800	10850	0.0221	0.0369
1x1000	23.0	2.4	4.5	119.0	17800	11613	0.0176	0.0291
1x1200	23.0	2.6	5.0	126.0	21500	14076	0.0151	0.0247
1x1400	23.0	2.6	5.0	130.0	24450	15788	0.0129	0.0212
1x1600	23.0	2.7	5.0	133.0	26000	16101	0.0113	0.0186
1x2000	23.0	2.8	5.0	139.0	30700	18326	0.0009	0.0149
1x2500	23.0	3.0	5.0	148.0	37800	22333	0.0072	0.0127







Power Grid Power Plant Power Station Underground Cabling System

PRODUCT CATALOGUE

iEngineering, Australia Pty. Ltd.
Office:-+61 (0)2 83207682
Mobile:-+61 (0) 467 055 252
Email:-dnaiker@iengaust.com.au
Addr:-Building T2A, Warawara Circuit,
Quaker Hills,NSW.

